

# External Interface Board Test Results for EIB S/N: 0058

**Overall Test Status: Passed!**

Technician: David Toner, Life #: 26565

Test performed: 04/13/25, 07:35 AM

## PSC I/O and MPS 5069 PLC I/O Test Results

**Visual LED Status Test: Passed!**

| I/O Port     | Voltage  | Pass/Fail |
|--------------|----------|-----------|
| OUT1-PSC OFF | 5.065 V  | Pass      |
| OUT1-PSC ON  | 0.033 V  | Pass      |
| OUT2-PSC OFF | 4.978 V  | Pass      |
| OUT2-PSC ON  | 0.031 V  | Pass      |
| OUT3-PSC OFF | 5.037 V  | Pass      |
| OUT3-PSC ON  | 0.032 V  | Pass      |
| OUT4-PSC OFF | 5.09 V   | Pass      |
| OUT4-PSC ON  | 0.032 V  | Pass      |
| IN1-PSC OFF  | -0.0 V   | Pass      |
| IN1-PSC ON   | 20.067 V | Pass      |
| IN2-PSC OFF  | -0.0 V   | Pass      |
| IN2-PSC ON   | 19.901 V | Pass      |
| IN3-PSC OFF  | -0.0 V   | Pass      |
| IN3-PSC ON   | 19.845 V | Pass      |
| IN4-PSC OFF  | -0.0 V   | Pass      |
| IN4-PSC ON   | 19.764 V | Pass      |
| 24V_PS       | 24.235 V | Pass      |