

# External Interface Board Test Results for EIB S/N: 0070

**Overall Test Status: Passed!**

Technician: David Toner, Life #: 26565

Test performed: 04/13/25, 08:28 AM

## PSC I/O and MPS 5069 PLC I/O Test Results

**Visual LED Status Test: Passed!**

| I/O Port     | Voltage  | Pass/Fail |
|--------------|----------|-----------|
| OUT1-PSC OFF | 5.095 V  | Pass      |
| OUT1-PSC ON  | 0.033 V  | Pass      |
| OUT2-PSC OFF | 5.112 V  | Pass      |
| OUT2-PSC ON  | 0.033 V  | Pass      |
| OUT3-PSC OFF | 5.048 V  | Pass      |
| OUT3-PSC ON  | 0.033 V  | Pass      |
| OUT4-PSC OFF | 5.031 V  | Pass      |
| OUT4-PSC ON  | 0.032 V  | Pass      |
| IN1-PSC OFF  | -0.0 V   | Pass      |
| IN1-PSC ON   | 19.829 V | Pass      |
| IN2-PSC OFF  | -0.0 V   | Pass      |
| IN2-PSC ON   | 19.742 V | Pass      |
| IN3-PSC OFF  | -0.0 V   | Pass      |
| IN3-PSC ON   | 19.967 V | Pass      |
| IN4-PSC OFF  | -0.0 V   | Pass      |
| IN4-PSC ON   | 19.96 V  | Pass      |
| 24V_PS       | 24.235 V | Pass      |