

External Interface Board Test Results for EIB S/N: 0087

Overall Test Status: Passed!

Technician: David Toner, Life #: 26565

Test performed: 04/13/25, 10:38 AM

PSC I/O and MPS 5069 PLC I/O Test Results

Visual LED Status Test: Passed!

| I/O Port | Voltage | Pass/Fail |
|--------------|----------|-----------|
| OUT1-PSC OFF | 5.105 V | Pass |
| OUT1-PSC ON | 0.033 V | Pass |
| OUT2-PSC OFF | 5.086 V | Pass |
| OUT2-PSC ON | 0.033 V | Pass |
| OUT3-PSC OFF | 5.118 V | Pass |
| OUT3-PSC ON | 0.033 V | Pass |
| OUT4-PSC OFF | 5.039 V | Pass |
| OUT4-PSC ON | 0.032 V | Pass |
| IN1-PSC OFF | -0.0 V | Pass |
| IN1-PSC ON | 19.741 V | Pass |
| IN2-PSC OFF | -0.0 V | Pass |
| IN2-PSC ON | 19.834 V | Pass |
| IN3-PSC OFF | -0.0 V | Pass |
| IN3-PSC ON | 19.591 V | Pass |
| IN4-PSC OFF | -0.0 V | Pass |
| IN4-PSC ON | 19.861 V | Pass |
| 24V_PS | 24.235 V | Pass |