

External Interface Board Test Results for EIB S/N: 0013

Overall Test Status: Passed!

Technician: Kevin Mandracchia, Life #: 25337

Test performed: 04/12/25, 08:20 AM

PSC I/O and MPS 5069 PLC I/O Test Results

Visual LED Status Test: Passed!

I/O Port	Voltage	Pass/Fail
OUT1-PSC OFF	5.091 V	Pass
OUT1-PSC ON	0.033 V	Pass
OUT2-PSC OFF	5.013 V	Pass
OUT2-PSC ON	0.031 V	Pass
OUT3-PSC OFF	5.119 V	Pass
OUT3-PSC ON	0.033 V	Pass
OUT4-PSC OFF	5.085 V	Pass
OUT4-PSC ON	0.033 V	Pass
IN1-PSC OFF	-0.0 V	Pass
IN1-PSC ON	19.548 V	Pass
IN2-PSC OFF	-0.0 V	Pass
IN2-PSC ON	19.881 V	Pass
IN3-PSC OFF	-0.0 V	Pass
IN3-PSC ON	20.019 V	Pass
IN4-PSC OFF	0.0 V	Pass
IN4-PSC ON	19.974 V	Pass
24V_PS	24.236 V	Pass