

# External Interface Board Test Results for EIB S/N: FAIL01

**Overall Test Status: Failed!**

Technician: Mike Capotosto, Life #: 26357

Test performed: 04/08/25, 05:29 PM

## PSC I/O and MPS 5069 PLC I/O Test Results

**Visual LED Status Test: Failed!**

I/O Port	Voltage	Pass/Fail
OUT1-PSC OFF	5.059 V	Pass
OUT1-PSC ON	0.033 V	Pass
OUT2-PSC OFF	5.091 V	Pass
OUT2-PSC ON	0.033 V	Pass
OUT3-PSC OFF	5.007 V	Pass
OUT3-PSC ON	0.032 V	Pass
OUT4-PSC OFF	5.07 V	Pass
OUT4-PSC ON	0.032 V	Pass
IN1-PSC OFF	-0.0 V	Pass
IN1-PSC ON	-0.0 V	Fail
IN2-PSC OFF	-0.0 V	Pass
IN2-PSC ON	-0.0 V	Fail
IN3-PSC OFF	-0.0 V	Pass
IN3-PSC ON	-0.0 V	Fail
IN4-PSC OFF	-0.0 V	Pass
IN4-PSC ON	-0.0 V	Fail
24V_PS	24.237 V	Pass