

External Interface Board Test Results for EIB S/N: PASS01

Overall Test Status: Passed!

Technician: Mike Capotosto, Life #: 26357

Test performed: 04/08/25, 05:26 PM

PSC I/O and MPS 5069 PLC I/O Test Results

Visual LED Status Test: Passed!

I/O Port	Voltage	Pass/Fail
OUT1-PSC OFF	5.019 V	Pass
OUT1-PSC ON	0.032 V	Pass
OUT2-PSC OFF	4.951 V	Pass
OUT2-PSC ON	0.032 V	Pass
OUT3-PSC OFF	5.07 V	Pass
OUT3-PSC ON	0.033 V	Pass
OUT4-PSC OFF	5.039 V	Pass
OUT4-PSC ON	0.032 V	Pass
IN1-PSC OFF	-0.0 V	Pass
IN1-PSC ON	19.925 V	Pass
IN2-PSC OFF	-0.0 V	Pass
IN2-PSC ON	19.73 V	Pass
IN3-PSC OFF	-0.0 V	Pass
IN3-PSC ON	19.931 V	Pass
IN4-PSC OFF	-0.0 V	Pass
IN4-PSC ON	20.009 V	Pass
24V_PS	24.238 V	Pass