

External Interface Board Test Results for EIB S/N: 0010

Overall Test Status: Passed!

Technician: Kevin Mandracchia, Life #: 25337

Test performed: 04/12/25, 07:44 AM

PSC I/O and MPS 5069 PLC I/O Test Results

Visual LED Status Test: Passed!

I/O Port	Voltage	Pass/Fail
OUT1-PSC OFF	5.068 V	Pass
OUT1-PSC ON	0.033 V	Pass
OUT2-PSC OFF	5.044 V	Pass
OUT2-PSC ON	0.034 V	Pass
OUT3-PSC OFF	5.042 V	Pass
OUT3-PSC ON	0.032 V	Pass
OUT4-PSC OFF	5.092 V	Pass
OUT4-PSC ON	0.032 V	Pass
IN1-PSC OFF	-0.0 V	Pass
IN1-PSC ON	19.681 V	Pass
IN2-PSC OFF	-0.0 V	Pass
IN2-PSC ON	19.834 V	Pass
IN3-PSC OFF	-0.0 V	Pass
IN3-PSC ON	19.937 V	Pass
IN4-PSC OFF	-0.0 V	Pass
IN4-PSC ON	19.831 V	Pass
24V_PS	24.235 V	Pass