

External Interface Board Test Results for EIB S/N: 0019

Overall Test Status: Passed!

Technician: Kevin Mandracchia, Life #: 26565

Test performed: 04/12/25, 09:42 AM

PSC I/O and MPS 5069 PLC I/O Test Results

Visual LED Status Test: Passed!

I/O Port	Voltage	Pass/Fail
OUT1-PSC OFF	5.048 V	Pass
OUT1-PSC ON	0.032 V	Pass
OUT2-PSC OFF	4.999 V	Pass
OUT2-PSC ON	0.031 V	Pass
OUT3-PSC OFF	5.038 V	Pass
OUT3-PSC ON	0.033 V	Pass
OUT4-PSC OFF	5.069 V	Pass
OUT4-PSC ON	0.032 V	Pass
IN1-PSC OFF	-0.0 V	Pass
IN1-PSC ON	20.047 V	Pass
IN2-PSC OFF	-0.0 V	Pass
IN2-PSC ON	19.995 V	Pass
IN3-PSC OFF	-0.0 V	Pass
IN3-PSC ON	19.874 V	Pass
IN4-PSC OFF	-0.0 V	Pass
IN4-PSC ON	19.87 V	Pass
24V_PS	24.236 V	Pass