

Day-Ahead Load Forecast Accuracy of U.S. Balancing Authorities, 2015–2026: A Scorecard from Public EIA-930 Data

Cardinal Grid Notes, No. 1 DOI: 10.5281/zenodo.22749436

Ricardo W. C. Guerra Filho

Cardinal Grid (independent open initiative)

ORCID 0000-0001-6699-9951 ricardo.guerra@cardinalgrid.com

Abstract—Balancing authorities (BAs) in the contiguous United States report to the U.S. Energy Information Administration, through Form EIA-930, both the hourly demand that occurred and the day-ahead demand forecast they produced the previous day. This note scores those forecasts for the full public record, from 1 July 2015 to 10 September 2026. For each BA-day with at least 20 valid hours, mean absolute percentage error (MAPE), bias, root-mean-square error and the error at the hour of the actual daily peak are computed after explicit data-quality rules. Of 72 BAs in the files, 58 report both series and 42 meet the eligibility criteria for ranking. The demand-weighted day-ahead MAPE across eligible BAs is 3.56%, with a median BA value of 4.20%. At the hour of the daily peak, the forecast was below actual demand on 59% of eligible BA-days, and the share has increased since 2019; one eligible BA-day in a hundred under-forecasts the peak by more than 27.7%. The highest error values in the ranking are dominated by reporting problems rather than forecasting problems, which motivates the data-quality layer of the underlying tool. Code, results and the event calendar are archived with a DOI.

Index Terms—load forecasting, balancing authority, EIA-930, forecast evaluation, data quality, bulk power system reliability

I. INTRODUCTION

The day-ahead load forecast is the quantity against which a balancing authority commits generation and procures operating reserves. When the forecast is below the load that occurs, reserves are short; the joint FERC–NERC inquiry into Winter Storm Elliott documented day-ahead under-forecasts of up to 11.6% at one BA, with peak-load forecast errors around 10% for most core BAs on December 23, contributing to emergency operations and firm load shed [1]. The joint review of the January 2025 Arctic events records the largest under-forecast by a BA at 11.8% in Winter Storm Uri, 12.5% in Elliott and 14% in Winter Storms Gerri and Heather, with errors peaking early in the storms as the weather worsened [2]. NERC’s 2025 Long-Term Reliability Assessment projects summer peak demand growth of over 224 GW in ten years, most of it data centers, and reports increasing load-forecast errors on extreme days in ERCOT [3]; the U.S. Department of Energy estimates that, absent corrective action, outage risk could increase roughly 100-fold by 2030 [4].

These findings concern specific events. A systematic, public measurement of day-ahead forecast accuracy across all BAs

has been possible since July 2015, when EIA began collecting hourly demand and the day-ahead demand forecast from every BA in the contiguous United States [5]. This note presents that measurement for the full record to date, using an open-source tool [6], and reports three results: the distribution of forecast error across BAs, the accuracy of the largest operators, and a systematic tendency to under-forecast the daily peak hour. The purpose is descriptive. No BA has been contacted, and the note does not attempt to explain any individual BA’s performance.

II. DATA

A. Source and definitions

Form EIA-930 requires each NERC-registered BA to report, in a daily file due by 7:00 a.m. Eastern, “yesterday’s hourly day-ahead demand forecast for today” and the hourly demand that occurred, as “hourly integrated values in megawatts by hour ending time” with UTC time stamps [7]. The instructions define the forecast field only as “the day-ahead demand forecast” and state that a BA which does not produce a forecast directly comparable to reported demand should report “the day-ahead demand forecast generated in the normal course of business”. EIA therefore prescribes neither the forecasting method, nor its inputs, nor the time of day at which the forecast is produced. The forecast series is each BA’s operational day-ahead forecast as it existed the day before, at that BA’s own cut-off time.

B. Coverage

The analysis uses EIA’s six-month balance files from 1 July 2015 to 10 September 2026 [5], which contain 72 BA codes. Generation-only BAs report no demand and are excluded automatically. 58 BAs report both demand and forecast for enough hours to be scored. EIA’s own imputation flag for demand is retained; imputed values account for less than 0.001% of scored hours.

III. METHODS

A. Metrics

Let D_h and F_h be demand and forecast in hour h of a BA-day, and $e_h = F_h - D_h$ (positive values are over-forecasts).

For each BA-day with a set H of valid hours,

$$\text{MAPE} = \frac{1}{|H|} \sum_{h \in H} \frac{|e_h|}{D_h}, \quad \text{bias} = \frac{1}{|H|} \sum_{h \in H} \frac{e_h}{D_h}, \quad (1)$$

$$\text{RMSE} = \sqrt{\frac{1}{|H|} \sum_{h \in H} e_h^2}, \quad \epsilon_{\text{peak}} = \frac{e_{h^*}}{D_{h^*}}, \quad h^* = \arg \max_{h \in H} D_h. \quad (2)$$

The peak-hour error ϵ_{peak} is the error at the hour of the actual daily peak, which is the quantity relevant to reserve adequacy. BA-day values are aggregated over months, years and the whole period as hour-weighted means; the demand-weighted MAPE across BAs weights each BA-day by its mean demand and its number of valid hours.

B. Data-quality rules

Three rules are applied before any error is computed. (i) Hours with $D_h \leq 0$ or $F_h \leq 0$ are excluded. (ii) Hours with F_h/D_h outside $[1/2, 2]$ are flagged as implausible and excluded: the band retains every documented extreme-weather miss, including the 11.6% Elliott case, and removes unit errors, partial reports and stale values. (iii) A BA-day is scored only if it has at least 20 valid hours. In addition, a BA whose median daily bias over the whole period exceeds $\pm 25\%$ is treated as a series mismatch, in which forecast and demand do not describe the same quantity, and is listed separately rather than ranked. Over the period, 114,714 hours were flagged under rule (ii), and AEC (median bias +88%), PSEI (median bias -29%) were excluded as series mismatches.

C. Eligibility and events

BAs enter the ranking if they have at least 180 scored days, a mean demand of at least 500 MW, and no series mismatch; 42 BAs qualify. Named events are fixed date windows taken from the public inquiries: Winter Storm Uri (13–20 February 2021), the Pacific Northwest heat dome (26–30 June 2021), Winter Storm Elliott (23–26 December 2022), the July–August 2023 heat wave, the January 2024 Arctic storms (13–17 January 2024) and the January 2025 cold wave (19–24 January 2025), each restricted to the EIA regions the inquiries identify.

IV. RESULTS

A. Distribution of forecast error across BAs

Table I summarizes the period. Fig. 1 shows the whole-period MAPE of every eligible BA. The demand-weighted MAPE is 3.56% and the median BA is at 4.20%. The five lowest values are PGE (1.8%), BPAT (2.0%), TVA (2.2%), ERCO (2.5%), GCPD (2.5%); the five highest are LDWP (7.8%), WACM (8.6%), WALC (9.9%), TEPC (11.1%), FPC (22.0%).

B. The largest operators

Table II reports the largest ISOs/RTOs and utilities. Fig. 2 shows their yearly MAPE. Two features of Fig. 2 are noted without interpretation: the increase in the yearly MAPE of CISO and SWPP since 2023, and the 2015 value of AZPS; each may reflect forecasting, a change in what the BA reports, or both. The 2026 value covers January to September.

TABLE I
SUMMARY OF THE SCORED RECORD, JULY 2015 TO SEPTEMBER 2026.

Quantity	Value
BAs in the EIA-930 files	72
BAs reporting demand and forecast	58
BAs eligible for ranking	42
BA-days scored	209,987
Hours scored	5,033,125
Hours flagged implausible	114,714
Demand-weighted MAPE, eligible BAs	3.56%
Median BA MAPE, eligible BAs	4.20%
BA-days with forecast below peak-hour demand	59%
1st percentile of peak-hour error	−27.7%

TABLE II
LARGEST BALANCING AUTHORITIES: WHOLE-PERIOD DAY-AHEAD FORECAST ERROR. RANK IS AMONG THE 42 ELIGIBLE BAs. THE LAST COLUMN IS THE 1ST PERCENTILE OF THE PEAK-HOUR ERROR, I.E. THE UNDER-FORECAST EXCEEDED ON ONE BA-DAY IN A HUNDRED.

Rank	BA	Region	MAPE	Bias	$ \epsilon_{\text{peak}} $ mean	$P_1(\epsilon_{\text{peak}})$
2	BPAT	NW	2.01%	0.12%	2.14%	−7.0%
3	TVA	TEN	2.22%	0.66%	2.35%	−6.9%
4	ERCO	TEX	2.46%	0.41%	2.52%	−8.0%
6	ISNE	NE	2.61%	−1.65%	1.41%	−4.6%
9	MISO	MIDW	2.76%	2.41%	2.65%	−3.6%
10	DUK	CAR	2.81%	0.52%	2.97%	−10.0%
11	SOCO	SE	2.84%	−1.97%	2.19%	−7.9%
12	NYIS	NY	2.84%	−2.36%	2.94%	−8.6%
15	PJM	MIDA	3.23%	−1.23%	2.23%	−6.8%
20	SWPP	CENT	4.18%	2.84%	3.97%	−9.0%
21	FPL	FLA	4.19%	−2.17%	4.45%	−16.4%
26	CISO	CAL	4.33%	−1.70%	3.23%	−28.7%
27	AZPS	SW	4.35%	−0.20%	3.50%	−17.5%
32	PACE	NW	5.04%	3.85%	4.49%	−20.3%

C. Peak-hour bias

Fig. 3 shows, for each year, the share of eligible BA-days on which the forecast at the hour of the actual daily peak was below the demand that occurred. Over the whole period the share is 59%; an unbiased forecast would give a value near 50%. The share has increased since 2019 and exceeded 60% in every year from 2023. The first percentile of the peak-hour error across all eligible BA-days is −27.7%.

D. Named events

Table III lists, for each event window, the eligible BA with the largest peak-hour under-forecast, and Fig. 4 shows the distribution across eligible BAs. The largest single eligible BA-day miss in the record is PACE on 2016-04-02, a forecast 50% below a 10,048 MW peak; single-day extremes of this size may still be reporting problems, and the percentile statistics above are the robust figures.

V. DISCUSSION

A. Interpretation

Three points follow from the results. First, typical day-ahead accuracy is a few percent, and the largest operators are at or below the median; the long tail of the ranking is, on inspection,




Fig. 1. Whole-period hour-weighted day-ahead MAPE of the 42 eligible balancing authorities, July 2015 to September 2026, sorted by value; the dashed line is the median. Filled bars are the largest ISOs/RTOs and utilities listed in Table II. Source: EIA-930 six-month files [5]; scoring by [6].




Fig. 2. Yearly hour-weighted MAPE of the largest balancing authorities. The 2026 value covers January to September.

a tail of reporting quality rather than of forecasting skill, which is why the scoring tool carries an explicit data-quality layer and why the highest values should be read as “data or forecast problem”, not “forecast problem”. Second, the peak-hour bias is systematic and has grown: on roughly six BA-days in ten the forecast used for reserve procurement was below the load that occurred at the peak, and the share has risen through the period of rapid large-load growth. The mechanism is not identified here; candidate explanations include structural load growth outpacing model updates and asymmetric loss functions in operational practice. Third, event windows show that misses




Fig. 3. Share of eligible BA-days on which the day-ahead forecast was below actual demand at the hour of the daily peak, by year. The dashed line marks 50%. The 2026 value covers January to September.

TABLE III
LARGEST PEAK-HOUR UNDER-FORECAST BY AN ELIGIBLE BA DURING EACH NAMED EVENT WINDOW.

Event	BA (region)	Under-forecast at peak
Heat wave (Jul.–Aug. 2023)	WALC (SW)	41.0%
Arctic storms (Jan. 2024)	WACM (NW)	18.4%
Winter Storm Elliott (Dec. 2022)	LGEE (MIDW)	16.4%
Cold wave (Jan. 2025)	LGEE (MIDW)	13.7%
Pacific NW heat dome (June 2021)	SCL (NW)	12.5%
Winter Storm Uri (Feb. 2021)	AECI (MIDW)	6.5%

of 10–20% at the peak hour are not confined to the Elliott case documented by FERC and NERC.

B. Limitations

Forecasts are as submitted to EIA and may differ from what operators used internally; EIA’s revision rules apply to




Fig. 4. Distribution across eligible BAs of the worst peak-hour under-forecast within each named event window (0 means the BA never under-forecast the peak during the window).

measured data, not to the forecast. The forecast horizon is not the same for every BA: a forecast closed at 9 a.m. the day before covers 15 to 39 hours ahead, one closed at 5 p.m. covers 7 to 31, and EIA does not record the cut-off time, so part of the difference between BAs is horizon rather than skill; comparisons of a given BA over time are not affected. Several small BAs' series contain errors that the plausibility band does not catch. Event windows are fixed dates rather than weather-defined extreme days. No BA has been contacted for comment.

VI. CONCLUSION

The public EIA-930 record allows the day-ahead load forecasts of every U.S. balancing authority to be scored continuously without any operator's cooperation. Over July 2015 to September 2026, eligible BAs show a demand-weighted day-ahead MAPE of 3.56%, a systematic and growing tendency to under-forecast the daily peak hour, and a tail of apparent errors that are reporting problems. The scoring tool, its results and the event calendar are open and updated daily, and subsequent notes will address data quality in the EIA-930 series and the attribution of errors to weather.

DATA AND CODE AVAILABILITY

Data: EIA-930 six-month balance files [5]. Code and results: [6] (Apache-2.0), archived at <https://doi.org/10.5281/zenodo.22697386>. This note and its figures are reproduced by `analysis.py` and `paper.py` in <https://github.com/cardinalgrid/notes>.

REFERENCES

- [1] FERC, NERC and Regional Entity Staff, "Inquiry into bulk-power system operations during december 2022 winter storm Elliott: Final report," Federal Energy Regulatory Commission and North American Electric Reliability Corporation, Tech. Rep., Oct. 2023. [Online]. Available: <https://www.ferc.gov/news-events/news/ferc-nerc-release-final-report-lessons-winter-storm-elliott>
- [2] —, "January 2025 Arctic events: A system performance review," Federal Energy Regulatory Commission, Tech. Rep., Apr. 2025. [Online]. Available: <https://www.ferc.gov/news-events/news/ferc-nerc-issue-report-system-performance-during-january-2025-arctic-weather>
- [3] North American Electric Reliability Corporation, "2025 long-term reliability assessment," NERC, Tech. Rep., Jan. 2026. [Online]. Available: https://www.nerc.com/globalassets/our-work/assessments/nerc_ltra_2025.pdf
- [4] U.S. Department of Energy, "Report on evaluating U.S. grid reliability and security," DOE, Tech. Rep., Jul. 2025. [Online]. Available: <https://www.energy.gov/sites/default/files/2025-07/DOE%20Final%20EO%20Report%20%28FINAL%20JULY%207%29.pdf>
- [5] U.S. Energy Information Administration, "Hourly electric grid monitor: Six-month balance files," <https://www.eia.gov/electricity/gridmonitor/>, 2026, six-month files from July 2015 onward; accessed 10 Sep. 2026.
- [6] R. W. C. Guerra Filho, "BA forecast scorecard: scoring U.S. balancing authorities' day-ahead load forecasts from EIA-930 (v0.1.1)," Software archived on Zenodo, doi:10.5281/zenodo.22697387, 2026, source: <https://github.com/cardinalgrid/ba-forecast-scorecard>.
- [7] U.S. Energy Information Administration, "Form EIA-930, hourly and daily balancing authority operations report: Instructions," https://www.eia.gov/survey/form/eia_930/instructions.pdf, 2026, accessed 10 Sep. 2026.