

_ 4	4	•	A/R	35	_			2	1		_	_	,
1050	IDEC	SMD	A/R TY DUCT	WEIDMULLER	SQUARE D	BUSSMAN	BUSSMAN	WEIDMULLER	PHOENIX CONTACT	CONTROL MICROSYSTEMS	STAHLIN	STAHLIN	
SR3B-05	RR2BA-U	OS-900A-12-0	NPB6 SERIES	1020100000	PK7GTA	MDL-5	MDL-3	10143000000	STEP-PS-100-240ACDC/	P200-1A00-AA11	BP18P16	DSW18161ØHPL	0,11,100
RELAY BASE, BLADE	CONTROL RELAY, 12VDC, DPDT	OPTICAL LIQUID LEVEL SENSOR, 12VDC	WIRE DUCT, THIN FINGER, BLACK	TERMINAL BLOCK, WDU4, 22-10AWG, BEIGE	GROUND BAR, 7 POSITION	FUSE, 5 AMP	FUSE, 3 AMP	FUSED TERMINAL BLOCK	POWER SUPPLY, 120VAC-12VDC, 2.1 AMPS	SCADAPACK LP, 5 ANALOG INPUTS, 2 ANALOG OUTPUTS, 8 I/O, INTEGRATED 900MHz RADIO	SUBPANEL, 18"×16"	ENCLOSURE, FIBERGLASS, WINDOW DOOR, 18"x16"x10"	V 0 0 1 P 1 P 0 1 P

TERMINAL
BLOCK
LAYOUT

	L
	N
Γ	GND
Γ	+12V
	+12V
	+12V
	+12V
Γ	+12V
	COM
	COM
	COM
	COM
	СОМ
	DIO-Ø
L	DIO-1
L	DIO-2
	DIO-3
L	DIO-4
L	DIO-5
L	DIO-6
L	DIO-7
L	VL00P
L	VL00P
L	VL00P
L	AI-COM
L	AI-COM
L	AI-Ø
L	AI-1
L	AI-2
L	AI-3
L	AI-4
L	AI-5
L	AO-COM
L	A0-Ø
L	AO-1

_			_
70104F01	JWG	DRAWNET: JHM	7Ø1Ø4
31	REET NO. 1/2	NONE	10/01/07

SCADA DEMO RAISED WATER SYSTEM PANEL LAYOUT & BOM

MISSISSIPPI STATE UNIVERSITY DEPT. OF COMPUTER SCIENCE AND ENGINEERING

₹	>	-			
REVISION	FOR CONSTRUCTION	RECORD DRAWING			
втм	10/1/07	1/8/ø8			

					Ĺ	
				RECORD DRAWING	FOR CONSTRUCTION	

Control Systems, Inc.

3822 HIGHWAY 25 MONTEVALLO, ALABAMA 35115 (205) 679-4000 FAX: (205) 679-4274