

DAILY COAL REPORT											
COAL PARTICULARS FOR (upto 2400 Hrs on) :						DATE OF REPORT : 27.06.25					
POWER STATION & CAPACITY		COAL OPENING STOCK	COAL RECEIPT	COAL CONSUMPTION	COAL CLOSING STOCK	TOTAL STOCK (IND+IMP)	NO. OF DAYS STOCK	GENERATION in MU	UNITS IN SERVICE & SP. COAL CONS	MONTHLY CUMULATIVE	
										RECEIPT	CONSUMPTION
										METRIC TONNES	
TTPS 5*210 MW	(IND)	4,11,089	21,855	9,013	4,23,931	4,23,931	23.0	10.103	3,4,5 0.892	2,66,406	2,67,554
	(IMP)	0	0	0	0					0	0
MTPS I 4*210 MW	IB ARR	0	0	0	0	1,47,139	12.0	16.304	1,2,3,4 0.831	0	0
	KKL	60,744	6,983	11,701	55,847					1,75,734	2,59,091
	NCTPS IND	63,605	2,242	1,844	64,003					6,102	36,936
	SCCL	27,289	0	0	27,289					0	0
	TAL ARR	0	0	0	0					0	0
	IMP	0	0	0	0					0	0
MTPS II 1*600 MW	IB ARR	0	0	0	0	1,33,356	12.0	10.700	1 0.864	0	0
	KKL	89,594	6,014	8,674	86,934					1,64,086	1,74,894
	NCTPS IND	0	1,591	469	1,122					5,619	4,497
	SCCL	45,404	0	104	45,300					0	1,596
	TAL ARR	0	0	0	0					0	4,261
	IMP	0	0	0	0					0	0
NCTPS I 3*210 MW	(IND)	1,61,480	17,724	4,404	1,66,079	1,66,079	5.6	5.010	2 0.879	4,31,340	1,73,876
	(IMP)	0	0	0	0					0	0
NCTPS II 2*600 MW	(IND)			8,721				9.397	1 0.928		2,93,678
	(IMP)			0							0
NCTPS III 1*800 MW	From ECHS(IND)	0	0	0	0	4,15,364	-	16.325	1 0.619	0	0
	SCCL	1,52,081	0	5,050	1,47,031					28,445	1,23,096
	(IMP)	2,73,383	0	5,050	2,68,333					1,36,162	96,897
TOTAL	IND (A)	10,11,286	56,408	49,979	10,17,536	12,85,869	20.9	67.839		10,77,731	13,39,478
	IMP(D)	2,73,383	0	5,050	2,68,333					1,36,162	96,897
NCTPS ECHS	IND(B)	2,09,109	6,797	12,724	2,03,182	2,14,121		DAYS		2,93,901	3,10,339
	IMP(E)	10,939	0	0	10,939					0	0
KARAIKKAL	IND(C)	2,77,242	30,697	16,159	2,91,780	2,91,780		FOR MTPS		1,83,887	3,51,596
	IMP(F)	0	0	0	0					0	0

TTPS: .Unit 3,4,5 are in service; Unit 3: was lighted up @ 1235H/26.06.25 & sync @1609H /26.06.25 Unit 1&2 : Not in Service.

MTPS I: Units 1,2 ,3 & 4 are in service. As per ON approved by CE/MTPS-1 on 24.06.25, collection of stones from AIPS/IND-0.800 MT & TAL-KIKP-176.270 MT & Iron m/l from Tal-KIKP-1.730 MT (Total = 178.800MT) from CHP-I & II divisions has been withdrawn from Coal stock.

MTPS-II: Unit was synchronised @1631H/25.6.25 .

NCTPS I : Units 2 is in service. Unit 1 not in service due to Boiler tube puncture @ 2301H/26.06.25. Unit 3 not in service due to Boiler tube puncture @ 0516H/25.06.25

NCTPS II: Unit 1 is in service. Unit 2 : AOH on 25.06.25

NCTPS III : Unit was synchronised at 0620Hrs/25.06.25