




NOTE: DIMENSIONS FOR REFERENCE ONLY, NOT FOR CONSTRUCTION UNLESS CERTIFIED BY NEPTUNE BENSON.



UPPER HEAD AND ELEMENT DETAIL




SECTION A-A


FOOT PRINT

MARK	QTY.	DESCRIPTION	PART #	REMARKS
1	1	DEFENDER FILTER SP-29-36-500	SP-29-36-500	
2	1	AUTOMATIC FILTER PROGRAMMER MODEL : RMF 120V	MICRORMF	SHIP LOOSE
3	1	VACUUM TRANSFER UNIT	VACUUM	SHIP LOOSE
4	1	FILTER /REGULATOR 1/2" NPT CONNECTION	1000-5527	SHIP LOOSE
5	1	GAUGE PANEL KIT	1000-8245	SHIP LOOSE
6	1	VACUUM TRANSFER PLUMBING KIT	1000-5821	NOT SHOWN SHIP LOOSE
7	1	DEFENDER DRAIN VALVE 3" LEVER	1000-7320	SHIP LOOSE

NOTES:

1. FILTER TANK IS TO BE CONSTRUCTED OF HIGH QUALITY A36 CARBON STEEL, UPPER HEAD THICKNESS = 3/16" (4.76mm), LOWER HEAD THICKNESS = 3/4" (19.05mm) & SHELL THICKNESS = 3/16" (4.76mm).
2. INTERIOR OF TANK IS LINED WITH FLEXSOL 3000. EXTERIOR IS COATED WITH 5-8 MILS OF HIGH SOLIDS ENAMEL. NO WELDING OR EXTREME HEAT IS TO BE APPLIED TO TANK AFTER LINING OR COATING PROCESS IS DONE.
3. ELECTRICAL REQUIREMENTS: 120VAC-10-60Hz, 15 AMP CIRCUIT PROTECTION.
4. LOCATE ALL ELECTRICAL ITEMS IN A NON-HAZARDOUS LOCATION.
5. ELECTRICAL CONNECTIONS ARE THE RESPONSIBILITY OF THE CUSTOMER.
6. MEDIA QUANTITIES ARE INDICATED FOR INFORMATIONAL PURPOSES ONLY.
7. ALL PNEUMATIC TUBING SUPPLIED BY POOL CONTRACTOR.
8. DRAIN VALVE MUST BE A BUTTERFLY VALVE AND INSTALLED DIRECTLY ON THE 3" DRAIN FLANGE.
9. DESIGN PRESSURE IS 50 PSI (344.73 kpa). HYDROSTATICALLY TESTED TO 75 PSI (517.11 kpa).
10. THIS PRECOAT FILTER UTILIZES TUBE ELEMENTS AND THE EFFECTIVE FILTRATION AREA REPRESENTS THE UNCOATED AREA.





FILTER DATA

SYSTEM FLOW RATE =	147-412 GPM
FILTER AREA =	196 SQ.FT
FILTRATION RATE =	.75-2.1 GPM/SF
NUMBER OF TUBES =	500
UNIT WEIGHT - DRY :	825 LBS
UNIT CAPACITY :	181 GALS
OPERATING WEIGHT :	2340 LBS
CONCRETE BEARING PRESSURE =	5.97 PSI

MEDIA REQUIREMENTS

PERLITE : 22 LBS

NOTES

IMPERIAL CONNECTIONS

FLANGES CONFORM TO ANSI B16.5, CLASS 150

SPECIAL NOTES:
HEAD ROTATED 180 DEG
6" X 4" REDUCING BUSHINGS

REV	DESCRIPTION	DATE	DWN	CKD	APPD	ECN
-	-	-	-	-		

COMPANY CONFIDENTIAL INFORMATION
THIS DOCUMENT AND ALL INFORMATION CONTAINED HEREIN, INCLUDING THE DESIGN CONCEPTS AND THOSE ARISING THEREFROM ARE THE PROPERTY OF EVOQUA AND/OR ITS AFFILIATES AND ARE SUBMITTED IN CONFIDENCE. THEY MAY BE USED ONLY FOR THE EXPRESS PURPOSE FOR WHICH THEY ARE PROVIDED AND MUST NOT BE DISCLOSED, REPRODUCED OR COPIED IN ANY FORM, INCLUDING IN ELECTRONIC FORMAT, LOANED OR USED IN ANY OTHER MANNER WITHOUT THE EXPRESS WRITTEN CONSENT OF EVOQUA. ALL PATENT RIGHTS ARE RESERVED. THIS DOCUMENT AND DERIVATIVE WORKS THEREOF ARE PROTECTED UNDER APPLICABLE COPYRIGHT LAWS. UPON DEMAND OF EVOQUA, THIS DOCUMENT, ALONG WITH ALL COPIES AND EXTRACTS, AND ALL RELATED NOTES AND ANALYSES MUST BE RETURNED TO EVOQUA OR DESTROYED, AS INSTRUCTED BY EVOQUA. ACCEPTANCE OF THE DELIVERY OF THIS DOCUMENT CONSTITUTES AGREEMENT TO THESE TERMS.

DWN BY:		DATE
CKD BY:		DATE
APPD BY:		DATE
MGD BY:		
REF:		
SCALE:	NTS	

TITLE: PROJECT NAME
POOL NAME

CLIENT: CLIENT NAME

EVOQUA WATER TECHNOLOGIES
EVOQUA WATER TECHNOLOGIES
WARWICK RI USA
+1(0)1-800-832-8002

PROJECT	PART NUMBER	DMS REFERENCE	SHEET	REV
JOB#	SP-29-36-500	####	1 OF 1	-

BAR = 1" AT PLOT SCALE Doc Group: Doc Type:
STD:22x34_D v1.8