




STD-22x34_D v4.4




BAR = 1" AT PLOT SCALE



NOTES:

- FILTER TANK IS TO BE CONSTRUCTED OF HIGH QUALITY A36 CARBON STEEL, UPPER HEAD THICKNESS = 1 1/2" (38.1mm), LOWER HEAD THICKNESS = 5/16" (10.31mm) & SHELL THICKNESS = 1/4" (6.35mm).
- INTERIOR OF TANK IS LINED WITH FLEXSOL 3000. EXTERIOR IS COATED WITH 5-8 MILS OF HIGH SOLIDS ENAMEL. NO WELDING OR EXTREME HEAT IS TO BE APPLIED TO TANK AFTER LINING OR COATING PROCESS IS DONE.
- ELECTRICAL REQUIREMENTS: 120VAC-10-60Hz, 15 AMP CIRCUIT PROTECTION.
- LOCATE ALL ELECTRICAL ITEMS IN A NON-HAZARDOUS LOCATION.
- ELECTRICAL CONNECTIONS ARE THE RESPONSIBILITY OF THE CUSTOMER.
- MEDIA QUANTITIES ARE INDICATED FOR INFORMATIONAL PURPOSES ONLY.
- ALL PNEUMATIC TUBING SUPPLIED BY POOL CONTRACTOR.
- DRAIN VALVE MUST BE A BUTTERFLY VALVE AND INSTALLED DIRECTLY ON THE BOTTOM TANK HEAD..
- DESIGN PRESSURE IS 50 PSI (344.73 kpa). HYDROSTATICALLY TESTED TO 75 PSI (517.11 kpa).

MARK	QTY.	DESCRIPTION	PART #	REMARKS
1	1	SPLIT DEFENDER FILTER SP-49-48-1548	SP-49-48-1548-S1	
2	1	AUTOMATIC FILTER PROGRAMMER MODEL : RMF 12	MICRORMF	SHIP LOOSE
3	1	VACUUM TRANSFER UNIT	VACUUM	SHIP LOOSE
4	1	FILTER /REGULATOR 1/2" NPT CONNECTION	1000-5527	SHIP LOOSE
5	1	GAUGE PANEL KIT	1000-8245	SHIP LOOSE
6	1	VACUUM TRANSFER PLUMBING KIT	1000-5821	NOT SHOWN SHIP LOOSE
7	1	DEFENDER DRAIN VALVE 4" LEVER	1000-7321	SHIP LOOSE



FILTER DATA	
SYSTEM FLOW RATE = 608-1702 GPM	
FILTER AREA = 811 SQ.FT	
FILTRATION RATE = .75-2.1 GPM/SQ.FT	
NUMBER OF TUBES = 1548	
UNIT WEIGHT - DRY : 3,320 LBS	
UNIT CAPACITY : 615 GALS	
OPERATING WEIGHT : 8,437 LBS	
4 LEGS PER TANK	
CONCRETE BEARING PRESSURE = 42 PSI	
MEDIA REQUIREMENTS	
PERLITE : 96 LBS (11.52 CU.FT.)	

NOTES	
IMPERIAL CONNECTIONS	
FLANGES CONFORM TO ANSI B16.5, CLASS 150	
TANKS ARE SHIPPED WITH LEGS IN THE COLLAPSED POSITION TO REDUCE OVERALL HEIGHT AND ASSIST TANK ACCESS. TANK MUST BE INSTALLED WITH LEGS IN EXTENDED POSITION.	
INFLUENT, EFFLUENT, & DRAIN CONNECTIONS ARE DRILLED FOR METRIC AND IMPERIAL FLANGE BOLT PATTERNS	
CUSTOMER IS TO CONFIRM THERE ARE NO INTERFERENCES IN THE FILTER ROOM THAT WOULD INHIBIT THE ROTATIONAL SWING OF THE HEAD REQUIRED FOR GENERAL FILTER MAINTENANCE	
SPECIAL NOTES: SPLIT TANK	

REV	DESCRIPTION	DATE	DWN	CKD	APPD	ECN
-	-	-	-	-	-	-
-	-	-	-	-	-	-
-	-	-	-	-	-	-

COMPANY CONFIDENTIAL INFORMATION THIS DOCUMENT AND ALL INFORMATION CONTAINED HEREIN, INCLUDING THE DESIGN CONCEPTS AND THOSE ARISING THEREFROM ARE THE PROPERTY OF EVOQUA AND/OR ITS AFFILIATES AND ARE SUBMITTED IN CONFIDENCE. THEY MAY BE USED ONLY FOR THE EXPRESS PURPOSE FOR WHICH THEY ARE PROVIDED AND MUST NOT BE DISCLOSED, REPRODUCED OR COPIED IN ANY FORM, INCLUDING IN ELECTRONIC FORMAT. LOANED OR USED IN ANY OTHER MANNER WITHOUT THE EXPRESS WRITTEN CONSENT OF EVOQUA. ALL PATENT RIGHTS ARE RESERVED. THIS DOCUMENT AND DERIVATIVE WORKS THEREOF ARE PROTECTED UNDER APPLICABLE COPYRIGHT LAWS. UPON DEMAND OF EVOQUA, THIS DOCUMENT, ALONG WITH ALL COPIES AND EXTRACTS, AND ALL RELATED NOTES AND ANALYSES MUST BE RETURNED TO EVOQUA OR DESTROYED, AS INSTRUCTED BY EVOQUA. ACCEPTANCE OF THE DELIVERY OF THIS DOCUMENT CONSTITUTES AGREEMENT TO THESE TERMS.		DWN BY:	DATE	TITLE	
		P.THIRU	4/30/2026		
		CKD BY:	DATE		
		D.COTTR	4/30/2026		
		APPD BY:	DATE	CLIENT	
		D.COTTR	4/30/2026		
		MGD BY:	SCALE		
		NA	NTS		
		PART NUMBER	FILE/DRAWING NUMBER	PROJECT NAME	
		SP-49-48-1548-S1	Z-GA01		
		CODE	V114165233		
		FILE/DRAWING NUMBER	1		
		1	OF	CLIENT NAME	
		1	OF		
		1	OF		
		1	OF		
		1	OF	EVOQUA WATER TECHNOLOGIES WARWICK RI USA +1 800-832-8002	
		1	OF		
		1	OF		
		1	OF		