

CITY OF CAPE TOWN
DEVELOPMENT MANAGEMENT

Recommended for Approval

Building Control Officer / Delegetee

This application has been approved in terms of Section 7 (1) (a) of Act 103 of 1977, subject to the conditions in the attached letter of approval.

15 Jan 2020

Date

Planning & Building
Development Management

Approval Number: 97567068

Application Number: 000070470554

SITE & GROUND STOREY PLAN
SCALE 1:100

VILLAGE GREEN CLOSE

General Notes

- All levels and dimensions to be checked and verified with the author before any works commences.
- All works in compliance to NBR.
- Pre stressed concrete lintels all over openings of less than 3m.
- Brick force every 3rd course.
- Brick force in every row above lintels.
- Light area to be min 10% and ventilation area to be min 5% of all habitable rooms.
- All glazing to comply with part N of NBR.
- Dpc on every window frame.
- Dpc to be min 375 mic SABS approved.
- DPM to be min 250 mic SABS approved.
- All timber built into brickwork to be coated with pink primer.
- Flashing to be applied to all roof joints with a min overlap of 300mm.
- Parapet walls to be min 300mm above roof coverings and max 500mm high or to comply with rule kk303 ii of NBR.

NBR

- Parapet walls to be plastered sloped on top to the inside and covered with an approved waterproof sealer.
- All glass bigger than 1m2 and closer than 500mm to EFL to be safety glass.
- 250 micron dpc under walls.
- All walls plastered inside.
- All flashing to be applied to manufacturer's spec.
- All stair treads to be 250mm and risers 200mm maximum.
- 135mm fibre glass insulation in roofs.
- All walls to be plastered and painted to manufacturers specs.
- No foundations to stretch beyond any boundaries.
- All retaining walls to comply with NBR.
- All foundation walls to be designed by engineer.
- All walls, roofs and floors to be insulated according to SANS 10400.
- All chimneys to be 1m above the lowest point of the roof.

Copy right is vested in this plan. No unauthorised copies of or part of this plan is to be made without the written consent of the author of this plan.

SOUTH EAST ELEVATION
SCALE 1:100

SECTION A-A
SCALE 1:100

Roof notes
Corrugated roof sheets on pre fabricated trusses at 760mm centres to be tied down to wall with hoop iron ties into brickwork.
Pitch to be 11degrees.

Floor notes
25mm screed on 75mm concrete bed on 100mm insulation on dpc on well compacted filling compacted in layers of 150mm.

Drainage Notes

- All drainage to be according to NBR.
- All levels and dimensions to be checked and verified by author before any commencement of work.
- All drainage pipes under buildings and closer to 450mm to the NGL, to be encased in 200x200 concrete.
- RE to all ends.
- IE to all bends.
- Soil pipes to be min 110mm.
- Waste pipes to be min 50mm.
- Min fall of all pipes to be 1:40.
- All material used to be SABS approved.
- Fit gutters and down pipes where necessary.
- Disposal of stormwater to comply to the requirements of part R of NBS and BS(Act 1030 of 1977)
- All internal sewre pipe connections to be converted to closed systems

ENERGY EFFICIENCY REQUIREMENTS AND SANS 10400 XA

Fenestration areas Ground Floor

Windows	12.69m2
Floor	84.87m2
Fenestration	14.95%

Hot Water Supply 300Litre
Existing hot water to be used

Lighting
Low energy lighting to be used

Roof Insulation
135mm minimum cellulose fibre loose fill

SOUTH WEST ELEVATION
SCALE 1:100

NORTH EAST BOUNDARY ELEVATION
SCALE 1:100

STORMWATER DISPOSAL:
Method of stormwater disposal to be established on site according to actual site conditions.

The site to be shaped to avoid ponding where possible.

The roof stormwater run-offs is to be taken to the road or connected to a communal stormwater system.

Notes on SANS 10400PART XA:
Perimeter insulation is required and is to be a minimum insulation with R-value of 1.0.
Brickwall to have an insulation with R-value of 1.0 and a CR-value of 130.
115mm flexible fibre glass blanket to be placed in the roof of the ceiling.
All windows to aluminium frames.
External doors to have seals for draught protection.
Hot water pipes to be insulated with insulation that has a R-value of 1.0.
Hot water tank and geyser to be insulated with insulation blanket with a R-value of 2.0.

Redacted for portfolio purposes. Confidential information removed.

Sketch Type : GROUND STOREY PLAN, SITE PLAN, FIRST STOREY PLAN, SECTIONS, ELEVATIONS AND NOTES

Page	Scale	Date	Areas		DR6 No.
1 of 1	AS SHOWN	OCT 2019	House	125.63m2	
			Additions	13.2m2	
			Total	138.83m2	
			ERF size	329.00m2	
			Coverage	42.20%	M065