

(Please quote on all correspondence)

OUR REF S2520891

02380 622 622

www.ghgsolutions.co.uk

correspondence@agatha.app.ghgsolutions.co.uk

Mrs H Thomas
Mapletree Cottage
Pebmarsh
Halstead
CO9 2NA

05 September 2026

Dear Mrs Thomas,

Policyholder: Mrs H Thomas

Insurance claim for: Subsidence, 29/09/2025

Mapletree Cottage, Kings Mead, Pebmarsh, Halstead, CO9 2NA, United Kingdom

We write in regard to your Subsidence claim.

As you are aware, crack monitoring is being utilised at your property, and we are now in receipt of the August 2026 readings, a copy of which is attached for your perusal. The readings have shown that the station located to the right-hand elevation has opened by 3.14mm and the remaining station at the front porch has closed by 0.1mm.

It is noted that the readings were taken shortly after vegetation removal, and we will therefore require further readings to ascertain when stability is evidenced. The next set of readings will be collected in October 2026.

Once stability is evidenced, we will progress with superstructure repairs.

If you have any questions in the meantime, please do not hesitate to contact us.

Yours sincerely

Kim Salter Cert CILA

02380622622

For: GHG Solutions Limited

Email: correspondence@agatha.app.ghgsolutions.co.uk

Enc Crack Monitoring Report