

Date: 03/07/2026

Insurance Company: Ageas

Insurer Claim Number: 6866220H

Insurer Policy Number: 139425

Policyholder Name & Risk Address:

H Thomas And R Thomas Mapletree Cottage, Kings Mead, Pebmarsh, HALSTEAD, CO9 2NA

Date of Loss: 06/03/2026

Initial Visit Date: 03/07/2026

Further Visit/s Date: 28/07/2026

Description of Risk address

Detached House

Description of Drainage System / Water Service

Clay – 100mm - Foul

Shared

No

Circumstances

Ongoing subs claim, Defects noticed to the drainage system.

Engineers Findings

Attended property to carry out a CCTV survey of the drains as there is a subsidence investigation ongoing, MH1 U/S SVP1 there is a displacements which will require a patch repair MH1 D/S to MH2 we found multiple root intrusions which will require root cutting and 3 patch repairs to this one line to clear issues, the roots are congesting around 50% of the diameter MH3 U/S to Gully2 there is a medium displaced joint which will require a structural liner repair Also MH3 D/S to MH4 there were roots and a displaced joint which will require 2 structural lining repairs

Cause of Damage

Root intrusion /Ground Movement

Detail of Damage:

Root ingress /displaced joints

Further Action

MH1 U/S SVP1 - Require a patch repair

MH1 D/S to MH2 will require root cutting and 3 patch repairs to this one line to clear issues

MH3 U/S to Gully2 there is a medium displaced joint which will require a structural liner repair

MH3 D/S to MH4 will require 2 structural lining repairs

Recovery

N/A

Conclusion:

We can report that the cause of damage has been reported as root ingress/ground movement works have been authorised under the terms and conditions of the policy. All repairs have now been completed and all excavated areas back filled and reinstated. We will close our file.

Site Plan







