

Cloud Based Distributed Data Acquisition

Exemplified on Power Quality Monitoring

DIPLOMARBEIT

zur Erlangung des akademischen Grades

Diplom-Ingenieur

im Rahmen des Studiums

Software Engineering & Internet Computing

eingereicht von

Martin Gebhard Jenny

Matrikelnummer 0728228

an der Fakultät für Informatik

der Technischen Universität Wien

Betreuung: Pretitle Forename Surname, Posttitle

Mitwirkung: Pretitle Forename Surname, Posttitle

Pretitle Forename Surname, Posttitle

Pretitle Forename Surname, Posttitle

Wien, 1. Jänner 2001

Martin Gebhard Jenny

Forename Surname

Cloud Based Distributed Data Acquisition

Exemplified on Power Quality Monitoring

DIPLOMA THESIS

submitted in partial fulfillment of the requirements for the degree of

Diplom-Ingenieur

in

Software Engineering & Internet Computing

by

Martin Gebhard Jenny

Registration Number 0728228

to the Faculty of Informatics

at the TU Wien

Advisor: Pretitle Forename Surname, Posttitle

Assistance: Pretitle Forename Surname, Posttitle

Pretitle Forename Surname, Posttitle

Pretitle Forename Surname, Posttitle

Vienna, 1st January, 2001

Martin Gebhard Jenny

Forename Surname

Erklärung zur Verfassung der Arbeit

Martin Gebhard Jenny
Silvrettastr. 38, 6780 Schruns

Hiermit erkläre ich, dass ich diese Arbeit selbständig verfasst habe, dass ich die verwendeten Quellen und Hilfsmittel vollständig angegeben habe und dass ich die Stellen der Arbeit – einschließlich Tabellen, Karten und Abbildungen –, die anderen Werken oder dem Internet im Wortlaut oder dem Sinn nach entnommen sind, auf jeden Fall unter Angabe der Quelle als Entlehnung kenntlich gemacht habe.

Wien, 1. Jänner 2001

Martin Gebhard Jenny

Danksagung

TODO: Ihr Text hier.

Acknowledgements

TODO: Enter your text here.

Kurzfassung

TODO: Ihr Text hier.

Abstract

TODO: Enter your text here.

Contents

Kurzfassung	xi
Abstract	xiii
Contents	xv
1 Introduction	1
2 Goals	3
3 Theoretical Foundation	5
3.1 Power Quality Monitoring	5
3.2 Cloud Computing	10
3.3 Internet of Things	13
3.4 IoT	13
4 System Design	15
4.1 Requirements	15
4.2 System Overview	15
4.3 Hardware Architecture	15
4.4 Software Architecture	15
4.5 Network Architecture	17
4.6 Security Aspects / Threat-Modeling	17
5 Simulation	19
5.1 Tools	19
5.2 Important Points to consider	19
5.3 Evaluation	19
5.4 Impact on System Design	19
6 Implementation	21
7 Evaluation	23
List of Figures	25

List of Tables	25
List of Algorithms	27
Bibliography	29

CHAPTER 1



Introduction

TODO: Enter your text here.

CHAPTER 2

Goals

Theoretical Foundation

3.1 Power Quality Monitoring

Electric power is often seen as self-evident. It can be consumed at any time and any point all over the country. But, this standard of comfort implies a lot of effort for the power suppliers. The wide variety of power producers makes it hard for the suppliers to deliver a power grid with stable frequency and voltage. On the one hand, nuclear power plants produce a stable high amount of baseline power, on the other hand highly dynamic techniques like solar or wind energy can make the grid unstable. As a result, the grid has to be balanced. Surplus power has to be compensated, for example by pumping water into big artificial lakes in the mountains. Especially the increasing use of electric equipment in private and industrial environments punctuates the need for a stable power grid.

To fulfill the task of keeping the grid stable, precise measurement is needed at defined points in the power grid. Therefore, the term power quality monitoring describes the the monitoring of important parameters of the power grid, such as frequency or different aspects of the voltage. Furthermore, analysis are made to react to imbalances and to predict further events like the outage of a component of the power grid.

The European Standard EN 50160 defines the parameters of the power supply network that have to be monitored to ensure the given limits by the standard. The standard describes the characteristics under normal operation conditions at a supply terminal from a customer to the public network. The following sections describes some example characteristics of the corresponding Austrian standard ÖVE/ÖNORM EN 50160[1]. Furthermore, the International Standard IEC 61000-4-30 defines testing and measurement techniques for power quality monitoring. [2]

The goal of the proposed thesis is to develop a measurement system that measures relevant characteristics of a power system for power network supplier. According to the

underlying standard (EN 50160), it is sufficient to capture the voltage on a power line to calculate the relevant properties for a power quality analysis. The scenario used in the thesis consist of synchronized measurement devices, distributed over a wider geographical area, that are connected to a cloud system. The cloud system provides functionality for managing the devices and visualization of the measured data. Furthermore, interfaces can be consumed to use the data with external systems. With this design, the power quality of a power supplier network can be captured.

3.1.1 Parameters

Effective Value

The effective value of the power supply voltage has to be $230 \text{ V} \pm 10\%$ in 95% of every 10 ten minute interval and $230 \text{ V} + 10\%/- 15\%$ in every ten minute interval. The following formula is used to calculate the effective value of the captured signal:

$$U_{eff} \approx \sqrt{\frac{1}{n} \sum_{i=0}^n x_i^2} = \sqrt{\frac{1}{n} (x_1^2 + x_2^2 + x_3^2 + \dots + x_n^2)}$$

In order to calculate the following characteristics, a Fourier transformation (see 3.1.3 for further information) has to be applied to the captured data.

Frequency

The frequency of the power supply voltage has to be $50 \text{ Hz} \pm 1\%$ at 99.5% of the year and $50 \text{ Hz} + 1\%/- 6\%$ at 100% of the year. After the Fourier transformation, the frequency with the highest amplitude is assumed to be the fundamental frequency f_0 .

Voltage harmonics

According to the standard, all voltage harmonics up to the 25th order has to be monitored. Each value has to be calculated over an interval of ten minutes and has to be tested against the values listed in the standard as described in appendix ???. After the fundamental frequency f_0 is extracted out of the results of the Fourier transformation, the voltage harmonics can be calculated. The frequencies of the corresponding harmonics can be calculated by $f_n = n \cdot f_0$. The voltage harmonics of the desired order can then be calculated by the following formula:

$$V_n = \frac{A(f_n)}{A(f_0)} \cdot 100\%$$

where $A(f_n)$ is the amplitude of the signal at the frequency f_n .

Total harmonic distortion

In addition to the voltage harmonics, the total harmonic distortion (THD) has to be $\leq 8\%$. For this, the voltage harmonics up to the 40th order are aggregated by using the following formula:

$$THD = \frac{\sqrt{\sum_{h=2}^{40} V_h^2}}{V_1} \cdot 100\% = \frac{\sqrt{V_2^2 + V_3^2 + V_4^2 + \dots + V_{40}^2}}{V_1} \cdot 100\%$$

3.1.2 Measuring Electric Characteristics

TODO: better title

To calculate the selected power quality characteristics, the voltage of the power line has to be monitored. In order to accomplish this task, the analog signal has to be digitized for further computational processing. The signal has to be sampled and each sample has to be quantized to a finite number of bits representing the sample in a digital way. The accuracy of the quantization process strongly depends on the number of bits that such an analog/digital converter (ADC) offers. Assume an ADC represents a sample by B bits, the sample is transformed to a value in the range of 2^B bits, furthermore, the full-scale range R has to be taken into account. As a result of this, the full-scale range R is divided in 2^B steps and the resulting quantization with or quantization resolution can be represented using the following formula[3]:

$$Q = \frac{R}{2^B}$$

In the proposed scenario, a ADC with a $R = \pm 1200 \text{ V} = 2400 \text{ V}$ and $B = 24$ bits is used. This results in the following quantization resolution:

$$Q = \frac{2400 \text{ V}}{2^{24} \text{ bits}} = 0.000143 \text{ V} \approx 143 \mu\text{V}$$

Beside having a efficient quantization resolution, choosing the right sample rate is crucial. In order to reconstruct the measured signal, the time between two sample has to be chosen in a manner that on the one hand, unnecessary often taken samples of the same signal level are generated (oversampling) and on the other hand, not too less samples are taken such that the original signal cannot be reconstructed (undersampling)[3]. To avoid undersampling, the Nyquist sampling theorem has to be applied: Taken a real signal, that is bandlimited to B Hz (only signals with a frequency below B Hz are sampled), can be reconstructed without errors with the frequency R , described by the following formula[4]:

$$R > 2 \cdot B$$

In the proposed scenario, we examine total harmonic distortion up to the 40th order or

harmonics. According to the standard, the maximal allowed frequency is $50 \text{ Hz} + 1\% = 50.5 \text{ Hz}$. Therefore, the 40^{th} harmonic has a frequency of at most 2020 Hz . The signal is bandlimited by a lowpass filter to $B = 5000 \text{ Hz}$. According to the Nyquist sampling theorem, the sample frequency has to be set to at least $R > 2 \cdot B = 10000 \text{ Hz}$. Hence, the sample frequency of the measurement device used to evaluate the scenario is set to 20000 Hz .

3.1.3 Transformation from Time- to Frequency Domain

TODO: better title

Since a great number of important characteristics of the power quality depends on measuring the frequency (and it's components) on a power line, the transformation from a signal recorded in the time domain to it's frequency parts shall be discussed. The most important method used for transformation is the Fourier transform. By using the Fourier analysis, a signal can be represented by its sinusoidal waveforms. In other words, the output of the Fourier analysis shows the amplitude and phase (cosine and sine components) at every frequency of the original signal. The conversation of a signal from the time- to the frequency-domain can be represented by the Discrete Fourier Transform (DFT). The input for the DFT is a signal of N points and can be calculated using the following formula[5]:

$$X(k) = \frac{1}{N} \sum_{n=0}^{N-1} x(n) e^{-j \frac{2\pi}{N} nk}$$

Implementing the DFT directly results in an algorithm with a complexity of $\mathcal{O}(N^2)$. Therefore, efficient implementations (Fast Fourier Transform - FFT) are available that reduce the complexity to $\mathcal{O}(N \cdot \log(N))$. The most common FFT algorithm is the Cooley-Tukey algorithm that uses the divide and conquer approach which can be found in listing 3.1[6]. The results of this transformation are 'Bins' representing a sample of the spectrum with the frequency

$$f_i = \frac{R}{N} \cdot i$$

where i is the current Bin-index. Therefore, the output of the FFT has a limited resolution of the frequency. In the proposed scenario, the resolution (or the difference between two Bins) should be at least 0.5 Hz which can be represented as $\Delta f = f_n - f_{n-1} = 0.5 \text{ Hz}$. Since $n \geq 0$ and $n < N$, we can choose an arbitrary n in this range.

$$\begin{aligned} n &= 2, R = 20000 \text{ Hz} \\ \Delta f &= f_n - f_{n-1} = f_2 - f_1 \\ \Delta f &= \frac{R}{N} \cdot 2 - \frac{R}{N} \cdot 1 = \frac{2 \cdot R - 1 \cdot R}{N} = \frac{R}{N} \end{aligned}$$

$$\Rightarrow N = \frac{R}{\Delta f} = \frac{20000Hz}{0.5Hz} = 40000$$

When looking at the recursive algorithm, it can be seen that the algorithm works efficiently when N is a power of two. Hence we take the next greater power of two for N . $N = 2^{16} = 65536$, which results in a resolution $\Delta f = 0.305$ Hz.

For the sake of completeness, 'Window functions' have to be taken into account. The FFT works under the precondition that the signal is periodic in the examined window (N points). Due to measurement uncertainty and that in practice, the signal is not a perfect sine wave, errors occur in the output. To minimize the error, window function can be applied to the measurement data before FFT, which transforms the input signal to a periodic signal. Different window function (Hanning, Hamming, Blackman, etc.) exists to examine different aspects of the spectrum. Practice has shown that the Hanning-Window is useful in most situations and is also applied in the proposed thesis. Every sample $x[n]$ in the time domain is multiplied with $w[n]$, which has the following formula[7]:

$$w[n] = 0.5 - 0.5 \cdot \cos\left(\frac{2\pi n}{N}\right)$$

Listing 3.1: Recursive Cooley-Tukey FFT algorithm

```
private void CalculateFFT(ref Complex[] signal)
{
    int n = signal.Length;

    if (n <= 1)
    {
        return;
    }

    //Divide
    Complex[] even = new Complex[n / 2];
    Complex[] odd = new Complex[n / 2];

    for (int i = 0; i < n / 2; i++)
    {
        even[i] = signal[2 * i];
        odd[i] = signal[2 * i + 1];
    }

    //Conquer
    CalculateFFT(ref even);
    CalculateFFT(ref odd);

    //Combine
    for (int i = 0; i < n / 2; i++)
    {
        double kth = -2 * i * Math.PI / n;
```

```
Complex wk = new Complex(Math.Cos(kth), Math.Sin(kth));

signal[i] = even[i] + wk * odd[i];
signal[i + n / 2] = even[i] - wk * odd[i];
}
}
```

TODO: better colors TODO: small introduction

3.2 Cloud Computing

"I don't need a hard disk in my computer if I can get to the server faster... carrying around these non-connected computers is byzantine by comparison."

— Steve Jobs, former Apple CEO

3.2.1 Cloud Characteristics

The essential characteristics of cloud computing are as follows[8][9]:

On-demand self-service

Allows users of the cloud to consume capabilities from it. Common capabilities are network storage, server time or applications. The big difference compared to other computing models is, that the capabilities can be consumed as needed without complex interaction with the cloud provider.

Broad network access

All of the capabilities can be accessed over the network by standard mechanisms. Furthermore, thin and thick client platforms are supported (from mobile devices up to workstations).

Resource pooling

The cloud provider's resources are pooled together to serve multiple consumers. End users of the cloud mostly need not to know the location of the data center hosting the cloud environment (often users can choose the country or a certain datacenter). The different physical and virtual resources are assigned and reassigned dynamically on demand.

Rapid elasticity

For rapid elasticity and scalability, the provisioned capability can be automatically scaled up and down. For the end users, capabilities are often presented as unlimited.

Measured service

For billing purposes and transparency for both the cloud provider and the end user, measuring capabilities are applied. Furthermore, automatic control and optimization of the resources are performed based on these measures.

3.2.2 Service Models

By definition, the cloud system can be divided into the following three service models[9]:

Software as a Service (SaaS)

Software is provided to the users within the cloud infrastructure. To use the software, the services provided by the cloud can be accessed by either a web interface or is integrated into software installed locally. The advantage of this service model is, that the users consuming the services of the cloud rely on the underlying hardware (physical servers or network interfaces) and software (operating systems or databases)[9].

Examples: Google Mail, Google Docs[10].

Platform as a Service (PaaS)

Software created by users can be deployed to the cloud. For this, the cloud provides libraries, services and tools to support the users by developing a software with a programming language supported by the cloud. Like before, the underlying hardware and software is maintained by the cloud operator[9].

Examples: Google App Engine, Windows Azure[10].

Infrastructure as a Service (IaaS)

The users can consume computational power from the cloud. This includes the use of servers and operating systems, storage solutions, networking resources or additional capabilities like processing power. Again, the underlying hardware and software is maintained by the cloud operator[9].

Examples: Amazon Elastic Compute Cloud (EC2), Amazon Simple Storage Service (S3)[10].

Figure 3.1 shows the three main service models and the responsible entities for the involved services.

TODO: <https://blogs.technet.microsoft.com/yungchou/2010/11/15/cloud-computing-p>

Separation of Responsibilities




Figure 3.1: Service models[10]

Furthermore, the following subset of service models can be derived from the Everything as a Service (XaaS) aspect:

Data Storage as a Service (DaaS)

DaaS can be seen as enhancement of IaaS. The main idea behind this model is to provide storage solutions to users. Often supported services are databases (RDBMS or other types) and file storage.

Example: Amazon Simple Storage Service (S3)[11].

Human as a Service (HuaaS)

Services, that rely on information generated by a crowd of people. Human intelligence is used to fulfill tasks that are provided as a service to the users. Persons in the crowd use their tools, skills or knowledge to solve a task or a small subset of a task. The cloud systems aggregates the single results and provide as a service to the users.

Example: Amazon Mechanical Turk[12].

Other models

Since there is no strict separation between the stated service models, there exist various combination and modifications of them. The following listing shows some additional classification [8].

- Database-as-a-Service

- Security-as-a-Service
- Communication-as-a-Service
- Management/Governance-as-a-Service
- Integration-as-a-Service
- Testing-as-a-Service
- Business Process-as-a-Service

3.3 Internet of Things

3.4 IoT

The Internet of Things, a term initially coined at the AutoID labs at the Massachusetts Institute of Technology (MIT), describes the vision that virtually all objects become smart and connected [2, 18]. **TODO: further intro**

3.4.1 Value Layers

TODO: picture

Layer 1: Physical thing

On this layer, the physical object that can directly respond to a customer is described. The thing, e.g. a lightbulb, is bound to a physical location.

Layer 2: Sensor/Actuator

In layer 2, the physical thing gets intelligence by adding a processing unit (e.g. a microcontroller) to it. Sensors measure parameters of the environment (e.g. if a person is in the room) and actuators provide services to interact with the thing (e.g. switch the lightbulb on or off).

Layer 3: Connectivity

Layer 4: Analytics

Layer 5: Digital service

System Design

4.1 Requirements

4.2 System Overview

4.3 Hardware Architecture

4.4 Software Architecture

4.4.1 Synchronization

Synchronizing a distributed measurement system is essential. Although an not synchronized system delivers correct data that holds true for the point of measure, synchronizing theses systems allow to extract further knowledge out of the captured data. In the use case, selected for this thesis, power quality monitoring provides good arguments for synchronization. If somewhere in the power network an error occurs, it could be possible that this error is propagated throughout the network. Since the electric network and the infrastructure around it consists of resistive, inductive and capacitive load, a cascading of a fault is possible. With an adequate synchronization, it is possible to track the error propagation with a distributed measurement systems.

The testing equipment used in the proposed scenario support three different synchronization mechanisms. The radio based DCF77 time signal, the satellite based GPS signal and the Ethernet based SNTP protocol. The following section explains these three mechanisms in detail and evaluates which type suits most for this use case.

For the sake of completeness, two further synchronization modes exist. Distributed clock over EtherCAT and Q.sync. The first mode is part of the EtherCAT protocol that is implemented in the used modules, the second mode is a proprietary bus that connects

multiple controllers. Since the different power quality measurement systems are spread across a wider geographical area, this two modes can't be used.

DCF77

DCF77 is a radio based time distribution services. It uses a long wave radio transmitter with a carrier frequency of 77.5 kHz. Due to the fact that the transmitter is located in Germany, it covers a maximum range (by using the proper detector) of approximately 2400 km, which is in fact whole Europe. Since DCF77 is driven by atomic clocks, the received radio signal is less accurate than the them[13]. Every minute, the time information (and additional information like civil warnings[14] and weather data[13]) is transmitted amplitude modulated (AM) and phase modulated (PM) in Binary Coded Decimal (BCD). In the current message the information about the next second is transmitted, furthermore, the start of a minute can be detected. It is possible to detect leap seconds and the switch to daylight-saving time [14]. Considering accuracy of the DCF77, the decoding mechanism is crucial. For the use in watches only the amplitude modulated signal is decoded which results in accuracy of +5ms up to +150ms. By using better antennas, this values can be enhanced to +5ms up to +15ms. To gain more accuracy, the phase modulated signal has to be decoded as well. This method results in an exactness of $\pm 2\text{ms}$ [15].

Since the signal of a DCF77 receiver cannot be connected directly to the measurement devices, the signal has to be converter inside the receiver to a suitable format. As an example of such a format, the "IRIG B003" standard is described in more details here. The Inter Range Instrumentation Group (IRIG) specifies various standards regarding transmitting time information over via a serial time code format. The name of the described standard refers to a format with 100 pulses per second (B), Pulse width code (0), no carrier (0) and Binary Coded Decimal - BCD, Straight Binary Second of Day - SBS (3). The date information is transmitted as a sequence of seconds, minutes, hours, days, years, control functions and time of day [16]. Regarding the used testing equipment, DCF77 receivers can provide the IRIG B003 signal either straight as Transistor-Transistor Logic (TTL) signal into the measurement device or over the RS-485 bus.

GPS

The Navstar Global Positioning System (GPS) is a satellite based time distribution service. In normal operation mode, it consists of 24 geometrical space slots with at least one operational satellite in it. Each satellite sends it's time information, generated by an atomic clock, and it's position to the receiver stations down on earth with a frequency of 1.57542 GHz. To control and observer the status of the GPS, the Operational Control System (OCS) is used to communicate with the satellites via ground antennas. The OCS is responsible for various tasks including telemetry, monitoring of different parameters and uploading of navigation data. Considering accuracy, GPS offers two services. On the one hand, the Standard Positioning Service (SPS) that is available to the civil public with less accuracy and on the other hand, the Precise Positioning Service (PPS) available

to the military of the USA and it allies with high accuracy.[17]. Due to this fact, the proposed system and the used testing equipment can only make use of the SPS.

After receiving the time information from one or more satellites, the data can be passed to the testing equipment. For this, the received information is transformed to the National Marine Electronics Association (NMEA) 0183 format. Since NMEA was designed as interconnection format of different devices used in the marine, the format consists of various sentences representing features of the connected devices. To use NMEA as protocol for transmitting time- and position data, the two sentences \$GPRMC (Recommended Minimum Navigation Information) and \$GPGGA (Global Positioning System Fix Data. Time, Position and fix related data for a GPS receiver) can be used. The data is transferred as ASCII text and can be decoded directly by knowing the format of the corresponding sentence. NMEA uses, like IRIG, a serial bus for communication[18].

Beside NMEA, some GPS receivers are also able to provide information via the previously described IRIG B003 format.

SNTP

The Simple Network Time Protocol (SNTP), as a subset of the Network Time Protocol (NTP), provides time information in a network to clients. If a client wants to synchronize its internal clock with a clock placed in the network (SNTP server), it has to send a message to this server. In the response, three timestamps are transmitted. The client timestamp when the message was sent, server time when the message was sent and server time when the message was received. With the information in this message and the timestamp when this message was received by the client, the exact time can be applied to the client[19]. To synchronize a client's clock, the offset and delay of the client relative to the server is computed. By the used algorithm (especially because of the 64 bit integer arithmetic) a client has to be at least 34 years in the past and at most 34 years in future in order to get synchronized by the SNTP server[20].

Conclusion

TODO: add some content here

4.5 Network Architecture

4.6 Security Aspects / Threat-Modeling

TODO: check spelling

CHAPTER 5

Simulation

5.1 Tools


5.2 Important Points to consider

TODO: bad spelling

5.3 Evaluation

5.4 Impact on System Design

CHAPTER 6



Implementation

CHAPTER 7



Evaluation

List of Figures

3.1	Service models[10]	12
-----	--------------------	----

List of Tables

List of Algorithms

Bibliography

- [1] ÖVE/ÖNORM. EN 50160:2010 Merkmale der Spannung in öffentlichen Elektrizitätsversorgungsnetzen, 3 2011.
- [2] ÖVE/ÖNORM. IEC 61000-4-30:2009 Elektromagnetische Verträglichkeit (EMV) Teil 4-30: Prüf- und Messverfahren - Verfahren zur Messung der Spannungsqualität, 11 2009.
- [3] Sophocles Orfanidis. *Introduction to Signal Processing*. Prentice Hall, 1995.
- [4] A.M. Wyglinski, A.M.W. Di Pu, and D. Pu. *Digital Communication Systems Engineering with Software-Defined Radio*. Artech House Publishers, 2013.
- [5] D. Sundararajan. *The Discrete Fourier Transform: Theory, Algorithms and Applications*. World Scientific Publishing Company, Incorporated, 2001.
- [6] MobileReference. *Signal Processing Quick Study Guide for Smartphones and Mobile Devices*. Mobi Study Guides. MobileReference, 2007.
- [7] M. Meyer. *Signalverarbeitung: Analoge und digitale Signale, Systeme und Filter*. Springer Science+Business Media, 2006.
- [8] Zaigham Mahmood. Cloud Computing: Characteristics and Deployment Approaches. In *Computer and Information Technology (CIT), 2011 IEEE 11th International Conference on*, pages 121–126, Aug 2011.
- [9] Peter Mell and Timothy Grance. The NIST definition of cloud computing. *National Institute of Standards and Technology (NIST), Information Technology Laboratory*, NIST Special Publication 800-145, September 2011. <http://www.csrc.nist.gov>, Online, accessed 24-April-2014.
- [10] Kai Hwang and Deyi Li. Trusted cloud computing with secure resources and data coloring. *IEEE Internet Computing*, 14(5):14–22, September 2010.
- [11] T. Dillon, Chen Wu, and E. Chang. Cloud Computing: Issues and Challenges. In *Advanced Information Networking and Applications (AINA), 2010 24th IEEE International Conference on*, pages 27–33, April 2010.

- [12] A. Lenk, M. Klems, J. Nimis, S. Tai, and T. Sandholm. What's inside the Cloud? An architectural map of the Cloud landscape. In *Software Engineering Challenges of Cloud Computing, 2009. CLOUD '09. ICSE Workshop on*, pages 23–31, May 2009.
- [13] D. Engeler. Performance analysis and receiver architectures of DCF77 radio-controlled clocks. *Ultrasonics, Ferroelectrics and Frequency Control, IEEE Transactions on*, 59(5):869–884, May 2012.
- [14] Dirk Piester, Peter Hetzel, and Andreas Bauch. Zeit- und Normalfrequenzverbreitung mit DCF77. In *PTB-Mitteilungen vol. 114 (Heft 4)*, pages 345–368, 2004.
- [15] B. Rega. Genauigkeitsvergleich DCF77 und GPS. http://www.hopf.com/de/dcf77-gps_de.html. Online; accessed 07-May-2014.
- [16] Secretariat of Range Commanders Council, U.S. Army White Sands Missile Range. IRIG Standard 200-04: IRIG Serial Time Code Formats, 2004.
- [17] Department of Defense, United States of America. Global Positioning System Standard Positioning Service Performance Standard 4th Edition, September 2008.
- [18] National Marine Electronics Association. NMEA 0183, Standard For Interfacing Marine Electronic Devices, Version 3.01, January 2002.
- [19] S. Johannessen. Time synchronization in a local area network. *Control Systems, IEEE*, 24(2):61–69, Apr 2004.
- [20] D. Mills, U. Delaware, J. Martin, J. Burbank, and W. Kasch. RFC 5905: Network Time Protocol Version 4: Protocol and Algorithms Specification - Internet Engineering Task Force (IETF), June 2010.