Intertek Caleb Brett

REPORT OF ANALYSIS

Vessel : SUBMITTED SX
Port / Terminal : AEOLUS GROUP
Client Ref :
Our Ref : 2006-006993-PHIL
Date Sample Taken : 10/2/2006
Sample Designated As : BIO DIESEL
Drawn By : Submitted Samples

Method	Test	Date Submitted	Results	Units
SAMPLE ID	**2006-006993-PHIL-001**			
	SUBMITTED BIO-DIESEL	**10/2/2006**		
D4052	API Gravity		28.5	deg API
D240	Gross Heat of Combustion		17137	BTU / lb
D240	Gross Heat of Combustion		126197	BTU / gal

This report has been reviewed for accuracy, completeness, and comparison against specifications when available.The reported results are only representative of the samples submitted for testing and are subject to confirmation upon completion of the final report. This report shall not be reproduced except in full without written approval of the laboratory.

Approved By:_____

Intertek Caleb Brett

Initial:_____

Intertek Caleb Brett
327 Erickson Ave., Essington PA, 19029
Ph: (610) 521-1725, Fax: (610) 521-1445, Lab Fax: (610) 521-1427, www.intertek-cb.com