

## GPI 1 SUMMARY OF WEM FAILED PARAMETERS

Area	Reason/Remark	Parameters	Source	Result	OHS Standard	Evaluation
Accounting (Ms. Caela's Table) [recording, billing and financial report]	Misaligned	Illumination	General Lighting: 4 LED Misaligned	472 lux	500 lux	Failed
GPI 1 - Admin Supplies [office works]	Misaligned	Illumination	General Lighting: 2 LED Misaligned	162 lux	300 lux	Failed
GPI 1 - Checksheet Preparation Area [office works]	Misaligned	Illumination	General Lighting: 6 LED, misaligned,	167 lux	300 lux	Failed
L2-GPI 1 - SDRB 240, 250, 260 Line [assembly]		Illumination	Local Lighting: 1 LED,	289 lux	300	Failed

### WEM Corrective Action for Failed Parameters

Area: GPI 1 - Accounting  
Failed Parameters: Illumination  
Reason: Misaligned

Reason	Corrective Action	Remarks	Alternative Action
Misaligned	Re-alignment of LED lights to working table	Headaches concern of member if LED lights re-aligned to working table	1. Separate switch for 1 LED lights 2. Replace to higher lumens

Area: GPI 1 - Admin Supplies  
Failed Parameters: Illumination  
Reason: Misaligned  
Corrective Action:



Reason	Corrective Action
Misaligned	1. Re-alignment of LED lights to working table 2. Lower the position of the lights 3. Re-alignment of working table to LED lights 4. Additional lights with separate switch

Area: GPI 1 - Checksheet Preparation Area  
Failed Parameters: Illumination  
Reason: Misaligned



Reason	Corrective Action
Misaligned	1. Re-alignment of LED lights to working table 2. Lower the position of the lights 3. Installation of secondary lights

Area: GPI 1 - L2-GPI 1 - SDRB 240, 250, 260 Line [assembly]  
Failed Parmeters: Illumination  
Reason:



Reason	Corrective Action
Misaligned	1. Replace to LED Lights
	2. Installation of additional LED lights