

Top 12 Findings during a Rental and Resale Inspection

1. **Smoke Alarms**
 - All smoke alarms must be operational and interconnected, 24/7/365.
2. **Carbon Monoxide Detectors**
 - Carbon monoxide is a dangerous, odorless, and colorless gas that can be fatal. It's crucial to have these detectors installed and tested regularly.
3. **Egress from Dwelling Units**
 - Dwelling units must have two unobstructed exits of sufficient width. Illumination for egress routes should be provided by emergency power in case of power outages.
4. **Windows and Doors**
 - All windows designed to open must function properly.
 - Windows must have **undamaged screens** and be free from **broken or cracked glass**.
 - Safe and secure entry/exit doors must be easy to open in case of fire.
5. **Electrical Panel**
 - The electrical panel must be safely installed, properly labeled, with no missing blanks, and have a secure cover.
6. **Lighting & Access to Electrical Panel**
 - Electric panels must be adequately lit and easily accessible to tenants.
7. **Clear Space Around Key Systems**
 - The electrical panel, water heater, or furnace must be clear of obstructions.
8. **Clutter-Free Living Spaces**
 - Units must be free from excessive clutter, especially flammable materials like paper or cardboard.
9. **Water Pressure & Leaks**
 - All faucets must deliver adequate water pressure and be free from leaks.
10. **Designated Use of Rooms**
 - Kitchens, hallways, living rooms, and dining rooms cannot be permanent sleeping areas to ensure proper functionality and compliance.
11. **Paint and Wall Finish Condition**
 - Interior and exterior paint and wall finishes cannot have peeling, flaking, chipping paint, or sharp edges. The exterior of the units cannot have openings or holes permitting pests, bats, birds, or water damage.
12. **Exterior Cleanliness**
 - Unit exteriors must be free from junk, trash, debris, and unregistered or inoperable vehicles.