

License No.

Done 26-05-2026

JOB NO. 1081068

POWERCO LTD
POWERCO LTD
35 Junction Street
Welbourn Taranaki 4360

Site: 6 Te Hirawanui Drive,
Kelvin Grove

Site Contact:

Salesperson:

Date: 14/05/2026



DG Labelling request - 00049428 - ICP 1000619785PC2EE
6 TE HIRAWANUI DRIVE, KELVIN GROVE, PALMERSTON NORTH, 4470
WMA 50474259



AS-BUILT LOW VOLTAGE CONNECTION RECORD

Physical Address and/or Legal Description (incl. Lot & DP No):

6 Te Hirawanui Dr, Kelvin Grove

Contractor: NRC Tech

Date Work Completed: 26-05-2026

Signed: 

City/Town: Palmerston North

District: Manawatu

Cow Shed Number (Dairy Number):

Customer Works Application Number: 50474259

Powerco Workorder Number: 50474259

ICP Number: 1000619785PC2EE

C.O.C Number:

PHYSICAL CONNECTION POINT:

Installed service:

Overhead line

☒ Underground cable

Conductor connected to:

☒ Box

Pole

Other (specify)

Pole/Service box number: 321065

CONDUCTOR DETAILS:

Conductor size: 16mm²

Conductor material: Cu

Number of cables: 1

Number of cores: 1

Insulation: PVC/NS

Number of phases: 1

Phase colour(s): Red

Fuse size (Amps): 63

Cable duct used:

☒ No


New (specify size)

Existing (specify size)

WORK PLAN AND DESCRIPTION:

Location of Conductor

Provide dimensioned plan below. Must include measurements for any change in direction, to any duct end and for any depth outside industry standard. GPS any cables that cannot be easily measured. Where an LV open point is at the point of connection, show clearly what side the connection has been made to. Include North arrow in circle.



No. 8

No. 6

321065

D.G Label here

Te Hirawanui dr

Describe the work performed: