

FC01 compact two-nozzle filling cell

Siemens-authoritative controls and bounded NVIDIA quality architecture

FICTIONAL ENGINEERING PROJECT - NOT FOR CONSTRUCTION

CONCEPTUAL SAFETY ARCHITECTURE - REQUIRES PROJECT-SPECIFIC RISK ASSESSMENT, DESIGN, VERIFICATION AND VALIDATION BY A QUALIFIED MACHINERY-SAFETY ENGINEER.
NO PERFORMANCE LEVEL, SIL, CATEGORY, CE CONFORMITY OR REGULATORY COMPLIANCE IS CLAIMED.

Release status	What is implemented	What remains blocked
CONTROLLED NATIVE-ENGINEERING RELEASE CANDIDATE	Revision-E canonical model; Git-object byte authority; selected-architecture native panel CAD; poll-safe immutable PLC transaction; encrypted OPC UA integration; 32 timed scenarios.	TIA/WinCC compile/archive; Startdrive; PLCSIM; final-hash QET reopen/export; confirmed electrical inputs; real dataset/model/target runtime; physical FAT/SAT.

This report is an evidence index. It is not proof of construction readiness, functional safety, native compile, FAT, SAT, electrical test, physical commissioning or AI performance.

Integrated architecture and deterministic ownership

The PLC owns all machine sequence, interlocks, timeouts and transfer permission. NVIDIA is a standard quality-inspection device and cannot perform or bypass safety functions.

Layer	Owner	Deterministic responsibility	Failure behavior
Field / power	Electrical	Identified device, cable/core, terminal and I/O channel	Fail-closed valves; external safety removes hazardous energy
Equipment control	S7-1500 FB instances	Gate, clamp, two fill channels, conveyor/pump VFD, capper	Module timeout/contradiction fault; outputs safe
Machine coordinator	S7-1500	Legal states, accepted command edges, no automatic restart	HOLDING, CONTROLLED_STOPPING or FAULTED
Operator interface	MTP700 Unified	Role-checked handshake; feedback and disabled reason	No direct physical-output writes
Quality vision	NVIDIA edge service	Securely acquire request and publish one correlated immutable result	Malformed/stale/low-confidence/fault -> quality hold
Regression	Python + asyncua	Sequence fault injection and encrypted real server/client transport	Design evidence only; never PLCSIM or production-endpoint proof

Machine states: UNINITIALIZED, INITIALIZING, STOPPED, READY, AUTOMATIC, MANUAL_SETUP, HOLDING, CONTROLLED_STOPPING, FAULTED and RECOVERY_RESET. Reset returns to STOPPED and never initiates motion.

Selected Siemens and edge hardware baseline

Function	Selected item	Order number / status	Verification boundary
PLC	SIMATIC S7-1500 CPU 1511-1 PN	6ES7511-1AL03-0AB0	Current official lifecycle checked; V20 device catalog/compile open
Pulse counting	TM Count 2x24V	6ES7550-1AA01-0AB0	Two independent 24 V pulse channels; TIA configuration open
DI / DO / AI	DI 32 HF; DQ 32 HF; AI 8xU/I HF	6ES7521-1BL00-0AB0; 6ES7522-1BL01-0AB0; 6ES7531-7NF00-0AB0	Front connectors, wiring and catalog compatibility open
HMI	MTP700 Unified Comfort	6AV2128-3GB06-0AX1	WinCC V20 compile/licence open
Drives	Two SINAMICS G120C PN 0.75 kW	6SL3210-1KE12-3UF2	Ratings provisional; Startdrive absent
Network	SCALANCE XC208 managed plus S615 firewall	6GK5208-0BA00-2AC2; 6GK5615-0AA01-2AA2	VLAN/firewall architecture selected; native policy and site approval open
Vision	Jetson Orin NX 16GB on industrial carrier	Carrier/integration SKU TBD	Carrier, thermals, EMC, camera and real dataset open

Authoritative engineering target: TIA Portal V20, executable/product version 2000.0.9501.1. Installed STEP 7 and WinCC V20 components do not prove usable licence entitlement. Current identity is not authorized for TIA Openness. Startdrive and PLCSIM are absent.

PLC-AI acceptance contract

Transport selection: encrypted OPC UA across a routed quality zone. The PLC publishes one immutable request and holds its request level until coherent BUSY or a terminal result is observed. Results are accepted only with the current session/ID, fresh heartbeat, approved model identity and non-contradictory payload.

PLC -> NVIDIA	NVIDIA -> PLC	Acceptance rule
VISION_ENABLE; INSPECTION_TRIGGER; INSPECTION_ID; SESSION_EPOCH; RECIPE_ID; EXPECTED_BOTTLES; TARGET_FILL_LEVEL; PLC_HEARTBEAT; RESULT_ACK_ID	VISION_READY; VISION_BUSY; RESULT_VALID; RESULT_ID; bottle/fill semantics; warning/fault; MODEL_ID; MODEL_SHA256; INFERENCE_TIME; VISION_HEARTBEAT	Payload publishes before RESULT_VALID and remains immutable until matching ACK. ID must be fresh/nonzero; heartbeat fresh; no contradiction/uncertainty. Otherwise HOLDING.

The adapter requires Basic256Sha256 SignAndEncrypt, X.509 application/user identity, controlled trust/CRL stores and an exact 27-node typed map. No model is delivered. No training, ONNX export, TensorRT engine, DeepStream execution, accuracy, confusion matrix, false-accept/reject analysis or production latency is claimed. The RTX 5060 Laptop GPU does not substitute for the absent CUDA/TAO/DeepStream target stack or representative dataset.

Validation evidence and release blockers

Gate	Evidence	Status
Canonical consistency	551 deterministic Revision-E checks cover generator parity, schedules, source/native evidence contracts, interface ownership, safety boundaries and prohibited artifacts	PASS
Deterministic regression	88 simulator/source/native-contract + 59 edge-service + 15 interface-harness tests; 32 timed scenarios; one release; zero invariant violations/restarts	PASS - not PLCSIM
Workbook	21 summary/schedule sheets; deterministic normalized build, formula-error scan and all-sheet rendered review	PASS after final freeze
QElectroTech	Corrected 26-folio QET BCA022BE0B9F...; 24/24 static and 6/6 contracts. Exact final hash was not natively reopened/exported or reviewed page-by-page	SOURCE PASS; NATIVE/VISUAL BLOCKED
Panel CAD	FreeCADCmd reopened 165 objects / 148 controlled solids; STEP solid, IGES bounded-face and DXF/hole reimports verified	PASS
TIA / WinCC / drives	V20 installed; no native project, compile, cross-reference, archive restore or Startdrive evidence	BLOCKED
PLCSIM	Not installed	BLOCKED
NVIDIA model/runtime	Secure local asyncua integration passed; production PLC/PKI, dataset, model and CUDA/TensorRT/DeepStream target stack absent	INTEGRATION PASS; MODEL/RUNTIME BLOCKED

Gate totals: 5 PASS, 4 PARTIAL, 12 BLOCKED, 1 OPEN. Release use: controlled design review and continuation in qualified native tools only. Read the manifest, acceptance-gate report and open-input register before work.