

Harmonization of Frequency-Related Messaging and Operational Actions

Date-18-09-2026

A meeting was convened to discuss the operational actions and messaging practices across RLDC and to ensure that they are aligned with the operating procedure on 18th Sep 2026. During the meeting following points were discussed and agreed upon:

1. GM, System Operation, NLDC highlighted that with increasing renewable penetration, the fundamental nature of system state transitions has changed. With higher reference contingencies and greater dependence on weather-dependent generation, the system may transition directly from Normal to Emergency or Extreme Emergency. Accordingly, messaging and operational responses need not necessarily follow a sequential progression.
2. NLDC highlighted the need to harmonize the messaging formats across all RLDCs. In particular:
 - a. ACE data shall be included in the messages.
 - b. The nature of violation shall be clearly and unambiguously specified along with the required actionable points.
3. NLDC presented certain gaps observed from the sample messages reviewed, including multiple types of violations being covered in a single message, mismatch between system state and deviation levels, and non-inclusion of ACE.
4. All RLDCs agreed to review the identified gaps and reconcile the same at the earliest. ED, ERLDC highlighted that State utilities may sometimes face difficulty in interpreting ACE. NLDC clarified that reserve calculations are already being carried out based on ACE. Inclusion of ACE is particularly relevant during frequency-deviation scenarios where the State's drawal may be close to its schedule, while an obligation may still arise based on the prevailing frequency condition.
5. NLDC highlighted that violation messages should also be issued to generating stations. RLDCs informed that such messages are already being issued where deviations are significant. RLDCs also informed that deviation-related messages are being issued to QCAs.
6. NLDC highlighted that, based on an anticipated resource shortfall in a State, anticipatory communication may also be issued. NRLDC and SRLDC informed that resource-adequacy shortfall-based communications are already being issued to States. ERLDC requested NLDC to develop a suitable format for such anticipatory communication and SOS message.
7. ERLDC highlighted the need for streamlining triggering criteria for implementation of physical regulatory measures. NLDC clarified that a single frequency & deviation-based criterion may not be appropriate, and the decision remains at the discretion of the Shift-in-Charge based on the prevailing system conditions. However, frequency criteria corresponding to Extreme Emergency conditions are already specified.
8. NLDC requested all RLDCs to share the details of messages issued on 15th and 16th September in the prescribed format. The requisite data has now been received from all RLDCs.