GWALIOR MUNICIPAL CORPORATION

WATER QUALITY SURVEILLANCE & ENVIRONMENTAL HEALTH CELL - ISO/IEC 17025:201

Central Analytical Testing Laboratory, Maharaj Bada Central Facility, Gwalior (M.P.)

NABL CERTIFIED TC-8491
Statutory BIS IS 10500:2012

STATUTORY MICROBIOLOGY CLEARANCE CERTIFICATE

Coliform culture and statutory clearance post chlorine booster distribution cycle

REPORT / TRACKING ID:	GWL-MICRO-35692	**SAMPLING DATE:**	30 October 2026
MONITORING STATION:	Ward 58 - Padav Reservoir Distribution Main	**ANALYSIS PROTOCOL:**	Spectrophotometric Batch
ACCREDITED CHEMIST:	Anita Patel (Chief Microbiologist, State Environmental Lab)	**SECURITY SEAL:**	SSE-KMS AES-256 Encrypted
AWS S3 OBJECT KEY:	`reports/compliance-audits/ward58_padav_post_flush_clearance.pdf`		

#	WATER QUALITY PARAMETER	METHOD / INSTRUMENT	BIS IS 10500 LIMIT	RESULT	STATUS
01	**Thermotolerant Coliforms**	Membrane Filtration (44.5 C / 24h)	0 CFU/100ml	**0 CFU/100ml**	**CLEARED**
02	**Total Coliform Organisms**	Chromogenic Coliform Culture	0 CFU/100ml	**0 CFU/100ml**	**CLEARED**
03	**Escherichia Coli (E. Coli)**	MUG Fluorescence Detection	0 CFU/100ml	**0 CFU/100ml**	**CLEARED**
04	**Heterotrophic Plate Count**	Pour Plate Method (37 C / 48h)	< 100 CFU/ml	**12 CFU/ml**	**CLEARED**
05	**Free Residual Chlorine**	DPD Spectrophotometry	Min 0.20 mg/L	**0.62 mg/L**	**OPTIMAL**

STATUTORY VERDICT & FINDINGS:

VERDICT: Zero bacterial colonies detected. Full statutory microbiological clearance granted.

Residual chlorine buffer of 0.62 mg/L ensures complete pathogen suppression through distribution grid.

EXAMINED & CERTIFIED BY:

Anita Patel (Chief Microbiologist, State Environmental Lab)
NABL National Accreditation Board Certification #TC-8491

GMC PHED SEAL
VERIFIED & SEALED
SHA-256: e3b0c442...

STATUTORY CLEARANCE AUTHORITY:

GMC Water Works Directorate, Gwalior
Public Health Engineering Department, M.P. Government