Observations

Page one observation: generator A tested at 230 volts.

Observations

Page two observation: generator B tested at 215 volts.

Observations

Page three observation: generator C failed to start.