Water System Name	Water System ID	Sample Point	Sample Point ID	Date Collected	RID	LAB	PFOA	PFOS	PFNA	PFHxS	PFHpA	PFBS	PFHxA	PFDA	PFUnA	PFTriA	PFDoA	PFTeA	NEtFOSAA	NMeFOSAA	units	Method
Cannon Air Force Base	NM3567905	Well #3	679050031	3/7/2019	HAL123676	TestAmerica	ND	ND	ND	0.0084	0.0039	0.0093	0.023	ND	ug/L	Method: EPA 537 modified						
Cannon Air Force Base	NM3567905	Well #12	679050081	3/7/2019	HAL123672	TestAmerica	ND	ND	ND	0.007	0.003	0.0065	0.0017	ND	ug/L	Method: EPA 537 modified						
Cannon Air Force Base	NM3567905	Well #8	679050071	3/7/2019	HAL123671	TestAmerica	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ug/L	Method: EPA 537 modified
Cannon Air Force Base	NM3567905	Well #9	679050321	3/7/2019	HAL123673	TestAmerica	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ug/L	Method: EPA 537 modified
Allsups 45	NM3580105	Treatment Plant #1	801050021	11/5/2018	HAL116791	Anatek Labs, Inc.	ND	ND	ND	ND	ND	ND	Not Analyzed	ug/L	Method: EPA 537							
Clovis West LLC	NM3553405	Treatment Unit #1	534050081	11/5/2018	HAL116794	Anatek Labs, Inc.	ND	ND	ND	ND	ND	ND	Not Analyzed	ug/L	Method: EPA 537							
Desert Ranch MDWCA	NM3510005	SS #1	100050031	11/5/2018	HAL116795	Anatek Labs, Inc.	ND	ND	ND	ND	ND	ND	Not Analyzed	ug/L	Method: EPA 537							
Travelers World Campground	NM3500205	Well #1	002050011	11/5/2018	HAL116792	Anatek Labs, Inc.	ND	ND	ND	ND	ND	ND	Not Analyzed	ug/L	Method: EPA 537							
Turquoise Estates Wtr. Coop	NM3550905	Well #1 original	509050011	11/5/2018	HAL116793	Anatek Labs, Inc.	ND	ND	ND	0.00921	ND	ND	Not Analyzed	ug/L	Method: EPA 537							
Turquoise Estates Wtr. Coop	NM3550905	Well #1 confirmation	509050011	11/5/2018	HAL116793	Anatek Labs, Inc.	ND	ND	ND	0.00715	ND	ND	Not Analyzed	ug/L	Method: EPA 537							
Turquoise Estates Wtr. Coop	NM3550905	Well #1 field blank	509050011	11/5/2018	HAL116793	Anatek Labs, Inc.	ND	ND	ND	ND	ND	ND	Not Analyzed	ug/L	Method: EPA 537							
Turquoise Estates Wtr. Coop	NM3550905	Well #3	509050081	11/5/2018	HAL116798	Anatek Labs, Inc.	ND	ND	ND	ND	ND	ND	Not Analyzed	ug/L	Method: EPA 537							
Cannon Air Force Base	NM3567905	EP #1	679050171	11/6/2018	HAL116796	Anatek Labs, Inc.	ND	ND	ND	ND	ND	ND	Not Analyzed	ug/L	Method: EPA 537							
Cannon Air Force Base	NM3567905	EP #4	679050341	11/6/2018	HAL116797	Anatek Labs, Inc.	ND	ND	ND	ND	ND	ND	Not Analyzed	ug/L	Method: EPA 537							
EPCOR Wtr NM Inc Clovis	NM3527305	#22 EP	273050331	11/7/2018	HAL116799	Anatek Labs, Inc.	ND	ND	ND	ND	ND	ND	Not Analyzed	ug/L	Method: EPA 537							
EPCOR Wtr NM Inc Clovis	NM3527305	Norris & Brady EP	273050341	11/7/2018	HAL116800	Anatek Labs, Inc.	ND	ND	ND	ND	ND	ND	Not Analyzed	ug/L	Method: EPA 537							
EPCOR Wtr NM Inc Clovis	NM3527305	N 40 EP	273050351	11/7/2018	HAL116801	Anatek Labs, Inc.	ND	ND	ND	ND	ND	ND	Not Analyzed	ug/L	Method: EPA 537							
EPCOR Wtr NM Inc Clovis	NM3527305	Thomas & Brady EP	273050361	11/7/2018	HAL116802	Anatek Labs, Inc.	ND	ND	ND	ND	ND	ND	Not Analyzed	ug/L	Method: EPA 537							
EPCOR Wtr NM Inc Clovis	NM3527305	Well #17 EP	273050891	11/7/2018	HAL116803	Anatek Labs, Inc.	ND	ND	ND	ND	ND	ND	Not Analyzed	ug/L	Method: EPA 537							
EPCOR Wtr NM Inc Clovis	NM3527305	Well #20 EP	273050951	11/7/2018	HAL116804	Anatek Labs, Inc.	ND	ND	ND	ND	ND	ND	Not Analyzed	ug/L	Method: EPA 537							
EPCOR Wtr NM Inc Clovis	NM3527305	Well #13 EP	273050981	11/7/2018	HAL116805	Anatek Labs, Inc.	ND	ND	ND	ND	ND	ND	Not Analyzed	ug/L	Method: EPA 537							
EPCOR Wtr NM Inc Clovis	NM3527305	Sandia Booster Pump	273051041	11/7/2018	HAL116806	Anatek Labs, Inc.	ND	ND	ND	ND	ND	ND	Not Analyzed	ug/L	Method: EPA 537							
EPCOR Wtr NM Inc Clovis	NM3527305	Mesa EP	273051071	11/7/2018	HAL116807	Anatek Labs, Inc.	ND	ND	ND	ND	ND	ND	Not Analyzed	ug/L	Method: EPA 537							
EPCOR Wtr NM Inc Clovis	NM3527305	Well #205 EP	273051191	11/7/2018	HAL116809	Anatek Labs, Inc.	ND	ND	ND	ND	ND	ND	Not Analyzed	ug/L	Method: EPA 537							

ND = not detected

EP: entry point (water entering distribution system to customers)
Well: drinking water system source prior to treatment