

Recurring Failure and Root-Cause Escalation

Document ID	RCA-POL-2026	Status	current
Effective date	2026-02-01	Owner	Reliability Engineering

Recurring failure definition

A recurring failure is three or more corrective work orders for the same asset and failure family within a rolling 90-day period.

Required actions

1. Open an engineering review.
2. Complete a documented root-cause analysis within 2 business days.
3. Review maintenance history, operating conditions, alarms, parts replaced, and vendor observations.
4. Create corrective actions with an owner and due date.

Capital replacement threshold

A capital replacement assessment is required when the same asset has four or more corrective failures within a rolling 180-day period.

Routine preventive-maintenance work orders do not count toward either threshold.