

HVAC Preventive Maintenance Schedule

Document ID	PM-SCHED-2026	Status	current
Effective date	2026-01-01	Owner	Reliability Engineering

Fan coil units (FCUs)

- Inspect filters and condensate drains every quarter.
- Inspect fan motors and electrical terminals every 6 months.
- Perform a full functional test annually.

Rooftop units (RTUs)

- During November through March, inspect each RTU monthly.
- From April through October, inspect each RTU quarterly.
- Inspect refrigerant condition, compressors, belts, filters, safeties, and controls.

Air handling units (AHUs)

- Inspect filters monthly.
- Inspect belts, bearings, and dampers quarterly.