

KEO INTERNATIONAL CONSULTANTS

HVAC Indoor Unit Schedule — Al Zahra Commercial Tower, JLT

Document: KEO-AZT-HVAC-IUS-001 Rev: A | Date: March 2026

VRF INDOOR UNIT SCHEDULE — DECORATIVE (CEILING CASSETTE / WALL / CONSOLE)

Tag	Floor / Zone	Type	Capacity	System Ref	Qty
IU-L1-01	Ground Floor — Lobby	4-way Ceiling Cassette	3.5 TR	VRF-ODU-01	3
IU-1F-01	1st Floor — Reception	4-way Ceiling Cassette	2.0 TR	VRF-ODU-01	2
IU-1F-02	1st Floor — Open Office	4-way Ceiling Cassette	2.5 TR	VRF-ODU-01	4
IU-1F-03	1st Floor — Meeting Rooms	4-way Ceiling Cassette	1.5 TR	VRF-ODU-02	3
IU-2F-01	2nd Floor — Open Office	4-way Ceiling Cassette	2.5 TR	VRF-ODU-02	4
IU-2F-02	2nd Floor — Director Cabins	Wall Mounted Split	1.5 TR	VRF-ODU-02	4
IU-3F-01	3rd–17th Floor — Typical (×15)	4-way Ceiling Cassette	2.0 TR	VRF-ODU-03–10	60
IU-3F-02	3rd–17th Floor — Typical (×15)	Wall Mounted Split	1.5 TR	VRF-ODU-03–10	30
IU-18-01	18th Floor — Penthouse	4-way Ceiling Cassette	2.5 TR	VRF-ODU-11	4
IU-18-02	18th Floor — Penthouse	Console Floor Mounted	1.5 TR	VRF-ODU-11	2

VRF INDOOR UNIT SCHEDULE — DUCTED (CONCEALED / HIGH-STATIC)

Tag	Floor / Zone	Type	Capacity	System Ref	Qty
IU-GF-D1	Ground Floor — Retail Shell	Ducted Concealed (Medium Static)	5.0 TR	VRF-ODU-01	2
IU-1F-D1	1st Floor — Corridor + Toilets	Ducted Concealed (Low Static)	2.0 TR	VRF-ODU-02	2
IU-2F-D1	2nd Floor — Corridor + Toilets	Ducted Concealed (Low Static)	2.0 TR	VRF-ODU-02	2
IU-3F-D1	3rd–17th Corridor (×15)	Ducted Concealed (Low Static)	2.0 TR	VRF-ODU-03–10	15
IU-RF-D1	Roof Plant Room	Ducted High-Static	3.0 TR	VRF-ODU-12	1

SUMMARY — INDOOR UNIT COUNT BY TYPE

Decorative units (cassette / wall / console)	116

Ducted units (concealed / high-static)

Total indoor units

Predominant type

DECORATIVE (~84%)

Outdoor VRF units linked

12 × 16 HP (VRV-X heat recovery)

FAHU units (separate loop)

4 × 6.0 TR

