



1. CONTRACTOR SHALL SUBMIT THE FOLLOWING FOR REVIEW AND APPROVAL PRIOR TO FABRICATION OF

3. TESTING OF EMBEDDED INSERTS: APPLY DIRECT TENSION TEST LOAD OF 1.5 TIMES THE FORCE AT EACH INSERT. TEST ALL INSERTS.

4. CONTRACTOR SHALL INSTALL INSERTS PER MANUFACTURER'S RECOMMENDATIONS. 5. PLUG ALL INSERTS WITH PLASTIC THREADED BOLTS, FLUSH WITH SURFACE.

DETAIL SCALE: 1"=1'-0"






WALL PLATE DETAIL 3/4"=1'-0"

SLAB PLATE DETAIL 3/4"=1'-0"




%"øx4" HEADED

STUD, GALV, TYP



ELEVATION

TYPICAL REINFORCEMENT AROUND WALL OPENING 3/4"=1'-0"



1. VERIFY ALL DIMENSIONS AND LOCATIONS WITH MA DRAWINGS PRIOR TO START OF CONSTRUCTION.

2. REBARS MAY BE EITHER CAST-IN-PLACE OR POST INSTALLED.

3. POST INSTALLED DOWELS SHALL BE SET IN EPOXY W/ MIN 6" EMBED INTO CONC FOOTING.

4. FOOTING REINF NOT SHOWN FOR CLARITY.

5. FOR INFORMATION NOT SHOWN OR NOTED, SEE MA DRAWINGS.

DETAIL 3/4"=1'-0"

> CITY AND COUNTY OF SAN FRANCISCO SAN FRANCISCO PUBLIC WORKS

BUREAU OF DESIGN AND ENGINEERING DEPUT BUREAU MANAGER

12/19/18

DESIGNED

WY VI 01/2019

01/2019 BUREAU MANAGER 12/21/8 CHECKED WL WL 01/2019

PUBLIC UTILITIES COMMISSION WATER ENTERPRISE CITY DISTRIBUTION DIVISION 19TH AVENUE (STATE ROUTE 1)
COMBINED CITY PROJECT AUXILIARY WATER SUPPLY SYSTEM WORK

CITY AND COUNTY OF SAN FRANCISCO

DETAILS III AS SHOWN Liter L. Mulli-MANAGER, CITY DISTRIBUTION DIVISION 01/2019 297 OF 356 MA-S2.3 111,595 REVISIONS

FOR THE SOLE USE OF THE DOCUMENT RECIPIENT - DO NOT CITE, COPY, OR CIRCULATE WITHOUT THE EXPRESS PERMISSION OF THE SFPUC.

REFERENCES GATE BOOK PAGES, PLANS, SURVEY NOTES, ETC, USED GATE BOOK PAGES NO.

PLAN APPROVAL DATE CONTRACT No. COUNTY POST MILES TOTAL PROJECT PROJECT ID DISTRICT ROUTE 04-0G3501 0400000325 SF R0.94/4.05FOR REDUCED PLANS ORIGINAL SCALE IS IN INCHES

RED 0.70MM
YELLOW 0.20MM
GREEN 0.25MM
CYAN 0.40MM
BLUE 0.50MM
MAGENTA 0.20MM
WHITE 0.35MM
GRAY 0.15MM
9 0.15MM
10 1.00MM
100 0.50MM
210 0.50MM

PLOT: EXTENTS SCALE: 1:1 BORDER:

COLOR: No.

22,34

FILE: