

Estimate Power generation of invisible solar site using State estimation

1st Pornchai Chaweewat
EECC
AIT)
Pathumthani, Thailand
chaweewat.p@gmail.com

2nd Weerakorn Ongsakul
EECC
AIT)
Pathumthani, Thailand
email address

3rd Jai Govind Singh
EECC
AIT)
Pathumthani, Thailand
email address

4th Ali abur
EEC
NEU
Boston, MA, USA
email address

Abstract—
Index Terms—

I. INTRODUCTION

Sixty years ago, the price of solar panels was astronomical. The price was over 1,000 US dollars per watt in today's money with 1 percent efficiency [1]. As the cost continues to drop, solar panel systems are becoming much more viable for the average household. Today's price is less than 2.8 US dollars per watt for solar panel system including solar module, inverter, wiring hardware, labor cost, and maintenance cost [2]. As result of exponentially acceralate increasing in number of globally solar PV integration, especailly in residential sector.

Many researchers have studied the impacts and risks of PV on distribution systems [3]- [8]. However, the detection and monitoring of residential PV systems has not been the focus of the studies and related research.

Recently, the highest penetration of solar PV, recognized a large number of unauthorized solar PV installation [9]. Unauthorized solar PV installation creates safety risks and lack of visibility may result in incorrect planning, and operation, including over-voltage, back-feeding. Futhermore, in worst case scenario, it may damage system equipment such as transformers, voltage regulators, as well as customer applicants [10], [11]. In previous studies, there are various reasons for unauthorized or incorrectly registered PV system: a) owner decided not to apply for a permit to avoid fees [12], b) regulations were required after the system was installed, c) lack of awareness by the owner of diverse permitting rules, d) difference rules depending on size and type of PV installation can make the owners believe they do not need a permit e) change in property ownership including transfer, f) multiple system installed or future iaddition at the same premise, g) incorrect third party handling of the permit appication, h) data entry and data maintenance errors.

The rest of the paper is structured as follows: Section II reviews related research on state estimation application for power system and previous detection and estimation techniques on invisible solar PV site. Section III formulates the mathenatic model of measurement data as well as the structure

of proposed method. Section IV shows the results of proposed method on test cases. Section V concludes the paper and dicusses future research oppotunities on PV system detection and estimation.

II. LITERATURE REVIEWS

A. Applications of State estimation in power system

State estimation on distribution power system is reviewed in [21].

State estimation provides the optimum estimate of power system state based on received measurement units and the knowledge of network modeling. The measurement units may include as follows:

- power injection (real/reactive),
- power flow (real/reactive),
- bus voltage magnitude,
- phase angle,
- line current magnitude,
- current injection magnitude.

State Estimation provides various benefits for power system analysis as follows:

1) *Real time mornitoring*: For power system in transmission and distribution levels [17]. The Advance Meter infras-structure (AMI) data are fed into SE to real-time mornitor distribution power system in [19]. It improved the accuracy comparing to pseudo measurment based on historical load.

2) *Load allocation*: In distribution power system, SE assigns active and reactive power values to bus downstream [18]. Class curves and individual average demand of clients improved accuracy of load allocation [16]. The data from AMR system, which are used as the pseudo-measurements, was used to estimate load on the distribution transformers. [17].

3) *Bad data analysis*: In several real application, it happens that some flow measurement has no sign or the sign is wrong. A re-weighting technique was used to reduced the weights association to these measurements [18]. It also could helps to treat of power flow with erroneous sign. Futhurmore, SE was implemented in cyber attack events [22] on power system states. A detection false data injection method is proposed in [20].

4) *Topology identification*: the status of branches and switches are identified in [18].

B. previous solar PV detection techniques

The previous studies has been done on detection of location and estimation of power generation of invisible solar PV sites. Reference [23] proposed a change-point detection algorithm for a time series for residential solar PV detection. These method required smart meter data and historical load profile. The uncertainty of solar PV site and the data generated by a small set of selected representative sites were taken into account to estimates the power gneneration of known solar PV site in [24]. The new hybrid k-means and PCA techniques provided good accuracy of estimating invisible solar PV sites. The big data characterization of smart grids and two-layer dynamuc optimal synchrophasor measurement devices selection algorithm for fault detection, identification, and causal impact analysis was proposed in [25]. The utility data based on random matrix therory (RMT) are used in detection and estimation of invisible solar PV in real case in China in [26].

C. Contributions

Many researchers have studied the detection and estimation location of invisible solar PV installation [23] [26]. These study depended on smart meter data, data set of solar PV generation, as well as historical demand of customer in each load. This paper proposed method which identify location using state estimation, correlation measured and estimating the installation capacity using change point method of invisible solar PV site. All solar PV's site is assumed to operate at unity power factor. The solar PV is located randomly at any bus excepted slack bus. The measurement units are located at optimum locations. The measured data such as solar irradiation, power flow measurements in lines and voltage measurements at busses are generated with gaussian noise. The proposed method consists of four steps:

- collect solar irradiation, measurement data
- allocate power demend in each buses, nodes.
- indentify invisible solar PV site
- estimate solar PV site's installation capacity

III. PROBLEM FORMULATION

This section will presents the overall methodology of the study which will be devided into four parts. The conceptual of methodology is illustrated in Fig. 1.

A. Measurement devices, measured data and accuracy

In this study, there are three type of measurements; bus, line, and transformers measurement. Voltage magnitude in per unit is measurement at bus. Active and reactive power flow, and magnitude curreng are measured at line and trasformers. Bus measurement has 1% error and line measurement has 3% error.

To generate measurement data for testing prupposes, measurement error was added to tha actual measurements as shown in Equation 1.

$$Z = Z_a \pm e_z \quad (1)$$




Fig. 1. conceptual methodology

where Z_a is actual data and e_z is error added base on accuracy of the measurement.

These error are assumed to be modeled independent Gaussian random variable [14]. where where the error value is expected value from gaussian distribution. noise is gaussian distribution,as shown in Equation 2

$$g(x) = \frac{1}{\sigma\sqrt{2\pi}} e^{-\frac{1}{2}((x-\mu)/\sigma)^2} \quad (2)$$

B. Load allocation based state estimation

SE is based on the weighted least square (WLS) approach [13]. The method solves the following WLS problem to obtain an estimate of the system operating point defined by the system state x :

$$\min_x J(x) = \sum_{i=1}^m w_i (z_i - h_i(x))^2 = [z - h(x)]^T W [z - h(x)] \quad (3)$$

where w_i and $h_i(x)$ represent the weight and the measurements function associated with measurement z_i , respectively. For the solution of this problem the conventional iterative method is adape by solving following normal equations at each iteration, to compute the update $x^{k+1} = x^k + \Delta x^k$.

$$[G(x^k)] \Delta x^k = H^T(x^k) W [z - h(x^k)] \quad (4)$$

Where

$$G(x) = H^T(x)WH(x) \quad (5)$$

is the gain matrix and H is the jacobian of the measurement function $h(x)$.

C. Solar PV site's location identification

This part will describe location identification of invisible solar PV's site. The correlation-based feature selection (CFS) is key tool here. The basis of the CFS that was introduced in [27]. The CFS will be performed as a statistical measure of relationship between solar irradiation and load allocation from previous part. The measure is best used in these two variables that demonstrate a linear relationship between each other. The correlation coefficient that indicates the strength of the relationship between these two variables can be found using following formula:

$$r_{IP} = \frac{\sum(I_i - \bar{I})(P_i - \bar{P})}{\sqrt{\sum(I_i - \bar{I})^2 \sum(P_i - \bar{P})^2}} \quad (6)$$

where r_{IP} is the correlation coefficient of the linear relationship between the solar irradiation (I) and load consumption (P), I_i is the values of the solar irradiation variable in a sample, \bar{I} is the mean of I , P_i is the values of the load consumption variable in a sample, \bar{P} is the mean of P .

The negative correlation shows that the variables tend to move in opposite directions (i.e., when one variable increases, the other variable decreases). The probability of solar PV site located at bus i is expressed in Equation 7

$$\text{prob}_i = \begin{cases} 0 & \text{if } r_i \geq 0 \\ 1 & \text{if } r_i < 0 \end{cases} \quad (7)$$

D. Estimate solar PV site's installation capacity

$$\Delta \quad (8)$$

IV. TEST CASES AND RESULTS

The proposed solar PV detection was implemented using python language. Two power system are tested. There two test cases are based on four bus system and CIGRE Task Force C6.04.02 paper [15].

A. Test cases

1) *four bus system*: The one line diagram of the four bus system is shown in Fig. 2.

Table I shows the results. From the table, I it can be seen that the proposed method can predict perfectly location of solar PV.

TABLE I
RESULTS OF 4 BUS SYSTEM

[random PV location at bus (size of PV kW)]	Solar PV detection
[1(10)]	[1(8)]
[1(10), 2(20)]	[1(9), 2(17)]




Fig. 2. four bus system




Fig. 3. CIGRE network

2) *CIGRE system*: Table II shows the results. From the table, II it can be seen that the proposed method can predict perfectly location of solar PV.

TABLE II
RESULTS OF CIGRE

[random PV location at bus (size of PV kW)]	Solar PV detection
[1(10)]	[1(8)]
[1(10), 2(20)]	[1(9), 2(17)]

B. Results

V. CONCLUSION

Here is Conclusion.

ACKNOWLEDGMENT

REFERENCES

- [1] <https://www.theguardian.com/sustainable-business/2016/jan/31/solar-power-what-is-holding-back-growth-clean-energy>
- [2] <https://blog.pickmysolar.com/the-price-of-a-solar-panel-system-over-the-years>
- [3] M. E. Baran, H. Hooshyar, Z. Shen, and A. Huang, Accommodating high PV penetration on distribution feeders, *IEEE Trans. Smart Grid*, vol. 3, no. 2, pp. 10391046, Jun. 2012.
- [4] M. J. Reno, K. Coogan, R. J. Broderick, J. Seuss, and S. Grijalva, Impact of PV variability and ramping events on distribution voltage regulation equipment, in *Proc. IEEE Photovolt. Spec. Conf.*, Tampa, FL, USA, 2014.
- [5] M. E. Baran, H. Hooshyar, Z. Shen, and A. Huang, Accommodating high PV penetration on distribution feeders, *IEEE Trans. Smart Grid*, vol. 3, no. 2, pp. 10391046, Jun. 2012.
- [6] P. Li, X. Yu, J. Zhang, and Z. Yin, The H control method of grid-tied photovoltaic generation, *IEEE Trans. Smart Grid*, vol. 6, no. 4, pp. 16701677, Jul. 2015.
- [7] A. Samadi, L. Soder, E. Shayesteh, and R. Eriksson, Static equivalent of distribution grids with high penetration of PV systems, *IEEE Trans. Smart Grid*, vol. 6, no. 4, pp. 17631774, Jul. 2015.
- [8] H. Ravindra et al., Impact of PV on distribution protection system, in *Proc. North Amer. Power Symp. (NAPS)*, Champaign, IL, USA, Sep. 2012, pp. 16.
- [9] P. Fairley, (Jan. 2015). Hawaii's Solar Push Strains the Grid. [online]. Available: <http://www.technologyreview.com/news/534266/hawaiis-solar-push-strains-the-grid/>
- [10] W. Staff, (Sep. 2014). Heco Customers Asked to Disconnect Unauthorized PV Systems. [Online]. Available: <http://khon2.com/2014/09/05/heco-customers-asked-to-disconnect-unauthorized-pv-systems/>
- [11] V. Schwarzer and R. Ghorbani, Transient over-voltage mitigation: Explanation and mitigation options for inverter-based distributed generation projects, *Elect. Vehicle Transp. Center, Sch. Ocean Earth Sci. Technol.*, Univ. Hawaii i Manoa, Honolulu, HI, US A , Tech. Rep. HNEI-02-15, Feb. 2014.
- [12] <https://www.snopes.com/fact-check/is-it-illegal-florida-power-home-solar-storm/>
- [13] Roytelman I. and S.M. Shahidehpour, State estimation for electric power distribution systems in quasi real-time conditions, *IEEE Trans. Power Systems*, 1993 winter meeting, paper no:090-1-PW RD.
- [14] A. Abur and A. G. Exposito, *Power System State Estimation: Theory and Implementation*. New York: Marcel Dekker, 2004.
- [15] CIGRE' Task Force C6.04.02: Developing benchmark models for integrating distributed energy resources. S. Barsali, Kai Strunz, Zbigniew Styczynski Published 2005
- [16] STATE ESTIMATION FOR LOAD ALLOCATION IN DISTRIBUTION POWER SYSTEMS, R. Sharifian 1 E. Jafari 1 M. Rahimi 2 P. Ghaebi Panah 3
- [17] A Revised Branch Current-Based Distribution System State Estimation Algorithm and Meter Placement Impact, Haibin Wang, Student Member, IEEE, and Noel N. Schulz, Senior Member, IEEE
- [18] An Integrated Load Allocation State Estimation Approach for Distribution Networks, Jorge Pereira, J. T. Saraiva, Member, IEEE, V. Miranda, Member, IEEE
- [19] Distribution System State Estimation Using AMI Data, Mesut Baran, T. E. McDermott
- [20] Gu Chaojun, Student Member, IEEE, Panida Jirutitijaroen, Senior Member, IEEE, and Mehul Motani, Member, IEEE, Detecting False Data Injection Attacks in AC State Estimation
- [21] A Review on Distribution System State Estimation, Anggoro Pradianto and Chan-Nan Lu, Fellow, IEEE
- [22] Nathan Wallace, Stanislav Ponomarev, and Travis Atkison, Identification of Compromised Power System State Variables
- [23] X. Zhang and S. Grijalva, A data-driven approach for detection and estimation of residential pv installations, *IEEE Transactions on Smart Grid*, vol. 7, no. 5, pp. 24772485, Sept 2016.
- [24] H. Shaker, H. Zareipour, and D. Wood, Estimating power generation of invisible solar sites using publicly available data, *IEEE Transactions on Smart Grid*, vol. 7, no. 5, pp. 24562465, Sept 2016.
- [25] H. Jiang, X. Dai, D. W. Gao, J. J. Zhang, Y. Zhang, and E. Muljadi, Spatial-temporal synchrophasor data characterization and analytics in smart grid fault detection, identification, and impact causal analysis, *IEEE Transactions on Smart Grid*, vol. 7, no. 5, pp. 2525 2536, Sept 2016.
- [26] Detection and Estimation of the Invisible Units Using Utility Data Based on Random Matrix Theory, Xing He, Robert C. Qiu, Fellow, IEEE, Lei Chu, Qian Ai, Zenan Ling, Jian Zhang
- [27] M. A. Hall, Correlation-based feature subset selection for machine learning, Ph.D. dissertation, Dept. Comput. Sci., Univ. Waikato, Hamilton, New Zealand, 1999.