A novel electricity probabilistic price forecasting using deep residual neural networks for GEFCOm2014

Pornchai Chaweewat[1]

AIT

Abstract

What we do? - This paper proposes a electricity price forecasting approach based on a novel residual neural network for probabilistic electricity price forecasting under price spike environment for GEFCom2014.

Why I do this? - The electricity price, in deregulation electricity market, has become more fluctuated and generally unanticipated price spike. The use of prediction interval or probabilistic forecasting has become much more common due to it help market participants to submit effective bid with low risks.

How I do this? - A new model is developed from novel deep residual neural network approach. It consists of two major part. First is spike prediction. Interval's value forecasting is another which is formulated into two methods; upper-lower bounds and mean-variance method. The proposed methodology is test with GEFCom2014 dataset where there are 15 tasks for electricity price forecasting which high and spike price are include. The novel method is tested with non-price spike electricity price forecasting model as benchmark.

What is the result? - The overall results show that the proposed method with confidence levels at 90% and 80% can imporve reliability and narrow width of prediction interval under non and high number of high and spike price tasks. The model can handle in spike price occurances environment where it is realistic globally.

Keywords: Residual neural network, GEFCom2014

---

1. Introduction

Since the transformation of the deregulation of modern power systems, electricty price forecasting has become more important process to energy market's participants at planning and operation levels.

(talk about point of forecating, 1 method, 2 measurement, 3 problems) Over the past few decades, many powerful forecasting algorithms have been developed (for a recent comprehensive review, see [1]). The majority of emprical studies are on point forecasting (or call expected value of the spot price).

(mention about problems of poing of forecasting, introduct to interval forecasting)

(mention on used of deep residual neural network and why we use this method) Deep residual network is modified from deep Feed Forward Neural Networks (FFNNs) with extra connections (or called skip connections), passing input from one layer to a late layer as well as the next layer as shown in figure 1. DRN is widely used in computer vision and pattern reconigtion. There are few used on deep residual neural network.

Figure 1: Basis DRN

(proposeal) Therefore, this paper seeks to apply

(structure) The remainder of the paper is organized as follows. First, the

problem formulation is presented in brief in section 2. The, the main features of the ANN algorithm are presented in section 3. Next, the results after prediction in different cases of proposed method are discussed in section 4. Finally, conclusions are drawn in the last section of this paper.

2. Problem formulation

2.1. Interval forecasting

2.2. Measurement

The performance of the proposed model need to be assessed in term of the quaility of of prediction interval, namely converage probability and PI width. First, PI converage probility (PICP) refers to the ability of the constructed PIs to capture the actual target variables. PICP can be methematically stated as

$$PICP = \frac{1}{N} \sum_{i=1}^{N} C_i \tag{1}$$

where

$$C_i = \{ 1 \ , if t_i \in [L_i, U_i] 0, if t_i \notin [L_i, U_i] \tag{2}$$

where N is the number of samples in the test set, t_i represents the actual target, and L_i and U_i are lower and upper bounds of hte ith PI, repestively. The range of PICP lies between 0% (wher none of hte targets are enclosed by PI) to 100% (when all targets are enclosed by PI). Ideally, PICP should be very close or larger than the norminal confidence level associated to the PIs. PICP has a direct relationship with the width of PIs. A satisfactorily large PICP can be easily achieved by widening PIs from either side. However, such PIs are too conservative and less useful in practice, as they do not show the variation of the targetes. Therefore, a measure is resquired to check how wide the PIs are. Mean PI Width (MPIW) quantifies this aspect of PIs [2].

$$MPIW = \frac{1}{N} \sum_{i=1}^{N} (U_i - L_i) \tag{3}$$

3

Secondrly, MPIW shows the average width of PIs. Normalizing MPIW by the range of the underlying target, R, allows us to compare PIs constructed for different datasets repectively (the new measure is called NMPIW),

$$NMPIW = \frac{NMPIW}{R} \qquad (4)$$

Both PICP and NMPIW, are representing quality and width of PIs, eval-
uate the quality of PIS from one aspect. A combined index is required for the comprehensive assessment of PIs from both coverage probility and width perspectives. The new measure should give a higher priority to PICP, as it is the key feature of PIs determining whether constructed PIs are theoretically correcty or not. The Coverage Width-baed Criterion (CWC) evalutes PIs from
both coverage probility and width perspectives.

Where, η and μ are two hyperparameters controlling the location and amount of CWC jump. These measures can be easily determined based on the level of confidence associated with PIs. μ correspomds to the nominal confidence level associated with PIs and can be set to 1-α. The design of CWC is based on two
principles:

- if PICP is less than the nominal confidence level, (1-α)%, CWC should be large regardless of the width of PIs (measures by NMIPW),

- if PICP is greater than or equal to its corresponding confidence level, then NMPIW should be the influential factor. γ(PICP), eliminates the exponential term of CWC when PICP is greater or equal to the nominal confidence level.

2.3. Data description

All data in this paper is provided in Global Energy Forecasting Competition 2014 (see [3]). The aim of this competition is to forecast 15 tasks of electric-
ity prices in term of probabilistic distribution (in quantiles). Hourly data of locational marginal price (LMP), zonal load forecast and system load forecast are provided. The participants receive historical data and forecast for next day

4

electricty price. In total, the price forecasting track involves about three years of locational marginal price, zonal and system load forecast. The summarized solution data set of 15 tasks is shown in table 1.

Table 1: GEFcom2014 task solution

Task	Day	Holiday	Season	Normal price	High price	Spike price
1	Sun	Yes	Summer	24	-	-
2	Mon	No	Summer	24	-	-
3	Mon	No	Summer	22	2	-
4	Thu	No	Summer	24	-	-
5	Tue	No	Summer	22	2	-
6	Sat	Yes	Summer	24	-	-
7	Tue	No	Summer	16	8	-
8	Thu	No	Summer	12	8	4
9	Fri	No	Summer	13	6	5
10	Sat	Yes	Summer	18	6	-
11	Wed	No	Summer	24	-	-
12	Thu	No	Summer	24	-	-
13	Sat	Yes	Authumn	24	-	-
14	Sun	Yes	Authumn	24	-	-
15	Tue	No	Authumn	15	9	-

Where, table 2 summarizes top four team's method. The participation teams in GEFCom2014 perform electricity price forecasting method i.e.; linear regression (IR)[4], multilayer perceptron (MLP)[4], multiple quantile regression[5], hybrid quantile estimation with pre-and-post process[6].

Table 2: Summary of the methods used by the top four teams of the price forecasting track.

Techniques

	Techniques	Spike preprocessing	Forecast combination
Tololo	(1) Quantile regression, generalized additive models; (2) autoregressive models, random forest regression, gradient boosting machine; (3) Kernel based quantile regression.	Preprocessed spikes for some of the models.	ML-Poly aggregation
Team Poland	Autoregressive models with exogenous variables; filtering; quantile regression; judgmental forecasting	Three filtering methods: day type filtering, similar load profile filtering and expected bias filtering	Arithmetic average
GMD	Feed forward neural network	None	None
C3 Green Team	Quantile regression; radial basis function network; k-means algorithm; alternating direction method of multipliers; Autoregressive models with exogenous variables	None	None

3. Proposed probabilisitic deep residual neural network

As mention eariler,

Figure 2: Upper and lower bound and mean and variance estimation

Figure 3: Proposed probabilistic deep residual network

4. Conclusions

This paper proposes a novel application of residual neural network based approach to probabilistic electricity price forecasting.

References

[1] R. Weron, Electricity price forecasting: A review of the state-of-the-art with a look into the future, International Journal of Forecasting 30 (4) (2014) 1030–1081. `doi:10.1016/J.IJFORECAST.2014.08.008`.
URL `https://www.sciencedirect.com/science/article/pii/S0169207014001083`

[2] A. Khosravi, S. Nahavandi, D. Creighton, Construction of optimal prediction intervals for load forecasting problems, IEEE Transactions on Power Systems 25 (3) (2010) 1496–1503. `doi:10.1109/TPWRS.2010.2042309`.

[3] T. Hong, P. Pinson, S. Fan, H. Zareipour, A. Troccoli, R. J. Hyndman, Probabilistic energy forecasting: Global Energy Forecasting Competition 2014 and beyond, International Journal of Forecasting 32 (3) (2016) 896–913. `doi:10.1016/j.ijforecast.2016.02.001`.
URL `http://dx.doi.org/10.1016/j.ijforecast.2016.02.001`

[4] G. Dudek, Multilayer perceptron for GEFCom2014 probabilistic electricity price forecasting, International Journal of Forecasting 32 (3) (2016) 1057–1060. `doi:10.1016/j.ijforecast.2015.11.009`.
URL `http://dx.doi.org/10.1016/j.ijforecast.2015.11.009`

[5] R. Juban, H. Ohlsson, M. Maasoumy, L. Poirier, J. Z. Kolter, A multiple quantile regression approach to the wind, solar, and price tracks of GEFCom2014, International Journal of Forecasting 32 (3) (2016) 1094–1102. `arXiv:arXiv:1807.07747v1`, `doi:10.1016/j.ijforecast.2015.12.002`.
URL `http://dx.doi.org/10.1016/j.ijforecast.2015.12.002`

[6] K. Maciejowska, J. Nowotarski, A hybrid model for GEFCom2014 probabilistic electricity price forecasting, International Journal of Forecasting 32 (3) (2016) 1051–1056. `doi:10.1016/j.ijforecast.2015.11.008`.
URL `http://dx.doi.org/10.1016/j.ijforecast.2015.11.008`