

From: AZPDES - AZDEQ azpdes@azdeq.gov 
Subject: Re: SWPPP Signage Requirements
Date: November 18, 2025 at 11:18 AM
To: Chi Ejimofor chi@desertservices.net

AA

Hi Chi.

There is no specific sizing on the actual sign, as each site would require a different size. The 2025 CGP states in permit part 6.7:

- a. The operator must post the NOI Authorization # in a conspicuous location near the main entrance of the construction site and retain a copy of the NOI in the SWPPP. For linear construction activities, the authorization number(s) must be posted near the entrance where most of the construction activity is occurring.
- b. The operator must post the following statement with the Authorization #: "For stormwater complaints, please visit www.azdeq.gov." Lettering must be 2" or greater.

I think what you are showing in your email is correct!
Thanks for reaching out!



Rosi Sherrill, CPSWQ
Environmental Scientist
Arizona Department of Environmental Quality

1110 W. Washington St., 6th fl.
Phoenix, AZ 85007

602-771-4409

On Tue, Nov 18, 2025 at 9:25 AM Chi Ejimofor <chi@desertservices.net> wrote:

Hello,

I was wondering if you had some documentation on the signage requirements for SWPPP Signs. In my system I have this as the required information on the sign:

[SWPPP SIGN – 24" x 24"]
STORMWATER POLLUTION PREVENTION
{Project Name}
{Company Name}
{NOI Authorization ID (AZC #)}
FOR STORMWATER COMPLAINTS,
PLEASE VISIT WWW.AZDEQ.GOV

Can you confirm this is correct?

Best,

—

Chi Ejimofor
Project Coordinator
E: chi@desertservices.net
M: (304) 216-8700

img-6624309e-0a57-4130-a2c9-
4f541ae56ee4

