

TABLE 5: DETAILED WATER USE BREAKDOWN FOR THE DEVELOPMENT

FILL IN DEVELOPMENT NAME AND CITY CASE NUMBER ON TAB 1

TO RIGHT:WATER USE ALLOCATION-->	A. TOTAL AVERAGE WATER USE (GPD)	B. AVERAGE OUTDOOR <u>CONSUMPTIVE</u> WATER USE ⁽¹⁾			C. AVERAGE INDOOR <u>TOTAL</u> WATER USE ⁽¹⁾			D. AVERAGE INDOOR <u>CONSUMPTIVE</u> WATER USE ⁽²⁾			E. AVERAGE WASTEWATER FLOWS TO SEWER ⁽³⁾		
BELOW: WATER USE DEVELOPMENT TYPE/CATEGORY		UNIT OUTDOOR <u>CONSUMPTIVE</u> WATER USE (GPD/UNIT)	OUTDOOR CONSUMPTIVE USE (GPD)	OUTDOOR CONSUMPTIVE USE (% OF TOTAL USE)	UNIT <u>TOTAL</u> INDOOR WATER USE (GPD/UNIT)	INDOOR <u>TOTAL</u> USE (GPD)	INDOOR <u>TOTAL</u> USE (% OF TOTAL USE)	UNIT <u>CONSUMPTIVE</u> INDOOR WATER USE (GPD/UNIT)	INDOOR <u>CONSUMPTIVE</u> USE (GPD)	INDOOR <u>CONSUMPTIVE</u> USE (% OF TOTAL USE)	WASTEWATER FLOW (GPD/UNIT)	WASTEWATER FLOW (GPD)	WASTEWATER (% OF TOTAL USE)
Category: Residential/ Commerical Residential/ Hotel													
< 2 DU/ac)	-	276.7	-	0.0%	208.9	-	0.0%	20.9	-	0.0%	188	-	0.0%
2 – 2.9 DU/ac	-	276.7	-	0.0%	193.7	-	0.0%	19.4	-	0.0%	174	-	0.0%
3 – 7.9 DU/ac	-	72.3	-	0.0%	175.9	-	0.0%	17.6	-	0.0%	158	-	0.0%
8 – 11.9 DU/ac	-	72.3	-	0.0%	155.3	-	0.0%	15.5	-	0.0%	140	-	0.0%
12 – 22 DU/ac	-	72.3	-	0.0%	155.3	-	0.0%	15.5	-	0.0%	140	-	0.0%
High Density Condominium (condo)	-	30.0	-	0.0%	155.3	-	0.0%	15.5	-	0.0%	140	-	0.0%
Resort Hotel	-	44.6	-	0.0%	401.7	-	0.0%	32.1	-	0.0%	370	-	0.0%
Category: Commerical/ Other													
Restaurant	-	0.10	-	0.0%	1.20	-	0.0%	0.12	-	0.0%	1.08	-	0.0%
Commercial/Retail	100,403	0.10	12,550	12.0%	0.70	87,852.8	84.3%	0.11	13,177.9	12.6%	0.60	74,675	71.6%
Commerical High Rise	-	0.10	-	0.0%	0.50	-	0.0%	0.05	-	0.0%	0.45	-	0.0%
Office	-	0.10	-	0.0%	0.50	-	0.0%	0.05	-	0.0%	0.45	-	0.0%
Institutional	-	670	-	0.0%	670.0	-	0.0%	100.50	-	0.0%	569.50	-	0.0%
Industrial	3,749	154	562	0.5%	873.0	3,186.5	3.1%	130.95	478.0	0.5%	742.05	2,708	2.6%
Research and Development	-	192	-	0.0%	1,092.0	-	0.0%	163.80	-	0.0%	928.20	-	0.0%
Category: Special Use Areas													
Natural Area Open Space	-	-	-	0.0%							-	-	0.0%
Developed Open Space - Parks	-	1,786	-	0.0%							-	-	0.0%
Developed Open Space- Golf Course	-	4,285	-	0.0%							-	-	0.0%
Category: Evaporation from Swimming Pools/Spas, Cooling, Turf Area Irrigation, Other Outdoor Consumptive Uses													
Extra large pool (60k to 100k gallons)	-	274	-	0.0%							-	-	0.0%
Large pool (above 30k to 60k gallons)	-	154	-	0.0%							-	-	0.0%
Medium pool (15k to 30k gallons)	-	75	-	0.0%							-	-	0.0%
Small pool or spa (under 15k gallons)	51	51	51	0.0%							-	-	0.0%
Total Bermuda Turf Area	-	0.10	-	0.0%							-	-	0.0%
Total Overseeded Turf Area	-	0.02	-	0.0%							-	-	0.0%
Evaporative Cooling/ Cooling Towers	-	-	-	0.0%							-	-	0.0%
Category: Filter Backwash Flows & Make-up Water from Pools & Spas (rapid sand filters)													
Extra large pool (60k to 100k gallons)	-				228.6	-	0.0%				229	-	0.0%
Large pool (above 30k to 60k gallons)	-				171.4	-	0.0%				171	-	0.0%
Medium pool (15k to 30k gallons)	-				114.3	-	0.0%				114	-	0.0%
Small pool or spa (under 15k gallons)	57				57.1	57.1	0.1%				57	57	0.1%
TOTALS	104,260		13,164	12.6%		91,096	87.4%		13,656	13.1%		77,441	74.3%

F. TOTAL CONSUMPTIVE/NET WATER USE FOR THIS DEVELOPMENT (B. + D.)	26,820 GPD	25.7% OF TOTAL USE
---	------------	--------------------

NOTES:
(1) PER 2018 DS&PM CHAPTER 6, FIGURE 6-1.2
(2) VARIES FROM 8% TO 15%, TYPICALLY 10%
(3) WASTEWATER FLOWS TO SEWER ARE CALCULATED AS C. MINUS D.
GPD=GALLONS PER DAY, DU=DWELLING UNIT, FT2=SQUARE FEET, AC=ACRE, EA=EACH UNIT
NONE OF THE VALUES OR CALCULATIONS HEREIN ARE INTENDED TO BE USED FOR INFRASTRUCTURE DESIGN, PEAK FLOW DETERMINATION, OR SYSTEM CAPACITY ANALYSIS. FOR THESE PURPOSES REFER TO CH.6 & 7 OF THE CITY'S DESIGN STANDARDS AND POLICY MANUAL FOR THE RESPECTIVE DESIGN VALUES AND PEAKING FACTORS.

TABLE INPUT VALUES LAST UPDATED:10/2/2025