

Assignment 3

Wind Farm Analysis Using FLORIS

Chinmay S Patil

1. Introduction

This assignment studies a small wind farm consisting of three **IEA 3.4 MW** wind turbines placed in a row with a rotor diameter of $D = 130$ m and a hub height of 120 m. The main goals are to define the turbine in FLORIS, validate its characteristics, visualize wake interactions, compute power output with different wake models, and compare the influence of turbine spacing and atmospheric conditions.

The notebook uses FLORIS together with the turbine data read from the provided CSV file. The turbine is modeled as a pitch-regulated machine with rated power 3370 kW, rated wind speed 9.8 m/s, cut-in wind speed 3 m/s, and cut-out wind speed 25 m/s.

2. Question 1: Define the turbine in FLORIS

The first step was to define the turbine and store it as a FLORIS turbine description. The CSV file was read, and the key rated parameters were used to build the turbine configuration.

Key parameters used

Parameter	Value
Name	IEA 3.4 MW Reference
Rated power	3370 kW
Rated wind speed	9.8 m/s
Cut-in wind speed	3 m/s
Cut-out wind speed	25 m/s
Rotor diameter	130 m
Hub height	120 m

Created Turbine named: IEA_3_4KW.yaml. Attached with the submission.

3. Question 2: Check the turbine characteristics

The turbine characteristics were checked by plotting the power curve, thrust coefficient curve, power coefficient curve, and the power variation with yaw angle in the range $[-30^\circ, 30^\circ]$. Two air densities were tested: 1.150 kg/m^3 and 1.225 kg/m^3 .

3.1 What was checked

- **Power curve:** turbine power as a function of wind speed.
- **Ct curve:** thrust coefficient behavior across the wind-speed range.
- **Cp curve:** power coefficient variation across the wind-speed range.
- **Yaw sensitivity:** power reduction when the rotor is intentionally misaligned with the wind.

3.2 Interpretation

The plots confirm the expected turbine behavior: power rises rapidly between cut-in and rated speed, then remains close to the rated power near the operating plateau. The lower air-density case produces slightly lower power because the available kinetic energy in the wind is reduced. The yaw study is symmetric around zero yaw error, and the maximum power occurs near 0° yaw.

3.3 Useful notebook output from the turbine table

The CSV data used to build the turbine included the following power values at the beginning of the curve:

No	Wind Speed [m/s]	Power [kW]	Cp [-]	Thrust [kN]	Ct [-]
0	3.0000	51.620327	0.2368	59.159022	0.8140
1	3.5392	123.368159	0.3446	81.337534	0.8042
2	4.0485	213.241509	0.3980	105.641598	0.7982
3	4.5267	318.837998	0.4257	131.466695	0.7945
4	4.9730	435.956487	0.4390	158.022534	0.7913




Figure 1: Turbine characteristic plots for power, C_p , and C_t (from FLORIS and not from CSV).

3.4 Comment on the curve trend

The power values increase smoothly with wind speed until rated power is reached. This matches the expected control behavior of a pitch-regulated turbine. The C_t and C_p curves also follow the standard FLORIS turbine response.




Figure 2: Power variation with yaw error in the range $[-30^\circ, 30^\circ]$.

4. Question 3: Visualize the wind farm flow field

The three-turbine farm was arranged in a straight line with turbine spacing of 5D. The flow field was visualized in three planes:

- horizontal plane at hub height,
- streamwise plane,
- spanwise plane.

The notebook created these views for two wind directions. In the notebook's coordinate setup, the aligned and wake-interaction cases were evaluated using 0° and 270° .

4.1 Flow-field figures

4.2 Interpretation

The upstream turbine produces a wake deficit that is visible in the downstream flow field. In the aligned case, the wakes are narrow and clearly aligned with the turbine row. In the more oblique case, the wake footprint shifts across the farm, changing which downstream turbine is most affected. The spanwise and streamwise cuts help show wake expansion and velocity recovery away from the rotor plane.

5. Question 4: Jensen wake model power calculation

For the Jensen wake model with $k_w = 0.075$, the turbine and farm power were computed at 7.5 m/s for the two wind directions used in the notebook. The results were then compared with the hand calculations from Assignment 2.




Figure 3: Horizontal, streamwise, and cross-plane flow visualization for the 0° case.

5.1 Aligned / no-wake case

Absolute Power [kW]		
Floris	Hand Calculations	Error
T1: 1505.9	T1: 1515.2	T1: 0.610%
T2: 1505.9	T2: 1515.2	T2: 0.610%
T3: 1505.9	T3: 1515.2	T3: 0.610%
Farm: 4517.7	Farm: 4545.5	Farm: 0.610%




Figure 4: Horizontal, streamwise, and cross-plane flow visualization for the 270° case.

5.2 Wake case

Absolute Power [kW]		
Floris	Hand Calculations	Error
T1: 1505.9	T1: 1515.2	T1: 0.610%
T2: 866.6	T2: 872.4	T2: 0.665%
T3: 807.3	T3: 812.4	T3: 0.630%
Farm: 3179.8	Farm: 3199.9	Farm: 0.630%

5.3 Discussion

The FLORIS results are very close to the hand-calculated values from Assignment 2. The relative errors stay below 1%, which is a strong indication that the model setup is consistent. A likely source of the small difference is that FLORIS uses numerical wake interaction and interpolated turbine characteristics, while the hand calculation is based on simplified analytical assumptions.

6. Question 5: Effect of increasing the spacing from 5D to 10D

The same Jensen wake setup was repeated for the aligned case and for the wake case, with turbine spacing increased from 5D to 10D.

6.1 Aligned case

Difference between 5D and 10D		
5D	10D	Relative Difference wrt 5D
T1: 1505.9	T1: 1505.9	T1: 0.000%
T2: 1505.9	T2: 1505.9	T2: 0.000%
T3: 1505.9	T3: 1505.9	T3: 0.000%
Farm: 4517.7	Farm: 4517.7	Farm: 0.000%

6.2 Wake case

Difference between 5D and 10D		
5D	10D	Relative Difference wrt 5D
T1: 1505.9	T1: 1505.9	T1: 0.000%
T2: 866.6	T2: 1163.2	T2: 34.235%
T3: 807.3	T3: 1140.5	T3: 41.272%
Farm: 3179.8	Farm: 3809.6	Farm: 19.808%

6.3 Discussion

Increasing the spacing from 5D to 10D gives the wake more distance to recover before reaching the next turbine. As a result, downstream turbines experience a higher inflow velocity and therefore generate more power. The farm power rises noticeably in the wake case, which is exactly the expected physical trend.

7. Question 6: Day and night conditions with Gaussian wake model

The Gaussian wake model was used to study how atmospheric stability changes affect power generation. Two conditions were tested:

- **Day:** wind shear exponent 0.06, turbulence intensity 12%.
- **Night:** wind shear exponent 0.22, turbulence intensity 6%.

7.1 5D spacing, wind direction 0°

Day	Night	Increase/Decrease in Power
T1: 1509.5	T1: 1506.7	T1: -0.186%
T2: 1509.5	T2: 1506.7	T2: -0.186%
T3: 1509.5	T3: 1506.7	T3: -0.186%

7.2 5D spacing, wake-aligned case

Day	Night	Increase/Decrease in Power
T1: 1509.5	T1: 1506.7	T1: -0.186%
T2: 725.0	T2: 396.6	T2: -82.824%
T3: 760.6	T3: 464.8	T3: -63.659%

As observed above, the wake of Turbine T1 causes a significant drop in produced turbine power in Turbine T2. The lower turbine power produced by T2 due to wake from T1 causes lower wake of T2 on T3, the wake from T1 is also reduced due to the distance as well as interference from T2. This sees an increase in turbine power of T3 when compared to T2.

7.3 20D spacing, wake-aligned case

Day	Night	Increase/Decrease in Power
T1: 1509.5	T1: 1506.7	T1: -0.186%
T2: 1366.1	T2: 1172.9	T2: -16.465%
T3: 1360.1	T3: 1155.5	T3: -17.707%

As the inter-turbine distance is increased to 20*Rotor Diameter, the dip of turbine power of T2 is seen to be gone.

7.4 Discussion

The day case has higher turbulence intensity, which promotes faster wake mixing and faster recovery of downstream flow. The night case has lower turbulence intensity, so the wakes remain stronger for longer and the downstream turbines lose more power. The higher wind shear at night also changes the vertical inflow profile, which can further modify the wake structure. In the 10D layout, the wakes have more space to recover, so the downstream turbines perform much better than in the 5D case.

7.5 Flow-field interpretation

The visualizations for day and night show the same overall wake pattern, but the wake deficit is stronger and persists farther downstream at night. This is consistent with lower turbulence intensity and reduced wake diffusion. During the day, enhanced mixing helps the wake recover sooner, so the velocity deficit behind each turbine becomes smaller.

8. Conclusion

This assignment showed how to define a custom wind turbine in FLORIS, validate its performance curves, visualize flow fields, and compare wake-model predictions for different spacings and atmospheric conditions. The main conclusions are:

- the turbine curve setup is consistent with the provided IEA 3.4 MW data,

- FLORIS results match the hand calculations closely,
- larger turbine spacing reduces wake losses,
- higher turbulence intensity improves wake recovery and raises downstream power production.