

PROJECT NAME ACB Windsor - Clinical Suites: Valve Schedule					PROJECT NO. 21-515
CONTRACT DESCRIPTION Contract No.: 1 Contract Name: DSP - Clean Utilities (CU)	REVISION DESCRIPTION Revision No.: Revision Title:	1 Issued For RFP Package			LAST UPDATED (DATE / BY) 2027-02-26 MH

Valve Schedule									
TAG NO.	PID	PID NO.	DESCRIPTION	TYPE	SERVICE / SYSTEM	Pipe Type	PRODUCT MOC	Pressure Rating	CXN SIZE
W34-103	W34	W34 - Clean Air Distribution 1	Ball Valve	Component	Clean Air	Type Ps	316L Stainless-Steel, ASME BPE Comliant (Ps Spec)	100 PSIG @ 300 F	3/4"
W34-104	W34	W34 - Clean Air Distribution 1	Ball Valve	Component	Clean Air	Type Ps	316L Stainless-Steel, ASME BPE Comliant (Ps Spec)	100 PSIG @ 300 F	1"
W34-105	W34	W34 - Clean Air Distribution 1	Ball Valve	Component	Clean Air	Type Ps	316L Stainless-Steel, ASME BPE Comliant (Ps Spec)	100 PSIG @ 300 F	1/2"
W34-107	W34	W34 - Clean Air Distribution 1	Ball Valve	Component	Clean Air	Type Ps	316L Stainless-Steel, ASME BPE Comliant (Ps Spec)	100 PSIG @ 300 F	1/2"
W34-108	W34	W34 - Clean Air Distribution 1	Ball Valve	Component	Clean Air	Type Ps	316L Stainless-Steel, ASME BPE Comliant (Ps Spec)	100 PSIG @ 300 F	1/2"
W34-109	W34	W34 - Clean Air Distribution 1	Ball Valve	Component	Clean Air	Type Ps	316L Stainless-Steel, ASME BPE Comliant (Ps Spec)	100 PSIG @ 300 F	1/2"
W69-20	W69	W69 - Oxygen Storage and Dist	Ball Valve	Component	Oxygen	Type Ps	316L Stainless-Steel, ASME BPE Comliant (Ps Spec)	100 PSIG @ 300 F	3/4"
W69-21	W69	W69 - Oxygen Storage and Dist	Ball Valve	Component	Oxygen	Type Ps	316L Stainless-Steel, ASME BPE Comliant (Ps Spec)	100 PSIG @ 300 F	1"
W69-23	W69	W69 - Oxygen Storage and Dist	Ball Valve	Component	Oxygen	Type Ps	316L Stainless-Steel, ASME BPE Comliant (Ps Spec)	100 PSIG @ 300 F	1/2"
W34-102	W34	W34 - Clean Air Distribution 1	Ball Valve	Component	Clean Air	Type Ps	316L Stainless-Steel, ASME BPE Comliant (Ps Spec)	100 PSIG @ 300 F	1-1/2"
W34-106	W34	W34 - Clean Air Distribution 1	Ball Valve	Component	Clean Air	Type Ps	316L Stainless-Steel, ASME BPE Comliant (Ps Spec)	100 PSIG @ 300 F	1-1/2"
HV-W7U101	W7U	W7U - Fermentation Transfer Lines / Centrifuge Tie-ins	Diaphragm Valve	Component	Process Piping	Type Ps	316L Stainless-Steel, ASME BPE Comliant (Ps Spec)	100 PSIG @ 300 F	1"
W69-22	W69	W69 - Oxygen Storage and Dist	Ball Valve	Component	Oxygen	Type Ps	316L Stainless-Steel, ASME BPE Comliant (Ps Spec)	100 PSIG @ 300 F	2"

- Notes:
- 1. Pressure ratings are obtained from the piping spec document, referencing the MAWP of the piping spec: Type Ps
 - 2. All valves in the schedule must have an internal surface that aligns with ASME BPE code.
 - 3. All valves that service steam must come with CRN for NS
 - 4. Other components, such as pressure gauge PI-W7U102 is not included as this is a schedule for valves only.