

GENERAL SPECIFICATION G2.12

Electrical and Water Supply

CONTENTS

G2.12 Electrical and Water Supply1

 G2.12.1 Temporary Electrical Supply1

 G2.12.2 Water for the Works1

G2.12 ELECTRICAL AND WATER SUPPLY

G2.12.1 Temporary Electrical Supply

- (a) The Contractor shall provide for all necessary temporary lighting and electrical power required for the Works, including that for Suppliers and Specialist sub-contractors with all temporary wiring and meters, alter, adapt and maintain as necessary and pay all charges in connection therewith.
- (b) All supplies shall be controlled by a current-operated Earth Leakage Circuit Breaker (E.L.C.B.) of sensitivity not greater than 25/30 milliamperes.
- (c) The temporary electrical supply shall comply with Public Utilities (Electricity) Regulations in the Public Utilities Act. Particular attention is also drawn to Regulation 16(1) to (8) which covers portable apparatus.
- (d) The Contractor shall apply to the Power Grid or other approved power supplier for temporary construction power supply.
- (e) The Contractor/Sub-Contractor shall comply with the Code of Practice for Temporary Electrical Installations for Construction and Building Sites, SS: CP88.
- (f) The Contractor/Sub-Contractor shall obtain a license from Power Grid before any temporary electrical installations on site, irrespective of the approved load, may be used or operated.
- (g) The licensed electrical worker in charge shall carry out monthly inspections of all temporary electrical installations on site. A Certificate of Fitness shall be issued by the licensed electrical worker to the licence holder after every inspection.
- (h) Contractor shall include in his sums for complying with all the foregoing requirements of this Clause.
- (i) Where portable electrical generators are used, the Contractor shall carry out adequate soundproofing of the equipment before they are brought to site and comply with requirements of General Specifications for Environmental Considerations and Protection.

G2.12.2 Water for the Works

- (a) The Contractor shall provide at his own risk and cost, all water required for use in the Works including that for Suppliers and Specialist sub-contractors and shall make all arrangements with local authorities and pay all costs and fees in connection therewith. He will also provide all temporary water tubings, valves, pumps and storage tanks necessary for the proper execution of the Works, alter, adapt and maintain them as necessary and clear away all upon completion.
- (b) The Contractor shall allow, if deemed necessary, provision for on-site facilities for holding a reserve of one day's storage of water at all time, including possible instances when water rationing measure are in force in Singapore.

END OF SECTION