




ICA F/O CABLE DUCTS

6 NOS OF 110mm DIA PVC
ENCASED IN CONCRETE DUCT.
CONCRETE DUCT DIMENSION: 630x470
MIN. DEPTH FROM GROUND LEVEL TO TOP OF CABLE DUCT: 800
ICA F/O CABLE DUCT IS APPLICABLE TO CABLE DUCT WITH TAG 'JDUCT' IN BIM MODEL

- NOTES:
1. ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE STATED.
 2. THE CONTRACTOR SHALL VERIFY ICA CABLE DUCTS DIMENSIONS AND ARRANGEMENT AND DESIGN WITH THE INTERFACING CONTRACTOR.
 3. THIS DRAWING IS NOT DRAWN TO SCALE.

TENDER

T1	20/05/22	ISSUED FOR TENDER C4B	JL	GOT
REV	DATE	DESCRIPTION	REVIEWED	AUTHORISED

CLIENT:



SINGAPORE'S
NATIONAL
WATER AGENCY

PROGRAMME MANAGER:



A JOINT VENTURE DELIVERING THE DTSS2 PROJECT

CONSULTANT:



CH2M HILL Singapore Pte Ltd

PROJECT TITLE:

TUAS WATER RECLAMATION PLANT (TWRP)
DTSS PHASE 2

DRAWING TITLE

ICA F/O CABLE DUCTS

DRAFTED: PA	DESIGNED: SK	SHEET SIZE: A1
DRAFTING CHECK: RS	DESIGN CHECK: AT	SCALE: NTS
DATE: 20/05/22	REVIEWED: JL	PBS: 131101
CONTRACT: C4B	DRAWING NUMBER: PUB-DTSS2-TWRP	
	SHEET NUMBER: WSW00-I-5811	REVISION: T1

THIS DRAWING IS COPYRIGHT