

TAGGING CONVENTION

PROCESS

PIPES

WAAMF-PPP-CCCC-LLLLLS-BBBB-MMMMM

WHERE:	
WAAMF	REPRESENTS THE PROJECT PREFIX
PPP	THREE NUMERIC DIGITS DENOTING THE PROCESS UNIT
CCCC	UP TO FOUR ALPHA CHARACTER IDENTIFYING THE FLUID BEING CONVEYED
LLLL	FIVE NUMERIC DIGITS ASSIGNED TO PIPE: - THE FIRST DIGIT IS USED TO DENOTE THE SUB-SYSTEM; - THE SECOND AND THIRD DIGITS FOR THE PARALLEL STREAM (TRAIN); - THE SUBSEQUENT TWO DIGITS ARE SEQUENTIAL.
S	ONE ALPHA CHARACTER USED WHEN THERE ARE MULTIPLE PARALLEL PIPES OR CHANNELS
BBBB	DIAMETER OF PIPE IN MILLIMETERS
MMMM	UP TO FIFE ALPHA CHARACTER INDICATING THE MATERIAL OF THE PIPE

EQUIPMENT AND VALVES

WAAMF-PPP-DDDDDD-LLLLLS

WHERE:	
WAAMF	REPRESENTS THE PROJECT PREFIX
PPP	THREE NUMERIC DIGITS DENOTING THE UNIT PROCESS
DDDDD	UP TO THREE ALPHA CHARACTER IDENTIFYING THE EQUIPMENT OR VALVE
LLLL	FOUR NUMERIC DIGITS ASSIGNED TO FUNCTIONALLY RELATED DEVICES: - THE FIRST TWO DIGITS ARE USED TO DENOTE THE PARALLEL STREAM (TRAIN); - THE SUBSEQUENT TWO DIGITS ARE SEQUENTIAL FOR EACH TYPE OF DEVICE
S	ONE ALPHA CHARACTER USED WHEN THERE ARE MULTIPLE UNIT WITH THE SAME LOOP NUMBER

INSTRUMENTS

WAAMF-PPP-DDDDDD-LLLLLS

WHERE:	
WAAMF	REPRESENTS THE PROJECT PREFIX
PPP	THREE NUMERIC DIGITS DENOTING THE UNIT PROCESS
DDDDD	UP TO THREE ALPHA CHARACTER IDENTIFYING THE INSTRUMENT
LLLL	FOUR NUMERIC DIGITS ASSIGNED TO FUNCTIONALLY RELATED DEVICES: - THE FIRST TWO DIGITS ARE USED TO DENOTE THE PARALLEL STREAM (TRAIN); - THE SUBSEQUENT TWO DIGITS ARE SEQUENTIAL FOR EACH TYPE OF DEVICE
S	ONE ALPHA CHARACTER USED WHEN THERE ARE MULTIPLE UNIT WITH THE SAME LOOP NUMBER

ELECTRICAL LOCAL CONTROL STATIONS

WAAMF-PPP-LCS-DDDDDD-LLLLLS

WHERE:	
WAAMF	REPRESENTS THE PROJECT PREFIX
PPP	THREE NUMERIC DIGITS DENOTING THE UNIT PROCESS
LCS	LOCAL CONTROL STATION
DDDDD-LLLLS	REPRESENTS THE EQUIPMENT TAG

EXAMPLE:

FULL TAG

WSD02-113-GB-0101-250-SS1

DIGESTER 1, BIOGAS NB250 STAINLESS STEEL PN10

P&ID TAG

GB-SS1

EXAMPLE:

FULL TAG

WDL11-022-SCR-0101

FINE SCREEN 1 (DOMESTIC LIQUID MODULE 1)

EXAMPLE:

P&ID TAG

SCN-0101

EXAMPLE:

FULL TAG

WSD02-113-PSL-0101

DIGESTER 1 BIOGAS PRESSURE SWITCH LOW

P&ID TAG

PSL-0101

EXAMPLE:

FULL TAG

WSD02-113-LCS-P-1001A

LCS DIGESTER 10 RECIRCULATION PUMP A

P&ID TAG

LCS-P-1001A

NON-PROCESS

EQUIPMENT AND VALVES

WAAMF-DDDDDD-LLLLLS

WHERE:	
WAAMF	REPRESENTS THE PROJECT PREFIX
DDDDD	UP TO THREE ALPHA CHARACTER IDENTIFYING THE EQUIPMENT OR VALVE
LLLL	SEQUENTIAL EQUIPMENT NUMBERS. WHERE: - THE FIRST DIGIT IS USED TO DENOTE THE SUB-SYSYEM; - THE SECOND DIGIT FOR THE PARALLEL STREAM (TRAIN); - THE SUBSEQUENT TWO DIGITS ARE SEQUENTIAL FOR EACH TYPE OF DEVICE
S	ONE ALPHA CHARACTER USED WHEN THERE ARE MULTIPLE IDENTICAL UNIT WITH THE SAME EQUIPMENT NUMBER

ELECTRICAL LOCAL CONTROL STATIONS

WAAMF-LCS-DDDDDD-LLLLLS

WHERE:	
WAAMF	REPRESENTS THE PROJECT PREFIX
LCS	LOCAL CONTROL STATION
DDDDD-LLLLS	REPRESENTS THE EQUIPMENT TAG

EXAMPLE:

FULL TAG

WDL11-AHU-0101

AIR HANDLING UNIT (DOMESTIC LIQUID MODULE 1 HEADWORKS)

P&ID TAG

AHU-0101

EXAMPLE:

FULL TAG

WSD02-LCS-P-1001A

LCS 10 RECIRCULATION PUMP A

P&ID TAG

LCS-P-1001A

TENDER

T1	20/05/22	ISSUED FOR TENDER C4B	CN	GOT
T1	02/07/21	ISSUED FOR TENDER C3D2	CN	GOT
T1	18/12/20	ISSUED FOR TENDER C3B1	CN	GOT
T1	23/07/20	ISSUED FOR TENDER C2B	CN	GOT
T1	24/04/20	ISSUED FOR TENDER C3A	CN	GOT
T1	08/04/20	ISSUED FOR TENDER C3D1	CN	GOT
REV	DATE	DESCRIPTION	REVIEWED / AUTHORISED	

CLIENT:



PROGRAMME MANAGER:



CONSULTANT:



PROJECT TITLE:

TUAS WATER RECLAMATION PLANT (TWRP)
DTSS PHASE 2

DRAWING TITLE

P&ID LEGEND
TAGGING CONVENTION

DRAFTED: MW	DESIGNED: CSY	SHEET SIZE: A1
DRAFTING CHECK: DW	DESIGN CHECK: JL	SCALE: NTS
DATE: 08/11/17	REVIEWED: CN	PBS: 131101
CONTRACT: -	DRAWING NUMBER: PUB-DTSS2-TWRP	
	SHEET NUMBER: WSW00-P-0002	REVISION: T1

THIS DRAWING IS COPYRIGHT