

MAX 75mmx100mm
OPENING AS
REQD FOR
CONDUITS

13mm
RADIUS, TYP


13mmx250mmx250mm
AL PLATE

PLAN

32mm
TYP

32mm
TYP

6mm AL PLATE
SIZE AS REQUIRED
ROUND EDGES



OVERSIZED DEVICE

CONTROL STATION
OR OTHER DEVICE

FILE OFF
SHARP EDGES

MIN AL C150mmx75mm

900mm MIN / 1200mm MAX,
SEE NOTE 2

13 DIA STAINLESS STEEL CONCRETE
ANCHORS OR ANCHOR BOLTS WITH
LEVELING NUTS

PROVIDE COATING BETWEEN
ALUMINUM AND CONCRETE
AS SPECIFIED

NON-SHRINK GROUT

FINISH FLOOR
OR PLATFORM

ELEVATION

NOTES:

1. ALL DIMENSIONS IN MILLIMETERS, UNLESS OTHERWISE NOTED.
2. ALL MOUNTING HARDWARE SHALL BE STAINLESS STEEL. USE WASHERS AND SPLIT-LOCK WASHERS UNDER ALL NUTS AND BOLTS.
3. FOR HEIGHTS EXCEEDING 1200mm OR WEIGHTS OF MOUNTED EQUIPMENT EXCEEDING 90kg, SIZE POST AND CONNECTION FOR LATERAL LOADS. EXTEND POSTS TO STRUCTURE ABOVE WHERE REQUIRED BY CALCULATION.

PEDESTAL MOUNTED DEVICE

NTS

16165B

STANDARD DETAIL

JACOBS