

EARTHING CONDUCTOR
SIZE AS REQUIRED

CONDUIT DROP

INSULATING EARTHING
BUSHING WITH INSULATED
THROAT, SIZE AS REQUIRED

CABLE TRAY
CLAMP

PARALLEL CLAMP
SIZE AS REQUIRED

CABLE TRAY

BARE COPPER STRANDED
GROUND CONDUCTOR
AS REQUIRED

NOTES :

- 1: ALL DIMENSIONS IN MILLIMETERS,
UNLESS OTHERWISE NOTED.
2. FASTENING HARDWARE IN TRAY SHALL BE ROUNDED
AND HAVE NO SHARP CORNERS.

CONDUIT DROP INTO CABLE TRAY

NTS

STANDARD DETAIL

16192

JACOBS