

MOUNT TRANSMITTER/  
INDICATOR ABOVE  
ELEMENT CONNECTION

1/2" SST BLEED VALVE  
AND TEST TAP, TYP

1/2" SST TUBING, TYP

ACROSS FLOW ELEMENT/  
VALVE/DAMPER AS PER  
APPLICATION

3-VALVE  
EQUALIZATION  
MANIFOLD

TO PURGE STATION  
WHERE REQUIRED

FLOW

NOTES:

1. FOR GAS SERVICE, SLOPE ALL LINES UPWARD TOWARD INSTRUMENT.

## PRESSURE DIFFERENTIAL TRANSMITTER/INDICATOR FOR GAS INSTALLATION

NTS

STANDARD DETAIL

13208

**JACOBS**