

ODOUROUS AIR
PIPING

6
(@ SST PIPING)

100mm 316L SST
DRIPLEG (@ SST PIPING)
100mm FRP DRIPLEG
(@ FRP DUCT)

25mm PVC DRAIN LINE
(UNLESS OTHERWISE
INDICATED ON PLANS)

FLOOR OR
OPERATING DECK

S.S. X PVC FLANGE
CONNECTION
(@ S.S. PIPING)
FRP X PVC FLANGE
CONNECTION
(@ FRP DUCT)

THREADED CAP
FOR PRIMING

LENGTH AS
REQUIRED

THREADED CAP
DURING
PRESSURE TEST

150
MAX

TO NEARBY HUB
DRAIN OR TRENCH
DRAIN

NOTES :

1: ALL DIMENSIONS IN MILLIMETERS,
UNLESS OTHERWISE NOTED.

ODOUROUS AIR VENT GAS TRAP AND DRAIN

NTS

STANDARD DETAIL

15898

JACOBS