



Corrected to

OAK CLIFF or NINTH WARD DALLAS, TEXAS

Situated Three Miles S.W. of Dallas Post Office.

WATER FACILITIES. Water supply from two artesian wells and one surface well. Two stand pipes 15" x 30 ft. capacity 100,000 gals. each. One Smith valve compound duplex pump capacity one million gals. per 24 hours. 54 Miles of water pipes, 7" to 8" diam. Domestic pressure 40 lbs. in business section. For report of fire department, see volume one of Dallas, Tex.

KEY

- Fire proof construction
- Iron building
- Brick building with metal cornice
- Frame
- Side
- Stone front
- Brick special
- with frame side
- Frame building, not a special
- iron clad
- special
- Wall 12" no openings through it
- with openings
- Fire wall 6 inches above roof
- at
- 20
- Opening in divider wall
- with iron door
- Standard iron door
- Windows with iron shutters
- Window opening in 1st story
- Windows
- Stable
- Horizontal steam boiler
- Vertical
- Chimney
- Hydrant
- Fire alarm bell
- Automatic
- Independent electric plant
- Automatic fire alarm

127
Reference to adjoining sheet

