



Choupo

The Open Source Chemical Process Simulator

EduTools Guide

Choupo-dev

Copyright © 2026 Vítor Geraldês.

Authors: Vítor Geraldês.

This work is licensed under a Creative Commons Attribution-ShareAlike 4.0 International License.

Code examples, Choupo case files, and other machine-readable examples are licensed under GPL-3.0-or-later.

Typeset in L^AT_EX.

Acknowledgment. Choupo was conceived and architected by Vítor Geraldês. Substantial parts of the initial implementation, documentation, and tutorial corpus were produced with assistance from Anthropic Claude Code using Claude Opus/Fable models. This guide is published under human curation, review, and editorial responsibility by Vítor Geraldês.

License

Attribution-ShareAlike 4.0 International

Creative Commons Corporation ("Creative Commons") is not a law firm and does not provide legal services or legal advice. Distribution of Creative Commons public licenses does not create a lawyer-client or other relationship. Creative Commons makes its licenses and related information available on an "as-is" basis. Creative Commons gives no warranties regarding its licenses, any material licensed under their terms and conditions, or any related information. Creative Commons disclaims all liability for damages resulting from their use to the fullest extent possible.

Using Creative Commons Public Licenses

Creative Commons public licenses provide a standard set of terms and conditions that creators and other rights holders may use to share original works of authorship and other material subject to copyright and certain other rights specified in the public license below. The following considerations are for informational purposes only, are not exhaustive, and do not form part of our licenses.

Considerations for licensors: Our public licenses are intended for use by those authorized to give the public permission to use material in ways otherwise restricted by copyright and certain other rights. Our licenses are irrevocable. Licensors should read and understand the terms and conditions of the license they choose before applying it. Licensors should also secure all rights necessary before applying our licenses so that the public can reuse the material as expected. Licensors should clearly mark any material not subject to the license. This includes other CC-licensed material, or material used under an exception or limitation to copyright. More considerations for licensors: wiki.creativecommons.org/Considerations_for_licensors

Considerations for the public: By using one of our public licenses, a licensor grants the public permission to use the licensed material under specified terms and conditions. If the licensor's permission is not necessary for any reason--for example, because of any applicable exception or limitation to copyright--then that use is not regulated by the license. Our licenses grant only permissions under copyright and certain other rights that a licensor has authority to grant. Use of the licensed material may still be restricted for other reasons, including because others have copyright or other rights in the material. A licensor may make special requests, such as asking that all changes be marked or described. Although not required by our licenses, you are encouraged to respect those requests where reasonable. More considerations for the public: wiki.creativecommons.org/Considerations_for_licensees

Creative Commons Attribution-ShareAlike 4.0 International Public License

By exercising the Licensed Rights (defined below), You accept and agree to be bound by the terms and conditions of this Creative Commons Attribution-ShareAlike 4.0 International Public License ("Public License"). To the extent this Public License may be interpreted as a contract, You are granted the Licensed Rights in consideration of Your acceptance of these terms and conditions, and the Licensor grants You such rights in consideration of benefits the Licensor receives from making the Licensed Material available under these terms and conditions.

Section 1 -- Definitions.

- a. Adapted Material means material subject to Copyright and Similar Rights that is derived from or based upon the Licensed Material and in which the Licensed Material is translated, altered, arranged, transformed, or otherwise modified in a manner requiring permission under the Copyright and Similar Rights held by the Licensor. For purposes of this Public License, where the Licensed Material is a musical work, performance, or sound recording, Adapted Material is always produced where the Licensed Material is synched in timed relation with a moving image.
- b. Adapter's License means the license You apply to Your Copyright and Similar Rights in Your contributions to Adapted Material in accordance with the terms and conditions of this Public License.
- c. BY-SA Compatible License means a license listed at creativecommons.org/compatiblelicenses, approved by Creative Commons as essentially the equivalent of this Public License.
- d. Copyright and Similar Rights means copyright and/or similar rights closely related to copyright including, without limitation, performance, broadcast, sound recording, and Sui Generis Database Rights, without regard to how the rights are labeled or categorized. For purposes of this Public License, the rights specified in Section 2(b)(1)-(2) are not Copyright and Similar

Rights.

- e. Effective Technological Measures means those measures that, in the absence of proper authority, may not be circumvented under laws fulfilling obligations under Article 11 of the WIPO Copyright Treaty adopted on December 20, 1996, and/or similar international agreements.
- f. Exceptions and Limitations means fair use, fair dealing, and/or any other exception or limitation to Copyright and Similar Rights that applies to Your use of the Licensed Material.
- g. License Elements means the license attributes listed in the name of a Creative Commons Public License. The License Elements of this Public License are Attribution and ShareAlike.
- h. Licensed Material means the artistic or literary work, database, or other material to which the Licensor applied this Public License.
- i. Licensed Rights means the rights granted to You subject to the terms and conditions of this Public License, which are limited to all Copyright and Similar Rights that apply to Your use of the Licensed Material and that the Licensor has authority to license.
- j. Licensor means the individual(s) or entity(ies) granting rights under this Public License.
- k. Share means to provide material to the public by any means or process that requires permission under the Licensed Rights, such as reproduction, public display, public performance, distribution, dissemination, communication, or importation, and to make material available to the public including in ways that members of the public may access the material from a place and at a time individually chosen by them.
- l. Sui Generis Database Rights means rights other than copyright resulting from Directive 96/9/EC of the European Parliament and of the Council of 11 March 1996 on the legal protection of databases, as amended and/or succeeded, as well as other essentially equivalent rights anywhere in the world.
- m. You means the individual or entity exercising the Licensed Rights under this Public License. Your has a corresponding meaning.

Section 2 -- Scope.

- a. License grant.
 - 1. Subject to the terms and conditions of this Public License, the Licensor hereby grants You a worldwide, royalty-free, non-sublicensable, non-exclusive, irrevocable license to exercise the Licensed Rights in the Licensed Material to:
 - a. reproduce and Share the Licensed Material, in whole or in part; and
 - b. produce, reproduce, and Share Adapted Material.
 - 2. Exceptions and Limitations. For the avoidance of doubt, where Exceptions and Limitations apply to Your use, this Public License does not apply, and You do not need to comply with its terms and conditions.
 - 3. Term. The term of this Public License is specified in Section 6(a).
 - 4. Media and formats; technical modifications allowed. The Licensor authorizes You to exercise the Licensed Rights in all media and formats whether now known or hereafter created, and to make technical modifications necessary to do so. The Licensor waives and/or agrees not to assert any right or authority to forbid You from making technical modifications necessary to exercise the Licensed Rights, including technical modifications necessary to circumvent Effective Technological Measures. For purposes of this Public License, simply making modifications authorized by this Section 2(a) (4) never produces Adapted Material.
 - 5. Downstream recipients.
 - a. Offer from the Licensor -- Licensed Material. Every recipient of the Licensed Material automatically receives an offer from the Licensor to exercise the Licensed Rights under the terms and conditions of this Public License.
 - b. Additional offer from the Licensor -- Adapted Material. Every recipient of Adapted Material from You automatically receives an offer from the Licensor to exercise the Licensed Rights in the Adapted Material under the conditions of the Adapter's License You apply.
 - c. No downstream restrictions. You may not offer or impose any additional or different terms or conditions on, or apply any Effective Technological Measures to, the Licensed Material if doing so restricts exercise of the Licensed Rights by any recipient of the Licensed Material.

6. No endorsement. Nothing in this Public License constitutes or may be construed as permission to assert or imply that You are, or that Your use of the Licensed Material is, connected with, or sponsored, endorsed, or granted official status by, the Licensor or others designated to receive attribution as provided in Section 3(a)(1)(A)(i).

b. Other rights.

1. Moral rights, such as the right of integrity, are not licensed under this Public License, nor are publicity, privacy, and/or other similar personality rights; however, to the extent possible, the Licensor waives and/or agrees not to assert any such rights held by the Licensor to the limited extent necessary to allow You to exercise the Licensed Rights, but not otherwise.
2. Patent and trademark rights are not licensed under this Public License.
3. To the extent possible, the Licensor waives any right to collect royalties from You for the exercise of the Licensed Rights, whether directly or through a collecting society under any voluntary or waivable statutory or compulsory licensing scheme. In all other cases the Licensor expressly reserves any right to collect such royalties.

Section 3 -- License Conditions.

Your exercise of the Licensed Rights is expressly made subject to the following conditions.

a. Attribution.

1. If You Share the Licensed Material (including in modified form), You must:
 - a. retain the following if it is supplied by the Licensor with the Licensed Material:
 - i. identification of the creator(s) of the Licensed Material and any others designated to receive attribution, in any reasonable manner requested by the Licensor (including by pseudonym if designated);
 - ii. a copyright notice;
 - iii. a notice that refers to this Public License;
 - iv. a notice that refers to the disclaimer of warranties;
 - v. a URI or hyperlink to the Licensed Material to the extent reasonably practicable;
 - b. indicate if You modified the Licensed Material and retain an indication of any previous modifications; and
 - c. indicate the Licensed Material is licensed under this Public License, and include the text of, or the URI or hyperlink to, this Public License.
2. You may satisfy the conditions in Section 3(a)(1) in any reasonable manner based on the medium, means, and context in which You Share the Licensed Material. For example, it may be reasonable to satisfy the conditions by providing a URI or hyperlink to a resource that includes the required information.
3. If requested by the Licensor, You must remove any of the information required by Section 3(a)(1)(A) to the extent reasonably practicable.

b. ShareAlike.

In addition to the conditions in Section 3(a), if You Share Adapted Material You produce, the following conditions also apply.

1. The Adapter's License You apply must be a Creative Commons license with the same License Elements, this version or later, or a BY-SA Compatible License.
2. You must include the text of, or the URI or hyperlink to, the Adapter's License You apply. You may satisfy this condition in any reasonable manner based on the medium, means, and context in which You Share Adapted Material.
3. You may not offer or impose any additional or different terms or conditions on, or apply any Effective Technological Measures to, Adapted Material that restrict exercise of the rights granted under the Adapter's License You apply.

Section 4 -- Sui Generis Database Rights.

Where the Licensed Rights include Sui Generis Database Rights that apply to Your use of the Licensed Material:

- a. for the avoidance of doubt, Section 2(a)(1) grants You the right to extract, reuse, reproduce, and Share all or a substantial portion of the contents of the database;
- b. if You include all or a substantial portion of the database contents in a database in which You have Sui Generis Database Rights, then the database in which You have Sui Generis Database Rights (but not its individual contents) is Adapted Material, including for purposes of Section 3(b); and
- c. You must comply with the conditions in Section 3(a) if You Share all or a substantial portion of the contents of the database.

For the avoidance of doubt, this Section 4 supplements and does not replace Your obligations under this Public License where the Licensed Rights include other Copyright and Similar Rights.

Section 5 -- Disclaimer of Warranties and Limitation of Liability.

- a. UNLESS OTHERWISE SEPARATELY UNDERTAKEN BY THE LICENSOR, TO THE EXTENT POSSIBLE, THE LICENSOR OFFERS THE LICENSED MATERIAL AS-IS AND AS-AVAILABLE, AND MAKES NO REPRESENTATIONS OR WARRANTIES OF ANY KIND CONCERNING THE LICENSED MATERIAL, WHETHER EXPRESS, IMPLIED, STATUTORY, OR OTHER. THIS INCLUDES, WITHOUT LIMITATION, WARRANTIES OF TITLE, MERCHANTABILITY, FITNESS FOR A PARTICULAR PURPOSE, NON-INFRINGEMENT, ABSENCE OF LATENT OR OTHER DEFECTS, ACCURACY, OR THE PRESENCE OR ABSENCE OF ERRORS, WHETHER OR NOT KNOWN OR DISCOVERABLE. WHERE DISCLAIMERS OF WARRANTIES ARE NOT ALLOWED IN FULL OR IN PART, THIS DISCLAIMER MAY NOT APPLY TO YOU.
- b. TO THE EXTENT POSSIBLE, IN NO EVENT WILL THE LICENSOR BE LIABLE TO YOU ON ANY LEGAL THEORY (INCLUDING, WITHOUT LIMITATION, NEGLIGENCE) OR OTHERWISE FOR ANY DIRECT, SPECIAL, INDIRECT, INCIDENTAL, CONSEQUENTIAL, PUNITIVE, EXEMPLARY, OR OTHER LOSSES, COSTS, EXPENSES, OR DAMAGES ARISING OUT OF THIS PUBLIC LICENSE OR USE OF THE LICENSED MATERIAL, EVEN IF THE LICENSOR HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH LOSSES, COSTS, EXPENSES, OR DAMAGES. WHERE A LIMITATION OF LIABILITY IS NOT ALLOWED IN FULL OR IN PART, THIS LIMITATION MAY NOT APPLY TO YOU.
- c. The disclaimer of warranties and limitation of liability provided above shall be interpreted in a manner that, to the extent possible, most closely approximates an absolute disclaimer and waiver of all liability.

Section 6 -- Term and Termination.

- a. This Public License applies for the term of the Copyright and Similar Rights licensed here. However, if You fail to comply with this Public License, then Your rights under this Public License terminate automatically.
- b. Where Your right to use the Licensed Material has terminated under Section 6(a), it reinstates:
 1. automatically as of the date the violation is cured, provided it is cured within 30 days of Your discovery of the violation; or
 2. upon express reinstatement by the Licensor.

For the avoidance of doubt, this Section 6(b) does not affect any right the Licensor may have to seek remedies for Your violations of this Public License.

- c. For the avoidance of doubt, the Licensor may also offer the Licensed Material under separate terms or conditions or stop distributing the Licensed Material at any time; however, doing so will not terminate this Public License.
- d. Sections 1, 5, 6, 7, and 8 survive termination of this Public License.

Section 7 -- Other Terms and Conditions.

- a. The Licensor shall not be bound by any additional or different terms or conditions communicated by You unless expressly agreed.
- b. Any arrangements, understandings, or agreements regarding the Licensed Material not stated herein are separate from and independent of the terms and conditions of this Public License.

Section 8 -- Interpretation.

- a. For the avoidance of doubt, this Public License does not, and shall not be interpreted to, reduce, limit, restrict, or impose conditions on any use of the Licensed Material that could lawfully be made without permission under this Public License.
- b. To the extent possible, if any provision of this Public License is deemed unenforceable, it shall be automatically reformed to the minimum extent necessary to make it enforceable. If the provision cannot be reformed, it shall be severed from this Public License without affecting the enforceability of the remaining terms and conditions.

- c. No term or condition of this Public License will be waived and no failure to comply consented to unless expressly agreed to by the Licensor.
- d. Nothing in this Public License constitutes or may be interpreted as a limitation upon, or waiver of, any privileges and immunities that apply to the Licensor or You, including from the legal processes of any jurisdiction or authority.

=====
Creative Commons is not a party to its public licenses. Notwithstanding, Creative Commons may elect to apply one of its public licenses to material it publishes and in those instances will be considered the "Licensor." The text of the Creative Commons public licenses is dedicated to the public domain under the CC0 Public Domain Dedication. Except for the limited purpose of indicating that material is shared under a Creative Commons public license or as otherwise permitted by the Creative Commons policies published at creativecommons.org/policies, Creative Commons does not authorize the use of the trademark "Creative Commons" or any other trademark or logo of Creative Commons without its prior written consent including, without limitation, in connection with any unauthorized modifications to any of its public licenses or any other arrangements, understandings, or agreements concerning use of licensed material. For the avoidance of doubt, this paragraph does not form part of the public licenses.

Creative Commons may be contacted at creativecommons.org.

Trademarks

Choupo is a trademark of TalentGround Lda.

Anthropic, Claude, and Claude Code are trademarks or registered trademarks of Anthropic, PBC.

OpenFOAM is a registered trademark of OpenCFD Ltd.

Contents

1	What this guide is — and what it is not	1
2	How a tool feeds itself	2
3	The constructions	3
4	Constructions not yet documented here	10
5	Using a tool in a lesson	11
6	Notes for maintainers	12

1 What this guide is — and what it is not

EduTools is the plane of Choupo's browser application where the *classical graphical methods* are constructed over curves the engine computes: the McCabe–Thiele staircase, the Kremser recovery curve, the ε -NTU chart, the Levenspiel plot, the Van Heerden ignition diagram, the pinch composite curves, and the rest. Each tool draws a construction a student has met on paper, on numbers a real solver produced, and puts the method's answer beside the engine's.

Key idea. This guide is a **lesson companion**, not a theory manual. It says what each construction is *for*, what to turn, what to watch, and what the picture is silent about. It contains no derivations at all.

That absence is deliberate and it is architectural. Every equation behind these tools already has exactly one home — `docs/theoryGuide.pdf` — and every live tool declares, in its registry entry, the named destination in that guide where its derivation lives. A second document carrying the same derivations would be a second home for the same statement, and within one semester the two would disagree. So this guide *points*, and the Theory Guide *derives*. When you want to know why $\varepsilon = (1 - e)/(1 - C_r e)$, follow the pointer. When you want to know what a class will get wrong about it, you are in the right document.

The five questions each tool section answers

Every tool documented here is written to the same five headings, in the same order, because a lesson is more portable than a description:

1. **The question** — in one sentence a student would recognise from a problem sheet.
2. **What to vary, what to watch** — the specific knob that makes the lesson visible, and what should happen when you turn it.
3. **The misconception the construction exposes** — what students actually get wrong, not merely what is true. This is the part worth reading twice.
4. **What the picture does not say** — the limits of the construction. In this project that is treated as part of teaching it, never as an apology for it.
5. **Where the derivation lives** — a pointer into the Theory Guide, never a copy of it.

Where the other material is

- **Theory Guide** — every derivation, every hypothesis, every worked example. The authority for all physics.
- **Explorer Guide** — the *property surfaces* (T - x - y , $\gamma(x)$, P^{sat} scans). The split criterion between the two planes is stated in the application itself: method-construction $\rightarrow$ EduTools, property-surface $\rightarrow$ Explorer.
- **Tutorials Guide** — the runnable cases. Every EduTools tool runs one of them; this guide names which.
- **User Guide** — authoring cases on disk, which is where any finding from a tool should end up.

2 How a tool feeds itself

What you'll learn. Where the numbers on the screen come from, why a tool works with no case open, and what a knob is actually allowed to change.

2.1 Opening a tool

EduTools is a tab of its own. The tool chooser leads the chrome row on that tab; on a case tab showing EduTools in its body the chooser is one slim row above the construction. Either way the list is the same, and a construction that is on the roadmap but not yet built is shown *disabled* rather than hidden — the menu states the roadmap instead of implying it.

Every tool is deep-linkable:

```
?workspace=methods&tool=<id>
```

The `methods` key is a contract and does not change with the workspace's caption, so a link already in a student's notes goes on working. The tool identifiers are the ones listed in §3 and §4.

Under the chooser sits a one-line caption of what the construction teaches, and beside it a book icon that opens the Theory Guide *at this tool's own section*. That icon is the pointer this whole guide is built around: a tool that cannot name its derivation is not finished, and a test in the application refuses an anchor the Theory Guide does not define.

2.2 Classroom, or your own run

Most tools default to **Classroom**: the tool clones a bundled tutorial — its *witness* case — writes your knob values into that case's own dictionary files, and solves it in the browser with the WebAssembly build of the same solver the command line runs. Nothing needs to be open, and nothing on disk is touched.

When the application's current run also carries the surfaces a tool reads, a source toggle offers **Current run** beside the classroom witness. A tool that a run cannot feed says so and stays empty; it never draws something else wearing the same name.

Key idea. A knob turns a *declared scalar* in the witness's dictionary and nothing else. The engine then recomputes everything. A knob that cannot find its key fails loudly rather than silently doing nothing, and a knob that would not reach the physics is deliberately absent — each absence recorded with its reason in the tool's own source.

That last rule has teeth. Several plausible-looking controls are missing on purpose: a pressure that a liquid-phase rate law never reads would be a placebo control; an integrator step count sitting beside physical knobs invites reading numerics as physics; a kinetic pre-exponential that a witness deliberately re-tuned would leave the tool teaching a case other than the one it names.

2.3 Why the picture can be trusted

Three standing rules govern this plane, and they are worth telling a class about, because they are the reason the construction and the simulator cannot quietly diverge.

1. **No physics in the browser.** Every curve is an engine column, an engine KPI, or an engine-written report file. The browser draws.
2. **Method geometry is the one exception, and it is labelled.** A staircase, a trapezoid area, a textbook closed form, a heat cascade re-run over published curves — these *are* the method being taught, so a few tools own them. Where that happens the tool says so on screen, and the engine's own number is the judge: agreement is verification, and a disagreement is a finding about the drawing, never a moved answer.
3. **An absence stays an absence.** A number the engine did not publish is not rendered as zero and not invented. Solver advisories are lifted out of the run log and shown, because these tools have no log tab to bury them in.

Common pitfall. A tool that shows nothing is usually telling you something. “This run publishes no Van Heerden surface” means the reactor you solved was isothermal — there is no generation-versus-removal diagram for it. The honest empty state is a diagnosis; read it before changing the tool.

3 The constructions

Six constructions are documented in full below. The remaining six live tools are listed in §4 with what is missing from each, because a thin lesson is worse than an admitted gap.

The six were chosen to span the three transfer subjects a course actually has to cover, two constructions each, and to prefer the tools whose *misconception* is both common and hard to dislodge by telling:

- **Mass transfer** — McCabe–Thiele (§3.1) and Kremser (§3.2).
- **Heat transfer** — ε -NTU (§3.3) and pinch composite curves (§3.4).
- **Reaction** — Levenspiel (§3.5) and Van Heerden (§3.6).

3.1 Distillation: the McCabe–Thiele staircase

Declared anchor: `ch:distillation`.

The question

A binary feed of composition x_F is to be split into a distillate x_D and a bottoms x_W . At reflux ratio R and feed quality q , how many equilibrium stages does it take, and on which stage does the feed enter?

What to vary, what to watch

Try it now. Set a sharp split ($x_D = 0.95$, $x_W = 0.05$, $x_F = 0.5$), then drag R down toward the red $R_{\min}$ tick on the slider. Watch three things at once: the staircase steps multiply, the *approach to pinch* bar fills and reddens, and at $R \leq R_{\min}$ the construction stops with a banner naming the pinch abscissa. Then drag R up and watch how little the stage count changes once you are clear of the cliff.

- R — the primary knob. The slider can be bound to R directly or to $R/R_{\min}$; the second binding is the design lens (“1.3× minimum”) and makes the cliff a fixed landmark at 1.0 instead of a number that moves.
- q — rotates the q -line about (x_F, x_F) . Watch the feed-stage index move, and watch $R_{\min}$ itself change: the same column, the same specifications, a different minimum reflux, because the feed arrived hotter or colder.
- E_{MV} — the Murphree tray efficiency. Below 1 the staircase steps to a dashed *pseudo*-curve and the count becomes a count of real trays.
- **The partial-condenser switch** — adds exactly one equilibrium stage, and the readout says so.
- **The components, γ model and P** — these are the only settings that re-run the engine, because they are the only ones that change the equilibrium curve. Everything else redraws instantly.

The misconception the construction exposes

Common pitfall. That the equilibrium curve responds to the reflux ratio. It is the commonest confusion in the whole subject, and it is usually invisible because on paper the student redraws the entire figure each time. Here the curve is a frozen engine result and the staircase is pure geometry over it, so turning R at sixty frames a second while $y^*(x)$ does not so much as flicker makes the point physically: *reflux is an operating decision; the equilibrium curve is a statement about the mixture*. Change the pressure or the activity model and the engine re-runs and the curve moves — which is the same lesson from the other side.

Two further confusions the same picture settles:

- **That $R_{\min}$ is a property of the column.** It is the intersection of the q -line with the equilibrium curve — feed composition, feed quality, product specifications and thermodynamics, and no equipment at all. Turn q and $R_{\min}$ moves although nothing has been built or unbuilt.
- **That more reflux is better because it needs fewer stages.** The chart shows only one half of that trade. Stage count falls steeply just above $R_{\min}$ and then flattens; the vapour traffic $V = (R + 1)D$, and with it the reboiler duty, the condenser duty and the column diameter, goes on rising linearly and is *nowhere on this diagram*. A student who optimises on the staircase alone will choose a column that cannot be paid for.

What the picture does not say

- **The operating lines are straight because Constant Molar Overflow is assumed.** The tool states this permanently under the chart rather than in a footnote. CMO is an energy assumption (equimolar latent heats),

and it is the one thing on the diagram that is not the real model. The equilibrium curve, by contrast, is the real curve at that pressure — not a constant- α toy.

- **No energy, no hydraulics, no diameter.** There is no reboiler duty, no condenser duty, no pressure drop, no flooding check. A column that is impossible to build converges perfectly well here.
- **Stages are not trays** unless $E_{MV} < 1$, and E_{MV} is a *declared* number — from a correlation, a chart, or plant data. The engine will not invent it.
- **The azeotrope you see belongs to the declared model.** If no curated binary-interaction pair covers the system, the tool announces that it is drawing *ideal* mixing and that the diagram therefore cannot show an azeotrope at all. Read that banner: an absent azeotrope may be a fact about the mixture or a fact about the data coverage, and only the banner tells you which.
- **Binary only.** A third component has no axis here.

Where the derivation lives

Derivation. Theory Guide, *Distillation column*, *Wang-Henke bubble-point* (`ch:distillation`) — the stage model, CMO, and the rigorous column this construction is the hand method for. The closed forms for the two limits the staircase locates geometrically, $N_{\min}$ and $R_{\min}$, are derived in *Shortcut distillation: Fenske–Underwood–Gilliland* (`ch:fug`). The Murphree efficiency and its effective- K treatment are in *Tray hydraulics* (`ch:hydraulics`). The staircase construction itself — horizontal to the operating line, vertical to the equilibrium curve — is drawn and explained in the absorber chapter (`ch:absorber`), where the same geometry serves a counter-current cascade.

3.2 Absorption: the Kremser shortcut, judged

Declared anchor: `ch:absorber`.

The question

A gas carrying a soluble solute is washed counter-currently with a lean solvent. How much of the solute do N stages recover — and does the one-line shortcut agree with what the column actually does?

What to vary, what to watch

The construction has two halves and the lesson is in the gap between them. The curve is the Kremser closed form, recovery against N at the absorption factor $A = L/(KV)$ the engine published. The point is the engine's own stagewise recovery for the column that was solved. The chip between them is the labelled deviation.

Try it now. Start from the witness (an ammonia/water absorber, six stages, both feeds at 298.15 K). Now raise the ammonia in the gas feed, step by step, and watch *two* chips together: `dT_rise` climbing as more heat of absorption is released, and the deviation between the shortcut and the column growing with it. Then put the ammonia back and raise the solvent flow instead: A rises, recovery rises, and the deviation shrinks.

- **Stages N** — the knob students reach for first. Watch how quickly the curve flattens: past a handful of stages, more stages buy very little.
- **Solvent flow L** — the knob that actually moves the answer, because it moves A .
- **Solute feed flow** — the knob that breaks the shortcut, by making the column non-isothermal.
- **Feed temperatures** — both of them, gas and solvent, with the `nonIsothermal` flag and `dT_rise` as the readout.

The misconception the construction exposes

Common pitfall. **That the deviation is an error.** A student who has only met the closed form reads any gap between shortcut and simulator as a defect — a bad K , a loose tolerance, a bug. It is neither. Kremser assumes *one constant* A , which means a straight operating line and a straight equilibrium line, which means an isothermal column. Absorption is exothermic. The solvent heats as it descends, K rises with temperature, and $A = L/(KV)$ therefore *falls* exactly where the column is doing its work. The engine re-evaluates K stage by stage; the shortcut cannot. The gap is the assumption failing, and it is real.

The direction matters as much as the size, and it is the part worth labouring: for a soluble, exothermic solute the isothermal Kremser is *optimistic*. It promises recovery the column will not deliver. A shortcut that erred the other way would merely be conservative; this one sends you to site with a column that underperforms.

A second confusion, milder but persistent:

- **That $A > 1$ settles the matter.** A is a ratio of two slopes, not a pass mark. At A barely above one, recovery approaches its ceiling so slowly that no realistic stage count gets there; at A comfortably above one, a few stages do almost everything. The curve makes the difference between those two situations obvious in a way that the inequality $A > 1$ never can.

What the picture does not say

- **The A on the chip is a single number for a column whose K varies.** It is evaluated at the feed temperature. That is precisely why the two sides of the deviation chip are not the same calculation — and precisely what makes the chip informative.
- **Absorbers only.** A stripper publishes a stripping factor $S = KV/L$ and a temperature *drop*, not these keys, so it does not activate this tool. That is a correct refusal, not a missing feature: the mirrored construction is a different lesson.
- **Stages are theoretical.** No packing height, no HETP, no tray efficiency, no flooding.
- **No solvent circuit.** The lean solvent arrives lean. A real plant regenerates it, and the regenerator's residual solute sets a floor on the recovery that no stage count can beat. That loop is not on this diagram.

Where the derivation lives

Derivation. Theory Guide, *Absorber and stripper: the counter-current cascade* (**ch:absorber**). The absorption factor $A_i = L/(K_i V)$ and the tridiagonal stage system are in *The counter-current cascade and the absorption factor*; the reason the engine does not use the closed form, and the temperature bulge that makes the isothermal shortcut optimistic, are in *Why the energy balance matters*.

3.3 Heat exchange: effectiveness against NTU

Declared anchor: **ch:hx-entu**.

The question

I have an exchanger of area A and overall coefficient U , and two streams with known inlet temperatures and flows. What duty do I actually get — and if I want more, will more area give it to me?

What to vary, what to watch

The chart is the family of $\varepsilon(\text{NTU})$ curves at several capacity ratios C_r , with the solved exchanger's own point placed on the curve for its own C_r . A chip reports whether the drawn geometry reproduces the engine's effectiveness; when it does not, that is a statement about the configuration the tool assumed, never about the point.

Try it now. Double the area, from 10 to 20 m², and read the duty before and after. Then double it again, to 40. Note how much of the first doubling you got back on the second. Now set the two heat-capacity rates far apart (raise one flow, drop the other), so $C_r \rightarrow 0$, and switch between counter-current and co-current: the two curves close up until they lie on top of each other.

- **Area A and coefficient U** — both enter only through $\text{NTU} = UA/C_{\min}$, which is the first thing to notice: a better coefficient and a bigger exchanger are the same move on this chart.
- **The two flows** — they set $C_{\min}$, $C_{\max}$ and hence both NTU and C_r , so a flow change slides the point along one curve *and* moves it to another.
- **The two inlet temperatures** — they do not move the point at all. They set $Q_{\max}$, and therefore the duty in kilowatts, but ε , NTU and C_r are all independent of them. Verifying that is a good five minutes.
- **The configuration** — counter-current, co-current, or one shell with two tube passes.

The misconception the construction exposes

Common pitfall. **That duty scales with area.** NTU is linear in A ; ε is emphatically not. Every curve on the chart bends over, and past roughly $\text{NTU} = 3$ the return on further area is nearly nothing — the exchanger is already delivering most of what the inlet temperatures permit, and no amount of metal buys what thermodynamics has capped. Students who have only seen $Q = UA \Delta T_{LM}$ read a proportionality that is not there, because ΔT_{LM} collapses as the exchanger gets good.

The second one is more interesting, and the chart proves it in one move:

- **That counter-current is always better.** It is never worse, but at $C_r = 0$ — one stream condensing or boiling, or simply so large that its temperature barely moves — the two arrangements give *identical* effectiveness, and the curves coincide exactly. The advantage of counter-current flow is purchased entirely by the temperature change of the smaller stream, so when that change is absent there is nothing to buy. This is worth doing on the screen because it is the kind of fact that is remembered as a slogan and applied where it does not hold.
- **That ε is an efficiency, so $\varepsilon = 0.75$ means a quarter is wasted.** Nothing is wasted; the exchanger is adiabatic to its surroundings and every joule that leaves the hot stream arrives in the cold one. ε is normalised by $Q_{\max} = C_{\min}(T_{h,\text{in}} - T_{c,\text{in}})$, a ceiling set by the *inlet temperatures*, which is a statement about what an infinitely large exchanger could do — not about losses.

What the picture does not say

- **It is a rating result, not a design.** “Given this hardware, what happens?” is the question answered. “What hardware do I need?” is a different loop, with pressure drop and geometry in it.
- **No pressure drop, no fouling, no cost.** The chart’s flat tail says extra area stops paying in duty; it says nothing about what the area costs, and nothing about the pumping power the extra length consumes.
- **Heat-capacity rates are taken as constant** across the pass. A stream whose c_p swings, or which changes phase part way, is outside the assumption.
- **Three configurations only.** Cross-flow arrangements, and the correction factors that go with them, are not offered here.

Where the derivation lives

Derivation. Theory Guide, *Two-stream heat exchanger: the ε -NTU rating method* (`ch:hx-entu`) — the definitions of C_r and NTU, the counter-current and co-current closed forms, the duty from $Q_{\max}$, and the $UA LMTD = Q$ self-check. The design problem the rating chart does not answer — geometry, pressure drop, the sizing loop — is the section immediately following it, *Heat exchanger DESIGN*.

3.4 Heat integration: the composite curves and the pinch

Declared anchor: `ch:pinch`.

The question

Before a single exchanger is drawn: what is the least hot utility and the least cold utility this set of streams can possibly need?

What to vary, what to watch

The tool draws the engine’s own published composite curves, reports its targets $Q_{H,\min}$ and $Q_{C,\min}$ and the pinch temperature, re-runs the heat cascade over the published curves as a cross-check, and renders the engine’s candidate-match table verbatim.

Try it now. Change nothing but $\Delta T_{\min}$ — from 20 K down to 10, then up to 30. Watch the composite curves slide together and apart, the two targets move in opposite directions, and the pinch temperature itself change. Nothing physical has been altered: not a stream, not a flow, not a temperature. Ask the class what, then, has changed.

- $\Delta T_{\min}$ — the decisive knob, and the one that is a *choice*.
- **The supply temperatures** — move one stream’s start and watch whether the pinch stays where it was. Sometimes it does not, and the region boundaries in the candidate table move with it.
- **The flows** — a flow scales that stream’s CP , which changes the slope of its segment of the composite curve. A steep segment and a flat one are the same duty over different temperature spans.
- **The candidate table** — read the temperature-feasibility column and the pinch-rule column separately. A match may be thermodynamically possible and still violate the CP rule at the pinch.

The misconception the construction exposes

Common pitfall. That the pinch is a property of the plant. It is a property of the stream data *plus a number the engineer chose*. Turning $\Delta T_{\min}$ moves the pinch temperature and both targets while the process stands still. Students routinely quote “the pinch is at 115°C” as though it had been measured; it was assumed into existence, half of it by the choice of driving force, and the value of that choice is an economic trade-off between exchanger area and utility bill that this pass does not make for you.

Two more, and the third is the one that decides coursework marks:

- **That a target is a design.** The table lists *thermodynamically admissible candidates* and never ranks them. The word “optimal” does not appear anywhere in this pass, and a gate in the test suite enforces that. Reaching the target may require more exchangers, and more awkwardly placed ones, than anybody would build; plot plan, control, start-up and safety are not in the temperature table.
- **That heating below the pinch merely costs a little extra.** It costs *exactly its own duty*, and so does cooling above the pinch, and the two are additive:

$$\sum (\text{heating below}) + \sum (\text{cooling above}) = Q_{H,\text{current}} - Q_{H,\min}.$$

The violation diagnostics report both sums, and they are computed by different code from the targets — so the identity closing is a check you can do by hand and the tool can fail. A student who has only the slogan “do not transfer heat across the pinch” cannot say how much a violation costs; this identity says exactly how much.

What the picture does not say

- **Energy targets only.** Area targets, capital targets, and the capital-versus-energy trade-off that would let you choose $\Delta T_{\min}$ economically are a further phase and are not implemented. The Theory Guide states this in the same words rather than describing something the engine does not have.
- **It never rewrites the network.** The flowsheet you wrote is the flowsheet that ran; the pass analyses it and stops.
- **A unit enters as its net duty.** A column with a reboiler and a condenser is a single net number unless you model the two as separate units — and for a column that is usually the wrong picture. Splitting is the fix, and it is your decision, not the pass’s.
- **The grand composite curve is derived in view.** The engine publishes the hot, cold and shifted composite curves; the tool builds the grand composite from those, and labels it as such. The cross-check chip exists so you can see that the derivation reproduces the engine’s targets.

Where the derivation lives

Derivation. Theory Guide, *Pinch analysis: the target before the network* (`ch:pinch`) — the *CP* line, why $\Delta T_{\min}$ shifts the axes, the problem table cascade by cascade, the composite curves, the candidate matches, the violation identity, and an explicit *What this pass does not do*.

3.5 Reactor sizing: the Levenspiel plot

Declared anchor: `ch:pfr`.

The question

The same reaction, the same feed, the same conversion — which reactor is smaller, a plug-flow tube or a stirred tank, and by how much?

What to vary, what to watch

One chart carries $1/(-r_A)$ against conversion X_A , and on it two areas: the plug-flow reactor’s integral $\int_0^{X_{\text{out}}} dX/(-r_A)$ under the curve, and the stirred tank’s rectangle of height $1/(-r_A)$ at the outlet and width X_{out} . Both witnesses are twins — byte-identical feed, kinetics and thermodynamics — so the comparison is between reactors and never between chemistries.

Try it now. Raise the plug-flow reactor’s volume so X_{out} climbs, and watch the rectangle and the area separate. At low conversion they nearly coincide; at high conversion the rectangle towers over the area. Then lower the temperature: the whole curve lifts (a slower rate is a larger ordinate) and both reactors grow —

but the *ratio* between them is governed by the curve's shape, not its height.

- **Reactor temperature** — through the Arrhenius constant.
- **The two feed flows** — the limiting reactant sets F_{A0} and the co-reactant changes what the rate law sees.
- **The plug-flow volume** — the knob that walks X_{out} along the curve, which is the axis the whole lesson lives on.

The misconception the construction exposes

Common pitfall. That the stirred tank needs more volume because it is somehow a worse reactor. Students reach for a hardware explanation — poorer mixing, dead zones, short-circuiting. The chart shows that the cause is the opposite and is purely geometric: a stirred tank is *perfectly* mixed, so every molecule in it sits at the outlet composition and therefore at the outlet rate — the *lowest* rate anywhere in the duty. The tube sees the whole range of rates from inlet to outlet. The rectangle circumscribes the area because perfect mixing throws away every fast rate the reaction was willing to give. *Being well mixed is what costs the volume.*

And immediately after that, the guard against over-learning it:

- **That “a CSTR always needs more volume” is a law.** It follows from the curve *rising* with conversion, which is what positive-order kinetics do. Draw a rate law whose $1/(-r_A)$ has a minimum — autocatalysis, strong product inhibition — and the rectangle can be the smaller of the two over part of the range, which is why real plants sometimes put a tank first and a tube after it. The construction is valuable exactly because it is a picture and not a rule: it shows you how to check, on any kinetics, rather than what to remember.
- **That the smaller reactor is the cheaper one.** Volume is not price. A large stirred tank can be considerably cheaper than a small tubular reactor with the same duty once you count fabrication, catalyst containment, cleaning and control.

What the picture does not say

- **The comparison is isothermal.** Both witnesses run at the same declared temperature. Nothing here shows the thermal behaviour that makes the two reactors genuinely different animals — for that, go to §3.6.
- **No residence-time distribution.** Plug flow and perfect mixing are the two ideal limits; every real reactor is between them, and neither line on this chart is a real vessel.
- **Reversible kinetics are clipped, and the clipping is announced.** Past equilibrium the engine's rate goes negative and those points are excluded from the area, with the exclusion stated in the chart annotation. An integral run through them would be arithmetic, not physics.
- **The stirred tank's volume is not a knob here,** for a recorded reason: the witness declares it inline, out of reach of the override grammar the classroom knobs use. It always runs its authored value. This is stated in the tool's own provenance line rather than left to be discovered.

Where the derivation lives

Derivation. Theory Guide, *Plug-flow reactor* (ch:pfr) — the differential balance, the RK4 integration, and the first-order analytic check that gives the canonical comparison at $k\tau = 1$ ($X^{\text{PFR}} = 1 - e^{-1} = 0.632$ against $X^{\text{CSTR}} = 1/(1 + k\tau) = 0.500$), which is this construction in closed form for one special case. The stirred tank's own extent formulation is in *Continuous stirred-tank reactor* (ch:cstr).

3.6 Multiple steady states: the Van Heerden diagram

Declared anchor: ch:cstr.

The question

The same reactor, the same feed, the same everything — so why does it sometimes sit cold and sometimes run hot, and could it be made to sit in between?

What to vary, what to watch

The diagram is heat **generated** $G(T)$ against heat **removed** $R(T)$, both drawn from the engine's own scan of the reactor's steady-state equation. Generation is a sigmoid: the rate rises exponentially with temperature and then

saturates once the reactant is gone. Removal is a straight line, because in an adiabatic vessel the only sink is the sensible heat that leaves with the product. A straight line can cut a sigmoid three times.

Try it now. Drag `T_guess` slowly from 280 K to 430 K and watch the *reported* marker. For a long stretch nothing happens; then it jumps to another crossing on a diagram that has not moved at all. Same equipment, same feed, same equations — a different answer, decided by where you started. That is not a numerical artefact; it is why real reactors have a start-up procedure.

- **`T_guess`** — the decisive knob. The engine finds *all* the roots, prints them, and reports the one nearest your guess.
- **Feed temperature** — slides the removal line. Push it up far enough and the two lower crossings merge and vanish; the reactor can then only be ignited.
- **Reactor volume** — stretches the generation sigmoid against a removal line that does not move with it.
- **The steadyStates count and the ignition span** — how many crossings there are, and how far the reactor jumps between the coldest and the hottest.

The misconception the construction exposes

Common pitfall. That three answers means the solver is broken. Students trained on “the equation has *an* answer” read multiplicity as a defect — a bad initial guess, a tolerance too loose, a bug to be reported. It is the physics of the system, and the diagram is the proof: an exponential generation curve and a linear removal line intersect three times over a range of conditions, and each intersection is a genuine steady state of the same hardware. The initial guess is not a numerical convenience in this problem. It is the start-up procedure, written as a number.

The one that is harder, and better:

- **That the middle state is merely difficult to converge to.** It is not difficult; it is *unstable*. A steady-state solver will sit on it happily, which is exactly what makes it dangerous pedagogy: the number exists and the reactor cannot hold it. Nudge the temperature up and generation exceeds removal, so it climbs further; nudge it down and it falls to the extinguished state. “The solver converged” and “the plant can run there” are different claims, and this is the cleanest demonstration in the corpus that the second does not follow from the first.
- **That the ignited state is the one you want.** It is the one with the conversion. It may also be past a selectivity limit, past a catalyst’s sintering temperature, or past the vessel’s design pressure — none of which appear on a diagram whose only axes are temperature and heat.

What the picture does not say

- **It is a steady-state diagram.** It says which states *exist*. It does not say how the reactor travels between them, how long ignition takes, whether it overshoots, or what the transient does to the catalyst. That is the dynamic simulator’s subject.
- **The instability flag is an ordering, not an analysis.** With exactly three roots the tool marks the middle one, which is arithmetic on the engine’s own root list. With any other count it makes *no* stability claim at all — a restraint worth pointing out to a class, because it is the difference between a result and a habit.
- **The removal line is straight because this reactor is adiabatic.** Add a cooling jacket at a fixed coolant temperature and it is still straight, with a different slope and intercept; let the coolant temperature vary along the vessel and it is not straight at all, and the geometry of “how many crossings” has to be re-argued.
- **The kinetics are a declared teaching variant.** The witness’s own header says so, and its Arrhenius parameters are deliberately *not* knobs: a construction about start-up should not silently become a construction about a different chemistry.

Where the derivation lives

Derivation. Theory Guide, *Continuous stirred-tank reactor* (`ch:cstr`) — the material balance in the reaction extent and the one-dimensional solve the engine performs, which is the equation whose roots this diagram displays. The witness case `tutorials/steady/reactors/cstr05_multiplicity` carries the generation-versus-removal argument in its own `flowsheetDict` header, and is the fullest written statement of the construction in the tree; the tool quotes it.

4 Constructions not yet documented here

Six live tools are *not* written up above. They are listed here with what exists and what is missing, because an admitted gap is a better guide than six thin sections. Each is a working tool: what is absent is the lesson material, not the construction.

For every entry below, what is missing is the same three things:

- the **misconception** the construction exposes — the part that has to be observed in a classroom before it can be written down, and the part that cannot be guessed from the source;
- **what the picture does not say** — the limits, stated with the same care as the six above;
- a worked “**what to vary, what to watch**” sequence, tried on the tool rather than inferred from its knobs.

Psychrometric chart (tool=psychro)

The humid-gas state map: saturation, relative-humidity lines, adiabatic-saturation and true wet-bulb lines, over any carrier gas and condensable pair the catalogue can serve. Every line is engine-computed. *Declared anchor:* `ch:drying`.

Drying curve, batch tray (tool=drying)

The two classical drying plots side by side on one run — moisture against time, and rate against moisture — with the critical moisture visible as the corner where a flat rate begins to fall. The tool is careful about one thing that deserves writing up properly: the engine omits the break time entirely when the crossing was never observed, and the tool reports *which* absence it is rather than drawing a zero. *Declared anchor:* `ch:drying`.

Cooling tower, Merkel (tool=merkel)

The saturated-air enthalpy curve above, the operating line below, and the gap between them shaded — that gap is the driving force the packing has to buy. A chip holds the four-point Chebyshev hand method against the engine’s converged integral. *Declared anchor:* `ch:coolingTower`.

Batch still, Rayleigh (tool=rayleigh)

The graphical Rayleigh integration: the area under $1/(y^* - x)$ between the pot’s final composition and the charge *is* $\ln(W_0/W)$, drawn over the engine’s own equilibrium curve and judged against the engine’s rigorously integrated still. *Declared anchor:* `ch:rayleigh`.

Pump against system curve (tool=pump-system)

The operating point as an intersection: the pump’s pressure rise falling with flow against the pipe system’s demand rising with it. The tool is explicit that the “pump curve” is whatever the pump *model* published, and greys it out with the caveat spelled in full when the model was specified by a fixed pressure rise and the curve is therefore the specification echoed back. *Declared anchor:* `ch:rotating`.

Adsorption breakthrough (tool=breakthrough)

The S-shaped breakthrough curve against the ideal square wave drawn at the engine’s stoichiometric time: the mass-transfer zone consumes bed capacity long before the bed is saturated. *Declared anchor:* `ch:adsorption`.

5 Using a tool in a lesson

Three patterns that work, drawn from how the tools are built rather than from how they could be used.

Turn one knob, and predict first

Every classroom tool re-solves in the browser on each knob change, which makes the interesting move cheap: ask for a prediction, then turn the knob. The productive knobs are the ones whose consequence is counter-intuitive — $\Delta T_{\min}$ on the pinch tool, area on the ε -NTU chart, T_{guess} on the Van Heerden diagram, the solute loading on the Kremser tool. All four are documented above with what should happen.

Make the deviation chip the discussion

Several tools put a classical hand method beside the engine's answer and report the gap. That gap is the lesson, and its size is not the point — its *cause* is. On the Kremser tool the gap is the isothermal assumption failing, and it grows the more exothermic the duty. On the cooling-tower tool the gap is nearly zero, and saying so plainly rather than manufacturing drama is itself worth modelling for students: a hand method that reproduces a converged integral to five figures has been *validated*, and that is a result.

Read the refusal

An engine that refuses is teaching. A pinched McCabe-Thiele construction, an infeasible cooling tower, an absorber whose stripper twin does not activate the tool, a drying run that never reached its critical moisture — each of those is a message with a reason in it. The tools show the engine's own words verbatim rather than a generic failure, and the reason is usually the physics of the case rather than a mistake in the input.

Key idea. All models are wrong; some are useful. Everything in this plane is built so a student can see *which* assumption is doing the work — and what happens on the day it stops being true.

6 Notes for maintainers

One anchor, and it must resolve

Each tool's registry entry names a Theory Guide destination. The preamble shared by all the manuals sets `destlabel=true`, so every `\label` in the Theory Guide becomes a PDF named destination and the book icon jumps straight to it. An anchor the guide does not define fails *silently* in a browser — the PDF simply opens at page one — so a test in the application checks every declared anchor against the guide source. A tool without a resolvable anchor is not finished.

Anchors are chapter-level, and some chapters are broader than their tool

The declared anchor points at the section that owns the tool's *unit operation*, which is not always the section that derives the tool's *construction*. Where the two differ, the *Where the derivation lives* paragraphs above name both destinations rather than pretending the first covers everything. Two cases are worth knowing about before adding a seventh tool section:

- A construction may be the hand method for a chapter that derives the *rigorous* model instead — the staircase against the stagewise column, the Levenspiel areas against the differential balance.
- A construction may be argued most fully in its *witness case's* own dictionary header rather than in the manual. That is a real source and this guide cites it as one, but it is not a substitute for a derivation, and a section that has to reach for it is flagging a gap in the Theory Guide rather than filling one.

When a tool changes

A knob added or removed, a chip relabelled, a witness re-parameterised: each of those can invalidate a *What to vary*, *what to watch* block here, and none of them will fail a build. The blocks are written to name knobs by their on-screen labels so a mismatch is at least visible to a reader with the tool open. Prose staleness is deliberately not gated in this project — a text search cannot tell a live claim from a recorded one — so the check is human, and it belongs in the same change that touches the tool.