



**BACTERIOLOGICAL WATER ANALYSIS**  
**USEPA Certified Water Laboratory**

Teton County Public Health

PHONE:

FAX:

Facility Name: Facility Type: Type Sample: EPA Number: Sample Location: Location Specifics: Physical Address:	Routine Sample
Chlorine Residual: pH:	4.50 ppm 7.4
Collected By: Collected Date/Time:	Sean Wetmore 12/10/2007 09:00 AM
Send Report To:	

HealthSpace ID: Lab ID: Date Received: Sample Condition: Date Analyzed: Type of Test: <b>Final Analysis:</b> Comments:	404 12/10/2007 Good 12/10/2007 Routine Sample <b>Safe</b>
---	--

Parameter	Result	Final Result
Total Bacterial Count		<100 / 100ml

\_\_\_\_\_ 12/12/2007  
Date Reported

**POOL/SPA WATER**

Final results are reported as total number of bacteria/ml. The maximum advised level for bacteria in a pool or spa is 100 bacterial/ml.