

# Job Test Certificate

SOP 31571 Job ID 1534 PO 11858CN3194MLH Aqua Cooling Solutions Ltd

**1 X SS.CVA-200 200mm Microbubble (de-aerator) Air Separator- Stainless  
25mm top & Bottom conection**

**How Tested:** Tested with air @ 21 Bar

**Date Tested:** 13 / 08 / 15

**Tested By (full name) :** Joe Haythorne **Sign:** J. Haythorne

**Witnessed By (full name) :** Steven G. **Sign:** Steve

**TESTED**

**Tested with air @ 21 Bar**

**OK PASSED**

**Fabricated Products UK Ltd**