

# Job Test Certificate

SOP 30216 Job ID 1527 PO 11817CN3217EB Aqua Cooling Solutions Ltd

1 X SS.CVA-250 250mm Microbubble (de-aerator) Air Separator- Stainless

How Tested: Tested with air @ 21 Bar

Date Tested: 13 / 08 / 2015

Tested By (full name) : Liam Levesley Sign. 

Witnessed By (full name) : Joe Haythorne Sign. 

TESTED  
Tested with air @ 21 Bar  
OK PASSED  
Fabricated Products UK Ltd