

Job Test Certificate

SOP 30216 Job ID 1527 PO 11817CN3217EB Aqua Cooling Solutions Ltd

X SS.CVA-250 250mm Microbubble (de-aerator) Air Separator- Stainless

How Tested: Tested with air @ 21 Bar

Date Tested: 13 / 08 / 2015

Tested By (full name): Liam Levesley **Sign:** 

Witnessed By (full name): Joe Haythorne **Sign:** 

TESTED
Tested with air @ 21 Bar
OK PASSED
Fabricated Products UK Ltd