

1 of 5

Job Test Certificate

SOP 30216 Job ID 1527 PO 11817CN3217EB Aqua Cooling Solutions Ltd

1 X SS.CVA-250 250mm Microbubble (de-aerator) Air Separator- Stainless

How Tested: Tested with air @ 21 Bar

Date Tested: 13 / 08 / 2015

Tested By (full name) : Liam Kennedy Sign: 

Witnessed By (full name) : Joe Haythorne Sign: 

TESTED

Tested with air @ 21 Bar

OK PASSED

Fabricated Products UK Ltd

Job Test Certificate

SOP 31571 Job ID 1534 PO 11858CN3194MLH Aqua Cooling Solutions Ltd

**1 X SS.CVA-200 200mm Microbubble (de-aerator) Air Separator- Stainless
25mm top & Bottom conection**

How Tested: Tested with air @ 21 Bar

Date Tested: 13 / 08 / 15

Tested By (full name) : Joe Haychose **Sign:** J. Haychose

Witnessed By (full name) : Steven G. **Sign:** Steven G.

TESTED

Tested with air @ 21 Bar

OK PASSED

Fabricated Products UK Ltd